LEGEND

CIRCUIT CHROUT NUM ₫⊗⊠□ੴ◎ **0** Þ DANAE D <u>م</u> PADOUBLE DUPLEX CONVENIENCE OUTLET 18" AFF TO CENTER EXCEPT AS NOTED SNOLE POLE SWITCH — MOUNTED 48" AFF TO TOP THREE WAY SWITCH — MOUNTED 48" AFF TO TOP FOUR WAY SWITCH SPECIALTY OUTLET DOWN LIGHT FIXTURE (# INDICATES TYPE PER FIXTURE SCHEDULE) FRACTIONAL HP MOTOR TEL/DATA RECEPTACLES (HALF SHADED DENOTES TELEPHONE AND DATA, CLEAR TELEPHONE ONLY) EBU - EMERGENCY LIGHT BATTERY UNIT, 120V VOLT AC. BATTERIES TO BE RATED FOR 90 MINUTES FOR CONNECTED LOAD. EXIT LIGHT ATLITE #PNLRU W/LED LAMPS BATTERY BACKUP ELECTRIC MOTOR CONTROLLER 208 V RECEPTACLE DUPLEX CONVENIENCE OUTLET 18" AFF TO CENTER EXCEPT AS NOTED POWER POLE CONNECTION. PANEL AND CIRCUITING AS INDICATED 1X4 LIGHT FIXTURE (∮ INDICATES TYPE PER FIXTURE SCHEDULE, DIAGONAL LINE DENOTES NIGHT LIGHT) 2X4 LIGHT FIXTURE (# INDICATES TYPE PER FIXTURE SCHEDULE) BODINE EMG. BALLASTED NIGHT LIGHT FIXTURE CABLE TRAY FOR COMMUNICATIONS AT BAR JOIST POWER FLOOR BOX disconnect switch — fused as required (diagonal line indicates fused) JUNCTION BOX - SIZED AS REQUIRED

WIED SUPPLINGE MECHANICAL EQUIPMENT

9

DOWUST FAN

PARTIAL CIRCUIT

NEATHERPROOF

ELECTRIC WATER COOLER

GROUND FAULT INTERRUPTER /W SURGE SUPPRESSOR

PANELXX - PANELBOARD- SEE SCHEDULES FOR CIRCUTING

FURNISHED BY OTHERS

COUNTER HEIGHT (SEE MILLWORK DRAWINGS FOR HEIGHT)

COUNTER HEIGHT (SEE MILLWORK DRAWINGS FOR HEIGHT)

HOSPITL GRAVE W/RED FACE AND PLATE, IF GFL, DEVICE TO HAVE SURGE SUPPRESSOR HOSPITL GROUND OUTLET /W SURGE SUPPRESSOR, ORANGE FACE AND PLATE BUSINGLY THERMAL OVERLOND SWITCH

BUSS DUCT

DRY TYPE TRANSFORMER

DRAWINGS
E100-LEGENDS
E200-SITE
E200-LIGHTING 1ST
E301-POWER 1ST
E301-POWER 2ND
E500-DETAILS

GENERAL NOTES:

1) ALL BRANCH CIRCUITS TO BE TYPE MC CABLE.
2) ALL ELECTRICAL MUST MEET NEC AND LOCAL CODES.
3) TELEPHONE AND DATA WIRNING BY OTHERS
4) TEMPERATURE CONTROL WIRNING BY OTHERS

Drawing Title:

SPRINKLER TAMPER SWITCH
SPRINKLER WATERFLOW SWITCH

FIRE ALARM VISUAL UNIT (NUMBER DENOTES CANDELA RATING) 6'8" AFF

FIRE ALARM HORN AND LIGHT UNIT - MOUNT 80" AFF
EXCEPT NO CLOSER THAN 6" TO CELLING, NUMBER DENOTES CANDELA RATING

▣

FIRE ALARM MANUAL STATION 48" AFF

FIRE ALARM SYSTEM

q Title:	REVISIONS		
TRICAL ID	Description:	Date:	
Ď			
NONE			
Progress 6/21/04			
lo.: 04425.flc	1		

ISSUED FOR REVIEW

Owner:

FIVE LIVER
COMPANY 5 MILK STREET
PORTLAND, MAINE
04 2 207 <i>-772-</i> 6404

MULTI-TENANT OFFICE BUILDIN

135 MARAINAL WAY PORTLAND, MAINE OAIOI

FAX: 774-1492	PHONE 879-1877	PORTLAND, MAINE 04101	175 ANDERSON STREET	ELECTRICAL CONTRACTORS	BH:Milliker

454 Cumberland Aven
Parland, NE 041
Phone: (207)774-44
Fax: (207)774-40

uww.CWSarch.o.