

ELECTRICAL PERMIT

City of Portland, Me.



Survie Financing
Bill 776 5517

To the Chief Electrical Inspector, Portland Maine:
The undersigned hereby applies for a permit to make electrical installations
in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
National Electrical Code and the following specifications:

Date

10/13/10

Permit #

3010 1700

CBL#

025 B 014

LOCATION: 127 MARGINAL WAY METER MAKE & #

CMP ACCOUNT #

OWNER

FORE RIVER Group

TENANT

WALGREENS

PHONE #

TOTAL EACH FEE

OUTLETS	85	Receptacles		Switches		Smoke Detector	85	.20	17.00
FIXTURES		Incandescent	210	Fluorescent		Strips	240	.20	48.00
SERVICES		Overhead	/	Underground		TTL AMPS <800	1	15.00	15.00
		Overhead		Underground		>800		25.00	
Temporary Service		Overhead		Underground		TTL AMPS		25.00	
METERS	6	(number of)					6	1.00	6.00
MOTORS		(number of)						2.00	
RESID/COM		Electric units						1.00	
HEATING		oil/gas units		Interior	6	Exterior	6	5.00	30.00
APPLIANCES		Ranges		Cook Tops		Wall Ovens		2.00	
		Insta-Hot		Water heaters		Fans		2.00	
		Dryers		Disposals		Dishwasher		2.00	
	1	Compactors		Spa		Washing Machine	1	2.00	2.00
		Others (denote)						2.00	
MISC. (number of)		Air Cond/win						3.00	
		Air Cond/cent				Pools		10.00	
		HVAC		EMS		Thermostat		5.00	
		Signs						10.00	
		is/res						5.00	
	1	Alarms/com					1	15.00	15.00
		Heavy Duty(CRKT)						2.00	
		Circus/Carnv						25.00	
		Alterations						5.00	
		Fire Repairs						15.00	
	12	E Lights					12	1.00	12.00
		E Generators						20.00	
PANELS		Service	8	Remote		Main	8	4.00	32.00
TRANSFORMER		0-25 Kva						5.00	
		25-200 Kva						8.00	
		Over 200 Kva						10.00	
TOTAL AMOUNT DUE									177.00
MINIMUM FEE/COMMERCIAL 45.00							MINIMUM FEE	35.00	

55.00

41.00

CONTRACTORS NAME

BH milliken

MASTER LIC. #

MC 60016837

ADDRESS

175 ANDERSON ST

LIMITED LIC. #

TELEPHONE

PORTLAND, ME 04101

SIGNATURE OF CONTRACTOR

White Copy - Office

Yellow Copy - Applicant

Permit Number _____

Location _____

Owner _____

Date of Permit _____

Final Inspection

By Inspector _____

Service called in _____

Closing-in _____ by _____

PROGRESS INSPECTIONS: _____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

DATE:

REMARKS:

10/15/2000

Semir - underhand Passed

3/15/2010

Sign needed for compressor Area Around disconnect otherwise.

Electar Final OK

BKL

4/9/2012

This Permit Should've Been Closed - closed!! Inspected!! Btk L