

TYPICAL ADA BATHROOM DETAILS

The image contains two diagrams illustrating typical ADA bathroom details. The left diagram shows a side view of a bathroom with a toilet, sink, and urinal. The right diagram shows a front view of a bathroom with a sink and a vanity unit.

Left Diagram Dimensions:

- Overall width: 3'-6"
- Overall depth: 3'-0"
- Toilet to sink distance: 1'-6"
- Sink to urinal distance: 3'-6" MIN.
- Toilet to urinal distance: 1'-5"
- Urinal to sink distance: 1'-7"
- Overall depth (toilet to sink): 2'-10"
- Overall depth (toilet to urinal): 2'-4" MAX.
- Overall depth (sink to urinal): 2'-10" MAX.

Right Diagram Dimensions:

- Sink to vanity distance: 1'-3" MIN.
- Sink to vanity distance (overall): 2'-3" MIN.
- Sink to vanity distance (overall): 2'-10" MAX.
- Sink to vanity distance (overall): 3'-4" MAX.
- Sink to vanity distance (overall): 3'-2" PREFERRED - CONFIRM SINK CLEARANCE
- Sink to vanity distance (overall): 4" TYP.

NOTES

- WHEN GIVEN A RANGE OF DIMENSIONS FOR PLACEMENT, PLACE ALL FIXTURES OF SAME TYPE AT THE SAME ELEVATION THROUGHOUT, UNLESS OTHERWISE DIRECTED.

1. WHEN GIVEN A RANGE OF DIMENSIONS FOR PLACEMENT, PLACE ALL FIXTURES OF SAME TYPE AT THE SAME ELEVATION THROUGHOUT, UNLESS OTHERWISE DIRECTED.
2. MIRRORS TO BE CENTERED OVER SINKS
3. PROVIDE APPROPRIATE BLOCKING IN WALLS BEHIND ALL FIXTURES, PARTITIONS, AND ACCESSORIES.

A	MIRROR 18" x 36" NOM.
B	SOAP DISPENSER - PBOIBC
C	NOT USED
D	TOILET PAPER DISPENSER
E	GRAB BAR 36" (1 1/4" TO 1 1/2" O.D.)
F	GRAB BAR 42" (1 1/4" TO 1 1/2" O.D.)
G	NOT USED
H	GRAB BAR 18" (1 1/4" TO 1 1/2" O.D.)

UNIT NOTES	
1	G.C. TO CONFIRM AND COORDINATE ALL ROUGH FRAMING DIMENSIONS FOR, BUILT-IN FIXTURES ETC. G.C. TO CONFIRM AND COORDINATE ALL CABINETRY AND APPLIANCES DIMENSIONS
2	PROVIDE APPROPRIATE BLOCKING IN WALLS BEHIND ALL PARTITIONS AND ACCESSORIES. BLOCKING FOR GRAB BARS TO BE PROVIDED IN WALLS OF BATHROOMS
3	PROVIDE MOISTURE RESISTANT GWB AT ALL WALLS AND CEILINGS IN BATHROOMS
4	REFER TO ELECTRICAL AND MECHANICAL DRAWINGS FOR ADDITIONAL INFORMATION REGARDING, LIGHTING, DIFFUSERS, ETC.
5	PROVIDE FIRE EXTINGUISHER ON BRACKET IN BASE CABINET BELOW SINK. (TYPE, ONE SINK PER ROOM)
6	WHERE DROPPED SOFFITS AND CEILINGS ARE SHOWN, THESE ARE IN ADDITION TO THE FIRE RATED GWB CEILING ABOVE WHICH IS PART OF THE RATED ASSEMBLY
7	WHERE PLUMBING VALVES ARE LOCATED IN FIRE RATED WALLS, PROVIDE FIRE RATED BOX IN WALL FOR VALVE TO BE INSTALLED WITHIN

CABINETRY AND APPLIANCE ABBREVIATIONS	
DB	= DRAWER BASE
DRB	= DOOR BASE
SB	= SINK BASE
WC	= WALL CABINET
DW	= DISHWASHER
REF	= REFRIGERATOR

