

Project Specifications

DIVISION 1 - GENERAL REQUIREMENTS

Section 05005 - Administrative Provisions

Contractor shall coordinate and install Owner furnished items as noted on the drawings.

Section 01500 - Construction Facilities and Temporary Controls

The Contractor shall be responsible for providing all materials, labor, supervision, equipment and other items of material or work, whether of a temporary or permanent nature, as required for the proper and expeditious execution of the work.

Connect to the Landlord's existing utilities.

Temporary Utilities: Provide ventilation and sanitary facilities as directed by the Landlord.

Temporary Controls and Dust Control: Provide positive means to prevent airborne dust from dispersing into the atmosphere. Temporary partitions and enclosures shall be dust proof, covered with polyethylene plastic sheet and completely sealed joints with duct tape. One hour fire rated temporary partitions shall be constructed between the construction zone and other occupied areas of the building.

DIVISION 2 - SITEWORK

Not Used

DIVISION 3 – CONCRETE

Section 03540 - Liquid-applied self-leveling floor underlayment. Provide where required to level existing concrete floors to meet flooring manufacturer's requirements.

Cementitious Underlayment: Blended cement mix, that when mixed with water in accordance with manufacturer's directions will produce self-leveling underlayment with the following properties:

- a. Compressive Strength: Minimum 4000 psi (27.6 MPa) after 28 days, tested per ASTM C 109/C 109M.
- b. Flexural Strength: Minimum 1000 psi (6.9 MPa) after 28 days, tested per ASTM C 348.
- c. Density: Maximum 125 lb/cu ft (2002 kg/cu m).
- d. Final Set Time: 1-1/2 to 2 hours, maximum.
- e. Thickness: Feather edge to maximum 3-1/2 inch (89 mm).
- f. Surface Burning Characteristics: Flame spread/Smoke developed index of 0/0 in accordance with ASTM E 84.
- g. Aggregate: Dry, well graded, washed silica aggregate, approximately 1/8 inch (3 mm) in size and acceptable to underlayment manufacturer.
- h. Primer: Manufacturer's recommended type.
- i. Joint and Crack Filler: Latex based filler, as recommended by manufacturer.

Verify that underlayment is compatible with floor covering scheduled for each area.

DIVISION 4 - MASONRY

Section 04200 - Unit Masonry

Existing Walls: Patch and repair existing masonry walls where being exposed for new finish.

DIVISION 5 - STRUCTURAL STEEL

Section 05500 - Metal Fabrications

Steel for metal fabrications - ASTM A-36
Provide overhead support for toilet partitions.

DIVISION 6 - WOOD AND PLASTICS

Section 06100 - Rough Carpentry

Provide concealed wood blocking, nailers, and supports for casework and accessories.
a. Lumber: S4S, No. 2 or Standard Grade.

Section 06200 - Finish Carpentry

Hardwood Lumber: Plain sliced Maple, plain sawn, maximum moisture content of 6 percent; with vertical grain, of quality suitable for transparent finish.

Hardwood Faced Plywood: HPVA HP-1; graded in accordance with AWI/AWMAC Architectural Woodwork Quality Standards Illustrated, core of veneer; type of glue recommended for specific application; thickness as required; face veneer as follows:
a. Exposed Surfaces: Grade AA, Maple, rift cut and comb grain, book-matched.
b. Semi-Exposed Surfaces: Grade A, Maple, rift cut and comb grain, random matched.

Finish work in accordance with AWI Architectural Woodwork Quality Standards Illustrated, Section 1500.

a. Transparent: Nitrocellulose lacquer (formerly TR-1).

Section 06410 - Casework

Plastic Laminate Casework, A.W.I. Quality Standards, Custom Grade with 3mm PVC Edging to match laminate. Refer to Interior Finish Legend for plastic laminate selections.

- a. Horizontal Surfaces: HGS, 0.048 inch (1.22 mm) nominal thickness, through color.
- b. Vertical Surfaces: VGS, 0.028 inch (0.71 mm) nominal thickness, through color.
- c. Counters with sinks to be plastic laminate with D90 edging and backsplash.
- d. Counters without sinks to be plastic laminate with plastic laminate edging and no backsplash.

- e. Solid surface transaction counters at reception desk where indicated.

- f. Hardware: BHMA A156.9, types as recommended by fabricator for quality grade specified.
 - 1. Drawer and Door Pulls: "U" shaped wire pull, steel with brushed chrome finish, 4 inch centers.
 - 2. Cabinet Locks: Keyed cylinder, two keys per lock, master keyed, steel with chrome finish. Provide where indicated on the drawings.
 - 3. Catches: Magnetic.
 - 4. Drawer Slides: Full extension, extra heavy duty grade, side mounted.
 - 5. Hinges: Concealed (fully mortised) self-closing type, steel with polished finish.
 - 6. Cable Grommets: Round plastic grommet with flip up tab to cover cord slot when not in use.
 - 7. Countertop Support Brackets: Work Surface Brackets manufactured by Hafele. Size according to countertop dimensions and support spacing to provide load capacity recommended by manufacturer.

Wall Mounted Standards and Shelving: Load Capacity: 300 to 680 pounds (135 to 310 kg) per pair of standards.

- a. Heavy Duty Shelf Standards: Double-slotted channel standards for brackets adjustable in 1 inch (25 mm) increments along entire length of standard, drilled and countersunk for screws.
- b. Brackets: Double tab type, locking into slots; size to suit shelves; same finish as standards.
- c. Finish: Powder-coated, white; provide screws with matching heads.
- d. Bracket Quantity: Provide one bracket for each 12 inches (305 mm) of standard length.
- e. Laminate Faced Shelves: $\frac{3}{4}$ " thick particleboard or medium density fiberboard covered with high pressure decorative laminate on both sides with rubber T-molding edge finish to match laminate.

DIVISION 7 – THERMAL AND MOISTURE PROTECTION

Section 07210 - Building Insulation and Firestopping

Sound Insulation: Friction fit unfaced glass fiber insulation.

Firestopping, fire safing and smoke seal materials at all fire rated partitions and around penetrations.

Foam Insulation (foam sealant for sealing around windows and other tight voids in exterior wall): On site foam-in-place insulation shall be Dow Froth-Pak 1.75-25FS, Class 1 foam or equal.

Section 07900 - Sealants

Interior (Paintable): Acrylic latex sealant (typical interior use).

- a. ASTM C834 for latex sealing compounds.

- b. Joint movement capability: $\pm 7.5\%$

Sealant for Toilet Rooms: silicone sealant (use around plumbing fixtures, sinks).

- a. ASTM C920, Type S, Grade NS, Class 25, uses NT, G, A, O.
- b. Joint movement capability: $\pm 25\%$

Acoustical sealant – Below interior partitions, and where abutting dissimilar materials.

Backer rod: Polyethylene foam backer rod.

Poly bond breaker tape at rated joints.

DIVISION 8 - DOORS AND WINDOWS

Section 08100 – Hollow Metal Frames

Interior Frames, Fire- Rated and Non-Fire-Rated: Door frames to be knock-down type.

Borrowed light frames to be welded.

- a. Accessibility: Comply with ANSI/ICC A117.1.
- b. Grade: Comply with frame requirements specified in ANSI A250.8 for Level 1, 18 gage.
- c. Fire Rating: As indicated on Door and Frame Schedule, tested in accordance with UL 10C ("positive pressure"). Attach fire rating label to each fire rated unit.
- d. Finish: Factory primed, for field finishing.
- e. Glazed Lights: Non-removable stops on non-secure side; sizes and configurations as indicated on drawings.
- f. Hardware Preparation: In accordance with bhma a156.115, with reinforcement welded in place, in addition to other requirements specified in door grade standard.
- g. Silencers: Resilient rubber, fitted into drilled hole; 3 on strike side of single door and 2 on head of pairs without center mullions.

Section 08210 - Wood Doors

Wood Doors: Thickness: 1-3/4 inches, interior flush wood, bonded, sanded solid core, 5 ply hot pressed construction. Provide manufacturer's warranty for the life of the installation.

- a. Door construction shall conform to WDMA I.S. 1-A 1997 "A" Grade or AWI Custom Grade requirements.
 - 1. Fire Rated Doors: Tested to ratings indicated on drawings in accordance with International Building Code ("positive pressure"); UL or WH (ITS) labeled without any visible seals when door is open.
- b. Stiles: Hardwood to match face veneer over structural composite lumber, glued to core.
- c. Rails: Mill option hardwood or structural core lumber. Top and bottom: 2 inches.
- d. Wood veneer: Plain sliced, White Maple, book matched, with clear finish.
- e. Edges: All door edges shall be maple veneer to match face veneer.
- f. Glazing Stops: Wood, of same species as door facing, butted corners; prepared for countersink style tamper proof screws.

- g. Adhesives: Face to core adhesives shall be Type I, waterproof.
- h. Core: Bonded particle core (PC), type 1-LD-2, conforming to WDMA I.S. 1-A 1997.
- i. Finish: Pre-finished, AWI System TR-6 Catalyzed polyurethane, clear finish.
- j. Factory machine doors for hardware other than surface-mounted hardware, in accordance with hardware requirements and dimensions.
- k. Provide edge clearances in accordance with AWI Quality Standards Illustrated Section 1700.

Section 08710 - Finish Hardware

Door Hardware: General

- a. Provide all hardware specified or required to make doors fully functional, compliant with applicable codes, and secure to the extent indicated.
- b. Provide all items of a single type of the same model by the same manufacturer.
- c. Provide products that comply with all applicable provisions of federal, state, and local codes.
- d. Fire-Rated Doors: NFPA 80.
- e. All Hardware on Fire-Rated Doors: Listed and classified by UL as suitable for the purpose specified and indicated.
- f. Provide sound gasketing on doors (all four edges) as noted on the drawings.

Hinges: Five-knuckle full mortise butt hinges

- a. Provide ball-bearing hinges at all doors having closers.
- b. Provide three hinges per leaf.

Locks and Latches: Standard duty commercial grade, bored lock and latchsets. Basis of Design: Schlage AL Series with Neptune style lever handle.

- a. Locksets and latchsets with 2-3/4" backset shall have cases of uniform size to allow interchangeability.
- b. Mechanically actuated anti-friction latchbolts and deadbolts shall have at least 1/2" throws. For double doors and doors under UL label requirements, latchbolt throws shall be 3/4".
- c. Provide standard ASA strikes with curved lips of lengths to suit door and jamb conditions, with wrought box strikes.
- d. Lock Cylinders: Manufacturer's standard tumbler type, six-pin standard core.

Closers: Surface-mounted, door-mounted closers.

- a. Provide a door closer on every fire- and smoke-rated door.
- b. At corridors, locate door-mounted closer on room side of door.

Bypassing Door Hardware: Track, hanger fasteners, guides, and pulls; size track and hangers according to manufacturer's recommendations for weight of doors.

Hardware Groups:

Group 1 (privacy):

- a. Hinges
- b. Privacy lockset
- c. Closer

- d. Wall bumper
- e. Sound gasketing where noted

Group 2 (passage): Each leaf:

- a. Hinges
- b. Passage latchset
- c. Wall bumper
- d. Manual flush bolts top and bottom

Group 3 (office):

- a. Hinges
- b. Office lockset
- c. Wall bumper
- d. Sound gasketing where noted

Group 4 (storeroom):

- a. Hinges
- b. Storeroom lockset
- c. Wall bumper

Group 5 (pair closet doors): Each leaf:

- a. Hinges
- b. Dummy trim
- c. Roller latch

Group 6 (sliding closet doors):

- a. 1 set sliding closet door hardware – size as appropriate for opening

Group 7 (stair):

- a. Hinges
- b. Passage latchset
- c. Closer

Section 08800 – Glazing

Interior Glazing: 1/4 " tempered safety glass.

DIVISION 9 – FINISHES

Section 09250 – Gypsum Board Assemblies

Provide completed assemblies complying with ASTM C 840 and GA-216.

Fire Rated Assemblies: Provide construction equivalent to that listed for the particular assembly in the current UL Fire Resistance Directory.

Non-Loadbearing Framing System Components: ASTM C 645; galvanized sheet steel, of size and properties necessary to comply with ASTM C 754 for the spacing indicated, with maximum deflection of wall framing of L/240 at 5 psf (240 Pa).

- a. Ceiling Hangers: Type and size as specified in ASTM C 754 for spacing required.
- b. Partition Head To Structure Connections: Provide track fastened to structure with legs of sufficient length to accommodate deflection, for friction fit of studs cut short and screwed to secondary deflection channel set inside but unattached to top track.

Gypsum board: 5/8 inch; ends square cut with tapered and beveled edges.

Fire Rated Gypsum Board: 5/8 inch Type "X", ASTM C36; fire resistive type, UL rated; ends square cut with tapered and beveled edges.

Moisture Resistant Gypsum Board: 5/8 inch moisture resistant and Type "X" moisture resistant in accordance with ASTM C630; ends square cut with tapered and beveled edges.

Fasteners: Steel drill screws (ASTM C1002) or fasteners recommended by gypsum board manufacturer.

Trim Accessories for Interior Installation: corner beads, edge trim, and control joints galvanized steel, rolled zinc, or rigid plastic.

- a. Control Joints: One-piece control joint formed with V-shaped slot, with removable strip covering slot opening.

Joint Materials: ASTM C475; 2" wide coated glass fiber tape, joint compound, adhesive, and water.

Partition Rating Identification: Stencil partition ratings above finish ceilings, at a height approved by the Owner. Stenciled characters shall be 6 inches high, with red paint, every 20 feet maximum. In smaller areas, where the ratings change, identify ratings of the individual walls surrounding the spaces so that all partitions are identified.

Section 09511 - Acoustical Treatment

Acoustical Units - General: ASTM E 1264, Class A. Flame Spread: 25 or less. Smoke Developed: 50 or less.

Acoustical Units: Armstrong School Zone

- a. Size: 24"x24"x3/4" #1821
- b. Edge: Beveled tegular edge.
- c. Fire Resistance Rating: Class "A"
- d. Surface: Fine fissure.

Suspension Systems - General: ASTM C 635; die cut and interlocking components, with stabilizer bars, clips, splices, perimeter moldings, and hold down clips as required.

- a. Grid: Armstrong 9/16" Suprafine Exposed Tee Grid.

Section 09650 - Resilient Flooring

Concrete Floor Testing: Furnish, test and apply systems for the reduction of moisture vapor transmission and alkalinity control for interior concrete slabs requiring the installation of resilient flooring, or carpet. Test results shall be approved by manufacturer's installation requirements for slab preparation.

Vinyl Sheet Flooring: Homogeneous without backing, with color and pattern throughout full thickness. Refer to Interior Finish Legend for material selections.

- a. Surface Burning Characteristics: Flame spread/Smoke developed index of 25/25, maximum, when tested in accordance with ASTM E 84.
- b. Critical Radiant Flux (CRF): Minimum 0.45 watt per square centimeter, when tested in accordance with ASTM E 648 or NFPA 253.

Vinyl Composition Tile Flooring: Homogeneous, with color extending throughout thickness. Refer to Interior Finish Legend for material selections.

- a. Surface Burning Characteristics: Flame spread/Smoke developed index of 25/25, maximum, when tested in accordance with ASTM E 84.
- c. Critical Radiant Flux (CRF): Minimum 0.45 watt per square centimeter, when tested in accordance with ASTM E 648 or NFPA 253.

Rubber Base: 1/8" gauge 4" high coved rubber. Refer to Interior Finish Legend for material selections.

Section 09680 - Carpet

Carpet: Textured pattern loop, nylon. Refer to Interior Finish Legend for material selections.

- a. Surface Burning Characteristics: Flame spread/Smoke developed index of 25/25, maximum, when tested in accordance with ASTM E 84.
- b. Critical Radiant Flux (CRF): Minimum 0.22 watt per square centimeter, when tested in accordance with ASTM E 648 or NFPA 253.

Carpet Mat: Cut nylon pile permanently bonded to rubber backing. Refer to Interior Finish Legend for material selections.

- a. Surface Burning Characteristics: Flame spread/Smoke developed index of 25/25, maximum, when tested in accordance with ASTM E 84.
- b. Critical Radiant Flux (CRF): Minimum 0.22 watt per square centimeter, when tested in accordance with ASTM E 648 or NFPA 253.

Edge Strips: Rubber.

Section 09900 - Painting

Interior Painting: Finish all surfaces exposed to view, unless fully factory-finished and unless otherwise indicated.

Volatile Organic Compound (VOC) Content: Provide coatings that comply with State of Maine Architectural Coatings VOC limits.

Paint: Gypsum Board/Plaster, Latex, 3 Coats. Refer to Interior Finish Legend for material selections.

- a. One coat of latex sealer.
- b. Two coats of latex enamel.

Paint: Ferrous Metals, Primed, Latex, 2 Coats. Refer to Interior Finish Legend for material selections

- a. Touch-up with latex primer.
- b. Two coats of latex enamel.

DIVISION 10 - SPECIALTIES

Section 10210 – Plastic Toilet Compartments

Toilet Compartments: Solid molded plastic panels, doors, and pilasters, ceiling-hung.

- a. Color: Single color per room as selected from manufacturer's standard palette.
- b. Door and Panel Dimensions:
 1. Thickness: 1 inch (25 mm).
 2. Door Width: 24 inch (610 mm). Door Width for Handicapped Use: 36 inch (915 mm), out-swinging.
 3. Height: 58 inch (1 473 mm).
 4. Thickness of Pilasters: 1 inch (25 mm).
- c. Pilaster Brackets: Polished stainless steel.
- d. Wall Brackets: Continuous type, polished stainless steel.
- e. Attachments, Screws, and Bolts: Stainless steel , tamper proof type.
- f. Hardware: Polished stainless steel:
 1. Pivot hinges, gravity type, adjustable for door close positioning; two per door.
 2. Door Latch: Slide type with exterior emergency access feature.
 3. Door strike and keeper with rubber bumper; mounted on pilaster in alignment with door latch.
 4. Coat hook with rubber bumper; one per compartment, mounted on door.
 5. Provide door pull for outswinging doors.

Section 10440 - Fire Protection Specialties

Fire Extinguishers - Comply with product requirements of NFPA 10 and applicable codes. Provide extinguishers labeled by Underwriters Laboratories Inc. Dry chemical type fire extinguishers, Stainless steel tank, with pressure gage.

- a. Class ABC.

- b. Size 10.
- c. Finish: Baked enamel, red color.

Recessed Fire Extinguisher Cabinets

- a. Door: 0.036 inch (0.9 mm) thick, reinforced for flatness and rigidity. Hinge doors for 180 degree opening with continuous piano hinge.
- b. Door Glazing: Plastic, clear, 1/8 inch (3 mm) thick acrylic. Set in resilient channel gasket glazing.
- c. Finish of Cabinet Exterior Trim and Door: Baked enamel, white color.
- d. Finish of Cabinet Interior: White enamel.
- e. Locking mechanism: Cylinder lock, capable to be opened in fire situation with sharp pull on handle.
- f. Lettering: Thermal, die-cut vinyl; black, type A.

Graphic Identification: 14" x 12" 90° angle projecting wall mounted sign with vertical arrows and lettering.

Section 01820 - Toilet Accessories

Grab Bars: Stainless steel with satin finish, peened finish. Wall thickness: 18 gage and outside diameter 1-1/4". Stainless steel flanges: 11 gage 3" diameter with four stainless steel vandal-proof set screws, concealed mounting.

- a. Anchor plate: 12 gage steel, 3" wide, in lengths to accommodate all grab bar configurations.

Soap Dispenser: Liquid soap dispenser, wall-mounted, surface, with stainless steel cover and horizontal stainless steel tank and working parts; push type soap valve, check valve, and window gage refill indicator, tumbler lock. Minimum Capacity: 48 ounces (1.5 liters).

Paper Towel Dispenser: Folded paper type, stainless steel, fully-recessed, with viewing slots on sides as refill indicator and tumbler lock. Capacity: 300 C-fold minimum.

Framed Mirrors: 24 inches by 36", unless noted otherwise on drawings.

- a. Frame: One piece, roll formed 3/4" x 5/8" 18 gage (minimum) stainless steel angles with welded and ground corners, satin finish. Provide concealed wall hanger for theft-proof mounting. Corners: welded, ground and polished smooth.
- b. Mirror: No. 1 quality, 1/4" polished glass, electrolytically copper plated, warranted against silver spoilage for a minimum 15 years. Protect back of mirror with 1/4" polystyrene padding and 20 gage galvanized steel back attached to frame with concealed screws.

Un-framed Mirrors: Size as shown on drawings. No. 1 quality, 1/4" polished glass, electrolytically copper plated, warranted against silver spoilage for a minimum 15 years. Protect back of mirror with 1/4" polystyrene padding and 20 gage galvanized steel back attached to frame with concealed screws.

Recessed Sanitary Napkin Disposal Unit: 18-8 S, type-304, heavy-gauge stainless steel, all-welded construction, satin finish.

- a. Disposal panel: 18-8 S, type-304, 22 gauge stainless steel, satin finish with international graphics symbol for sanitary napkin disposal.
- b. Waste Receptacle: 1.2 gallon capacity, leak-proof, rigid molded polyethylene; removable for servicing.

Single Robe Hook: Sstainless steel, heavy duty clothes hook with concealed mounting. Provide one for toilet room door for single toilet rooms.

Diaper Changing Station: Wall-mounted folding diaper changing station for use in commercial toilet facilities, meeting or exceeding ASTM F 2285.

- a. Style: Horizontal.
- b. Minimum Rated Load: 250 lbs (113.4 kg).
- c. Material: Polyethylene with antimicrobial treatment.

DIVISION 11 - EQUIPMENT

Section 11520 - Projection Screens

Front Projection Screens: Factory assembled, size as shown on drawings.

Matte Light Diffusing Fabric: Light diffusing screen fabric; washable, flame retardant and mildew resistant, without seams.

- a. Material: High contrast acoustically transparent gray vinyl without backing, with nominal gain of 0.8 over viewing angle not less than 70 degrees from axis, horizontally and vertically.
- b. Masking Borders: Black, four sides.
- c. Extra Drops: Black; 11 inches (279 mm).

Concealed-in-Ceiling Screen Cases: Steel; integral roller brackets.

- a. Closure Door: Independently motorized closure door that opens into housing.
- b. Case Finish: White, baked enamel.

Provide mounting hardware, brackets, supports, fasteners, and other mounting accessories required for a complete installation, in accordance with manufacturer's recommendations.

DIVISION 12 - FURNISHINGS

Section 12500 - Window treatment

Install solid blocking at window heads for between jamb mounted window shades.

DIVISION 13 - SPECIAL CONSTRUCTION

Not Used

DIVISION 14 - CONVEYING SYSTEMS

Not Used

Community Counseling Center
165 Lancaster Street
Portland, Maine

Finish Code	Category	CSI #	Manufacturer	Description	Series/Color	Manufacturer's REP	Remarks
ACT	Acoustical Ceiling Tile	09511	Armstrong	2'x2'x3/4" beveled tegular acoustical ceiling tile with good acoustical protection	School Zone, fine fissured, # 1821; color: white		Install with suprafine 9/16" suspension grid system; color: white.
CPT-1	Carpet	09680	Shaw		TBD	Andy Merrill 207-841-2506	use in corridors, private offices, admin.
CPT-2	Carpet	09680	Shaw		TBD	Andy Merrill 207-841-2506	use waiting area, foyer and board room
GWB	Gypsum Wall Board			gypsum wall assemblies			
HR	Handrail	10265		1-1/2" Maple rail , bracket mounted	Wood species: Maple; finish: natural		use in Elderworks
MAT	Walk-off Mat/Misc. Specialties	10010	Mats Inc.	6-7" 73.1 oz. rolled goods, 100% solution dyed UV stabilized polypropylene fibers with high density rubber backing	Supreme Nop; color: TBD	Mike Conway 207-450-3195	use in vestibules and foyer
P-1a	Paint	09990	Benjamin Moore	Eco-Spec low voc, eggshell finish	TBD		general perimeter color
P-1b	Paint	09990	Benjamin Moore	Eco-Spec low voc, semi-gloss finish			Door trim on P-1a walls
P-2a	Paint	09990	Benjamin Moore	Eco-Spec low voc, eggshell finish	TBD		general office color
P-2b	Paint	09990	Benjamin Moore	Eco-Spec low voc, semi-gloss finish			Door trim on P-2a walls
P-3a	Paint	09990	Benjamin Moore	Eco-Spec low voc, eggshell finish	TBD		accent color
P-3b	Paint	09990	Benjamin Moore	Eco-Spec low voc, semi-gloss finish			Door trim on P-3a walls

Finish Code	Category	CSI #	Manufacturer	Description	Series/Color	Manufacturer's REP	Remarks
P-4a	Paint	09990	Benjamin Moore	Eco-Spec low voc, eggshell finish	TBD		accent color
P-4b	Paint	09990	Benjamin Moore	Eco-Spec low voc, semi-gloss finish			Door trim on P-4a walls
P-5a	Paint	09990	Benjamin Moore	Eco-Spec low voc, eggshell finish	TBD		accent color
P-5b	Paint	09990	Benjamin Moore	Eco-Spec low voc, semi-gloss finish			Door trim on P-5a walls
P-6a	Paint	09990	Benjamin Moore	Eco-Spec low voc, eggshell finish	TBD		accent color
P-6b	Paint	09990	Benjamin Moore	Eco-Spec low voc, semi-gloss finish			Door trim on P-6a walls
P-7a	Paint	09990	Benjamin Moore	Eco-Spec low voc, eggshell finish	TBD		Field color in Waiting area
P-7b	Paint	09990	Benjamin Moore	Eco-Spec low voc, semi-gloss finish			Door trim on P-7a walls
P-8a	Paint	09990	Benjamin Moore	Eco-Spec low voc, eggshell finish	TBD		Door trim
P-8b	Paint	09990	Benjamin Moore	Eco-Spec low voc, semi-gloss finish			Door trim on P-8a walls
P-9	Paint	09990	Benjamin Moore	Eco-Spec low voc, flat finish	OC-34, marble white		ceiling paint
Plam-1	Plastic Laminate	06400	Formica	Matte Finish, vertical grade	#7012-58, amber maple		Vertical millwork
Plam-2	Plastic Laminate	06400	Wilsonart	Matte Finish, horizontal grade	#4667-60, green tigris		Horizontal surfaces
Plam-3	Plastic Laminate	06400	Formica	Matte Finish, vertical grade	#7288-58, ginger root maple		Accent vertical millwork @ reception desk

Community Counseling Center
165 Lancaster Street
Portland, Maine

Finish Code	Category	CSI #	Manufacturer	Description	Series/Color	Manufacturer's REP	Remarks
Plam-4	Plastic Laminate	06400	Wilsonart	Matte Finish, horizontal grade	#4862-90, sandy topaz		Horizontal surfaces @ 29" A.F.F. and 36" A.F.F. at reception desk
Plam-5	Plastic Laminate	06400	Formica	Metal Laminate	DecoMetal # 2022, brushed aluminum		Reception Desk Base @ Foyer
RB-1	Rubber Base	09651	Johnsonite	4" Rubber Base	Color:TBD	Roxane Spezzaferri 781-258-2837	general base
RB-2	Rubber Base	09651	Johnsonite	4" Rubber Base	Color:129, silk	Roxane Spezzaferri 781-258-2837	use in any rooms with VCT or SV-2
SS	Solid Surface		LG	quartz solid surfacing	Viatera;Color: Solana	Cynthia Maclachlan 781-789-2532	Horizontal surfaces @ 42" A.F.F. at reception desk
SV-1	Sheet Vinyl	09650	Johnsonite	2mm, 6'-6" wide safety sheet flooring	Granit Safe-T-Sheet; Color:692, acorn	Roxane Spezzaferri 781-258-2837	for use in all toilet rooms/ integral base, Use in G107 with RB-2
SV-2	Sheet Vinyl	09650	Mats Inc.	2mm heterogeneous sheet floor covering with glass fiber reinforcement	Debolon Compact; color 260 301, Alder	Mike Conway 207-450-3195	
VCT-1	Vinyl Composition Tile	09651	Mannington	12" x12" vinyl composition tile	TBD		field tile
VCT-2	Vinyl Composition Tile	09651	Mannington	12" x12" vinyl composition tile	TBD		accent tile in A108,A109,C100
VCT-3	Vinyl Composition Tile	09651	Mannington	12" x12" vinyl composition tile	TBD		accent tile in A108,A109,C100