

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that

BAYSIDE IV LLC

Located at

31 CEDAR ST (203 Oxford St)

PERMIT ID: 2017-01905

ISSUE DATE: 02/23/2018

CBL: 026 B012001

has permission to **Placing 2 modified shipping containers on the property, the bathroom is completed per the TPI policy and the locker room will have electrical installed on site, ADA bituminous ramp entrys**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Setbacks and Footings Prior to Pouring
Foundation/Rebar
Electrical - Commercial
Plumbing Only
Certificate of Occupancy/Final Inspection
Final - Electric
Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-01905	Date Applied For: 12/05/2017	CBL: 026 B012001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Two accessory buildings (public restrooms & patron locker rooms) associated with Oxford St shelter		Proposed Project Description: Placing 2 modified shipping containers on the property, the bathroom is completed per the TPI policy and the locker room will have electrical installed on site, ADA bituminous ramp entries		
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Ann Machado	Approval Date: 12/12/2017	Ok to Issue: <input checked="" type="checkbox"/>
Note: R-6 Zone Oxford St is front yard Front 5' min - approx . 43' - OK Rear - 10' min - 11' given -OK side 5' min (on right) 6' given- - Ok Side yard on side st - no setback -OK lot coverage - 60% of 3748 sf = 2248.8 sf - containers are 640 sf + 108 sf (gazebo) = 748 sf - OK				
Conditions: 1) This permit is being issued with the condition that these are temporary structures and will be removed when they are no longer needed to serve the shelter.				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Jeanie Bourke	Approval Date: 02/22/2018	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions: 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 2) This permit is approved per the requirements of the PID Shipping Container Policy and the MUBEC Third Party Inspection process. All TPI inspection reports and documentation shall be submitted to this office (PID) for review prior to locating the structures at the project site. 3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Jason Grant	Approval Date: 01/12/2018	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions: 1) All construction shall comply with City Code, Chapter 10. All construction shall comply with 2009 NFPA 101 Life Safety Code All construction shall comply with 2009 NFPA 1, Fire Code. This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4). All means of egress to remain accessible at all times. If applicable, all outstanding code violations shall be corrected prior to final inspection.				
Dept: DRC	Status: Not Applicable	Reviewer:	Approval Date: 12/12/2017	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				