The width does not allow for a 5' ADA turning radius

LOCKERS BY OTHERS
5'-0" TURNING CIRCLE REQUIRED

12" PUSH CLEARANCE WILL BE MAINTAINED

Provide ADA manuevering requirements at interior of door

NOTE:
SEE SHEET A1 FOR GENERAL NOTES, SCHEDULES, AND SECTIONS & DETAILS

LOCKER CONTAINER PLAN (3/A3)
SCALE: 1/2 = 1'-0"

PIER LAYOUT PLAN (4/A3)
SCALE: 1/2 = 1'-0"

SLOPED BITUMINOUS RAMP

FLOOR IS 4" +/- ABOVE EXISTING GRADE

Please provide a plan view and elevation of the ramp & landing with all required ADA elements including manuevering clearances, dimensions, railings, edge protection, slope etc.

LEGEND

102	DOOR NUMBER
1	WALL TYPES SEE WALL TYPE DETAILS
101	ROOM NUMBER
C	WINDOW TYPE

KEY PLAN

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 02/22/18

NO.	DATE	DESCRIPTION	DRWN	APPD.

REVISIONS

PROJECT NAME: OXFORD ST. SHELTER
BATHROOM & LOCKER CONTAINER
PORTLAND MAINE

SHEET NAME: LOCKER FLOOR PLAN

PROJECT NO. 17289
DRAWING NO. 17289A
FIELDBOOK:
SCALE:
DATE ISSUED: JAN. 09, 2018

SCORED: KGE
DRWN: DPW
CHECKED: KGE
APPROVED: KGE
PLOT DATE: JAN. 09, 2018

CLIENT & PROPERTY OWNER:
SNAPSPACE SOLUTIONS
58 BAKER BLVD
BRUNSWICK, MAINE 04412

Plymouth Engineering, Inc.
P.O. Box 48 30 Lower Detroit Road
Plymouth, Maine 04969
Tel: (207) 257-2071 Fax: (207) 257-2530
info@plymouthengineering.com
www.plymouthengineering.com

STATE OF MAINE
KEITH EWING
No. 12315
LICENSED
PROFESSIONAL ENGINEER

DRAWINGS NOT SEALED ARE FOR PLANNING PURPOSES ONLY AND ARE NOT INTENDED FOR PERMITTING, BIDDING OR CONSTRUCTION

SHEET 3 OF 3

A3

Jan 10, 2018 - 9:02am
J:\2017\17289 - portland homeless bath - portland - snapspace\J. Drawings\BUILDING\17289A_2532.DWG