Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal

To: John Ryan **From:** Mike Nugent

Fax: 773-5173 **Date:** April 25, 2002

Phone: 773-3625 **Pages:** 1

Re: Boys & Girls Club **CC:**

☐ **Urgent** ☐ **For Review** ☐ **Please Comment** ☑ **Please Reply** ☐ **Please Recycle**

Notes: While reviewing the plans for the above project I need a couple of items:

1) The structurals are not stamped by the engineer.

2) The Swimming pool design seems to exceed the allowable wall slope found in Section 421 of the BOCA Code. The plans do not reflect complete cross sectional views .