

Pearl Place II
184 Pearl Street

STATE OF MAINE
STEPHEN P. BENTON
No. 3507
PLUMBING
LICENSED PROFESSIONAL ENGINEER

JOB NO.
10-060

DRWN. CHK.
SP Doel SP Doel

SCALE:
1/8" = 1'-0"

ISSUE:
August 3, 2011
For Bid

TITLE
PLUMBING
FIRST FLOOR
PLAN

SHEET
M2.2



- Note:
1. Provide drain pans under washing machines, pipe to drain.
 2. Downlead water piping shown, uplead to floor above is similar.
 3. Branch water piping to each unit shall be 1/2" unless otherwise noted.
 4. Provide 1/2" hot water connections for dishwashers at each unit with ball shut-off valves and water former arrestors. Provide an indirect waste fitting for the dish bridge hose. See the Architectural drawings for details.
 5. Provide drain pans under washing machines.
 6. Water former arrestors shall be size 1/2" unless otherwise noted and located above accessible ceiling areas.

