

SECTION 096816 - SHEET CARPETING

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

1.2 SUMMARY

- A. This Section includes the following:
  - 1. Tufted carpet.
- B. Related Sections include the following:
  - 1. Division 09 Section "Resilient Base and Accessories" for resilient wall base and accessories installed with carpet.

1.3 SUBMITTALS

- A. Product Data: For the following, including installation recommendations for each type of substrate:
  - 1. Carpet: For each type indicated. Include manufacturer's written data on physical characteristics, durability, and fade resistance.
- B. LEED Submittals: Follow submittal requirements of Division 01 Section "Submittal Requirements" and provide product data on the LEED Materials Documentation Cover Sheet attached as an Appendix to Division 01 Section "Sustainable Design and LEED Requirements."
- C. Samples: For each of the following products and for each color and texture required. Label each Sample with manufacturer's name, material description, color, pattern, and designation indicated on Drawings and in schedules.
  - 1. Carpet: 12-inch- square Sample.
  - 2. Exposed Edge, Transition, and other Accessory Stripping: 12-inch- long Samples.
  - 3. Carpet Seam: 6-inch Sample.
- D. Product Schedule: For carpet Use same designations indicated on Drawings.
- E. Product Test Reports: Based on evaluation of comprehensive tests performed by a qualified testing agency.
- F. Maintenance Data: For carpet to include in maintenance manuals. Include the following:

## PEARL PLACE 2

1. Methods for maintaining carpet, including cleaning and stain-removal products and procedures and manufacturer's recommended maintenance schedule.
2. Precautions for cleaning materials and methods that could be detrimental to carpet.

G. Warranties: Special warranties specified in this Section.

### 1.4 QUALITY ASSURANCE

- A. Installer Qualifications: An experienced installer who is certified by the Floor Covering Installation Board or who can demonstrate compliance with its certification program requirements.
- B. Fire-Test-Response Characteristics: Provide products with the critical radiant flux classification indicated in Part 2, as determined by testing identical products per ASTM E 648 by an independent testing and inspecting agency acceptable to authorities having jurisdiction.
- C. Mockups: Before installing carpet, build mockups to verify seam construction and to demonstrate aesthetic effects and set quality standards for materials and execution.
  1. Approved mockups may become part of the completed Work if undisturbed at time of Substantial Completion.

### 1.5 DELIVERY, STORAGE, AND HANDLING

- A. Comply with CRI 104, Section 5, "Storage and Handling."

### 1.6 PROJECT CONDITIONS

- A. Comply with CRI 104, Section 7.2, "Site Conditions; Temperature and Humidity" and Section 7.12, "Ventilation."
- B. Environmental Limitations: Do not install carpet until wet work in spaces is complete and dry, and ambient temperature and humidity conditions are maintained at the levels indicated for Project when occupied for its intended use.
- C. Do not install carpet over concrete slabs until slabs have cured, are sufficiently dry to bond with adhesive, and have pH range recommended by carpet manufacturer.
- D. Where demountable partitions or other items are indicated for installation on top of carpet, install carpet before installing these items.

### 1.7 WARRANTY

- A. Special Warranty for Carpet: Manufacturer's standard form in which manufacturer agrees to repair or replace components of carpet installation that fail in materials or workmanship within specified warranty period.

## PEARL PLACE 2

1. Warranty does not include deterioration or failure of carpet due to unusual traffic, failure of substrate, vandalism, or abuse.
2. Failures include, but are not limited to, more than 10 percent loss of face fiber, edge raveling, snags, runs, loss of tuft bind strength, excess static discharge, and delamination.
3. Warranty Period: 10 years from date of Substantial Completion.

### 1.8 EXTRA MATERIALS

- A. Furnish extra materials described below, before installation begins, that match products installed and that are packaged with protective covering for storage and identified with labels describing contents.
  1. Carpet: Full-width rolls equal to 5 percent of amount installed for each type indicated, but not less than 10 sq. yd..

## PART 2 - PRODUCTS

### 2.1 MATERIALS, GENERAL

- A. Meet requirements of LEED for Homes Mid-Rise 2010 Credit MR 2.2 as defined in Division 01 Section "Sustainable Design and LEED Requirements" for this type of material.

### 2.2 CARPET (CPT-1)

- A. Products: Subject to compliance with requirements, provide one of the following:
  1. Shaw, Prosper Classicbac 60730; color Climb #2635.
- B. Fiber Content: Eco Solution Q® Nylon.
- C. Pile Characteristic: Multi-level pattern-loop pile.
- D. Pile Thickness: 0.195 inches for finished carpet.
- E. Stitches: 11 per inch.
- F. Face Weight: 28 oz./sq. yd..
- G. Primary Backing: Manufacturer's standard synthetic material.
- H. Backing System: Classicbac.
- I. Width: 12 feet.
- J. Applied Soil-Resistance Treatment: Manufacturer's standard material.
- K. Antimicrobial Treatment: Manufacturer's standard material.

## PEARL PLACE 2

### L. Performance Characteristics: As follows:

1. Flooring Radiant Panel: ASTM E648 Direct Glue Down Mode – Class 1
2. NBS Smoke Chamber: ASTM E662 Flaming Mode – 450 or less
3. Electrostatic Propensity: Less than 3.5 kV per AATCC 134.
4. Environmental Requirements: Provide carpet that complies with testing and product requirements of Carpet and Rug Institute's "Green Label Plus" program.

## 2.3 CARPET (CPT-2)

### A. Products: Subject to compliance with requirements, provide one of the following:

1. Shaw, Prosper 60726; color Climb #2635.

### B. Fiber Content: Eco Solution Q® Nylon.

### C. Pile Characteristic: Multi-level pattern-loop pile.

### D. Pile Thickness: 0.195 inches for finished carpet.

### E. Stitches: 11 per inch.

### F. Face Weight: 28 oz./sq. yd..

### G. Primary Backing: Manufacturer's standard synthetic material.

### H. Backing System: EcoWorx® Performance Broadloom.

### I. Width: 12 feet.

### J. Applied Soil-Resistance Treatment: Manufacturer's standard material.

### K. Antimicrobial Treatment: Manufacturer's standard material.

### L. Performance Characteristics: As follows:

1. Flooring Radiant Panel: ASTM E648 Direct Glue Down Mode – Class 1
2. NBS Smoke Chamber: ASTM E662 Flaming Mode – 450 or less
3. Electrostatic Propensity: Less than 3.5 kV per AATCC 134.
4. Environmental Requirements: Provide carpet that complies with testing and product requirements of Carpet and Rug Institute's "Green Label Plus" program.

## 2.4 CARPET CUSHION

### A. Fiber Cushion: 100% synthetic fiber construction.

1. Density: 6.8.
2. Gauge: 11/32 inch.

### B. Product: Syntex 28 by Leggett & Platt.

- C. Provide in all Type B units.

## 2.5 INSTALLATION ACCESSORIES

- A. Trowelable Leveling and Patching Compounds: Latex-modified, hydraulic-cement-based formulation provided or recommended by carpet manufacturer.
- B. Adhesives: Water-resistant, mildew-resistant, nonstaining type to suit products and subfloor conditions indicated, that complies with flammability requirements for installed carpet and is recommended or provided by carpet manufacturer.
  - 1. VOC Limits: Provide adhesives with VOC content not more than 50g/L when calculated according to 40 CFR 59, Subpart D (EPA method 24).
- C. Seam Adhesive: Hot-melt adhesive tape or similar product recommended by carpet manufacturer for sealing and taping seams and butting cut edges at backing to form secure seams and to prevent pile loss at seams.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- A. Examine substrates, areas, and conditions, with Installer present, for compliance with requirements for maximum moisture content, alkalinity range, installation tolerances, and other conditions affecting carpet performance. Examine carpet for type, color, pattern, and potential defects.
- B. Concrete Subfloors: Verify that concrete slabs comply with ASTM F 710 and the following:
  - 1. Slab substrates are dry and free of curing compounds, sealers, hardeners, and other materials that may interfere with adhesive bond. Determine adhesion and dryness characteristics by performing bond and moisture tests recommended by carpet manufacturer.
  - 2. Subfloor finishes comply with requirements specified in Division 03 Section "Cast-in-Place Concrete" for slabs receiving carpet.
  - 3. Subfloors are free of cracks, ridges, depressions, scale, and foreign deposits.
- C. For wood subfloors, verify the following:
  - 1. Underlayment over subfloor complies with requirements specified in Division 06 Section "Sheathing."
  - 2. Underlayment surface is free of irregularities and substances that may interfere with adhesive bond or show through surface.
- D. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 PREPARATION

- A. General: Comply with CRI 104, Section 7.3, "Site Conditions; Floor Preparation," and with carpet manufacturer's written installation instructions for preparing substrates.
- B. Use trowelable leveling and patching compounds, according to manufacturer's written instructions, to fill cracks, holes, depressions, and protrusions in substrates. Fill or level cracks, holes and depressions 1/8 inch wide or wider, and protrusions more than 1/32 inch, unless more stringent requirements are required by manufacturer's written instructions.
- C. Remove coatings, including curing compounds, and other substances that are incompatible with adhesives and that contain soap, wax, oil, or silicone, without using solvents. Use mechanical methods recommended in writing by carpet manufacturer.
- D. Broom and vacuum clean substrates to be covered immediately before installing carpet.

3.3 INSTALLATION

- A. Comply with CRI 104 and carpet manufacturer's written installation instructions for the following:
  - 1. Direct-Glue-Down Installation: Comply with CRI 104, Section 9, "Direct Glue-Down Installation." Provide in all Type A units.
  - 2. Stretch-in Installation: Comply with CRI 104, Section 12, "Stretch-in Installation." Provide in all Type B units.
- B. Comply with carpet manufacturer's written recommendations and Shop Drawings for seam locations and direction of carpet; maintain uniformity of carpet direction and lay of pile. At doorways, center seams under the door in closed position.
  - 1. Level adjoining border edges.
- C. Do not bridge building expansion joints with carpet.
- D. Cut and fit carpet to butt tightly to vertical surfaces, permanent fixtures, and built-in furniture including cabinets, pipes, outlets, edgings, thresholds, and nosings. Bind or seal cut edges as recommended by carpet manufacturer.
- E. Extend carpet into toe spaces, door reveals, closets, open-bottomed obstructions, removable flanges, alcoves, and similar openings.
- F. Maintain reference markers, holes, and openings that are in place or marked for future cutting by repeating on finish flooring as marked on subfloor. Use nonpermanent, nonstaining marking device.
- G. Install pattern parallel to walls and borders to comply with CRI 104, Section 15, "Patterned Carpet Installations" and with carpet manufacturer's written recommendations.

3.4 CLEANING AND PROTECTING

- A. Perform the following operations immediately after installing carpet:
  - 1. Remove excess adhesive, seam sealer, and other surface blemishes using cleaner recommended by carpet manufacturer.
  - 2. Remove yarns that protrude from carpet surface.
  - 3. Vacuum carpet using commercial machine with face-beater element.
- B. Protect installed carpet to comply with CRI 104, Section 16, "Protection of Indoor Installations."
- C. Protect carpet against damage from construction operations and placement of equipment and fixtures during the remainder of construction period. Use protection methods indicated or recommended in writing by carpet manufacturer and carpet adhesive manufacturer.

END OF SECTION 096816