


NOTE:  
 ① APARTMENT SINGLE STATION DETECTORS WIRE TO LOCAL 120 VAC. WIRE SINGLE STATION (SS) SMOKE DETECTORS TOGETHER IN TANDEM WITHIN EACH APARTMENT.  
 ② APARTMENT SINGLE STATION CO DETECTORS WIRE TO LOCAL 120VAC SOURCE. WIRE SINGLE STATION (SS) CO DETECTORS TOGETHER IN TANDEM WITHIN EACH APARTMENT.

THIRD FLOOR PLAN



<p><b>SimplexGrinnell</b> BE SAFE.                  A Tyco International Company</p> <p>20 THOMAS DRIVE                  WESTBROOK, ME 04092                  SALES: 207-842-6440                  SERVICE: 207-842-6440                  FAX: 207-842-6439</p>		
NO.	DATE	REVISION DESCRIPTION
FIRE ALARM & APARTMENT INTERCOM SYSTEM THIRD FLOOR PLAN PEARL PLACE II 184 PEARL STREET PORTLAND, MAINE		
DRAWN BY:	DATE:	
J. STEPHENS	1/13/11	
CHECKED BY:	DATE:	
KALAFARSKI	1/24/12	
PROJECT NUMBER:	147419994	
SHEET TITLE:	FIRE ALARM/INTER SYSTEM THIRD FLOOR PLAN	
SHEET NUMBER:	FA-104	
	FA-104.dwg	