
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager Downtown Properties Llc		Inspector Suzanne Hunt	Inspection Date 3/26/2010
Location 263 CUMBERLAND AVE	CBL 026 F008001	Status Re-Inspect 10 Days	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-109.(f)	Interior			Bathrooms	
Violation: Maintenance of service to utilities.					
Notes: all supplied equipment must be maintained in good working order. Fan must work.					
Comments: bathrrom in basment fan ok, fan on floor one is not adequate. Smg					