



Katharine Cahoon <kcahoon@portlandmaine.gov>

Notice of Violation and Order to Correct - 41 Chestnut Street - CBL 026 F013001

2 messages

Ian Jones <ian.alex.jones@gmail.com>
To: fireprevention@portlandmaine.gov
Cc: Ian Jones <ian.alex.jones@gmail.com>

Mon, Nov 14, 2016 at 4:36 PM

Location - 41 Chestnut Street
CBL - 026 F013001
Inspection Date - 10/5/2016
Inspector - Christopher Corey
Inspection Type - FP Routine Inspection
Status - Failed

1. NFPA 101 - 7.2.4.3.1 Fire Barrier Requires Maintenance

Proposed Date of Completion - Completed

2. NFPA 101 - 7.9.3 Emergency Lights Require Maintenance

Proposed Date of Completion - 11/21/2016

3. Portland Fire Department Chapter 10 Fire Alarm System Requires Service

Proposed Date of Completion - Completed

4. NFPA 101 - 31.3.4.5.1 Smoke Alarms Required

Proposed Date of Completion - Completed

5. NFPA 101 - 8.3.4.2 60 Minute Fire Door Required

Proposed Date of Completion - 11/25/2016

Please let me know as soon as possible if these dates of completion are satisfactory or not and I will work diligently to meet your requirements.

Ian Alexander Jones
V3 Partners, LLC | Principal
M: 908.432.9267 | E: ian.alex.jones@gmail.com

 **41 Chestnut.pdf**
737K

Katharine Cahoon <kcahoon@portlandmaine.gov>
To: Ian Jones <ian.alex.jones@gmail.com>

Tue, Nov 15, 2016 at 11:06 AM

Thank you for the proposed plan of action. We will be in touch for a followup re-inspection as we approach the completion date.

Katharine Cahoon
Administrative Assistant
Portland Fire Department
380 Congress Street
Portland, ME 04101

(P) [\(207\) 874-8400](tel:2078748400)

(F) [\(207\) 874-8410](tel:2078748410)

[Quoted text hidden]

[Quoted text hidden]

Ian Alexander Jones
V3 Partners, LLC | Principal
M: [908.432.9267](tel:9084329267) | E: ian.alex.jones@gmail.com

--
Katharine Cahoon
Administrative Assistant
Portland Fire Department
380 Congress Street
Portland, ME 04101

(P) [\(207\) 874-8400](tel:2078748400)

(F) [\(207\) 874-8410](tel:2078748410)