# 4R-3421		NAM	E: 223 Cumberland Ave. LLC	DATE: 11/28/2016
ZONE#	PASS	FAIL	LOCATION/DESCRIPTION	
1	X		Basement Smoke	
2	Х		223 Cumberland 2nd Floor Smoke	
3	Х		223 Cumberland 3rd Floor Smoke	
4	Х		223 Cumberland 4th Floor Smoke	
5	Х		Basement Pull Station	
6	Х		225 Cumberland Office Front Pull Station	
7	Х		225 Cumberland Office Rear Pull Station	
8	Х		221 Cumberland Coffee Front Pull Station	
9	Х		221 Cumberland Coffee Rear Pull Station	
10	Х		223 Cumberland 1st Floor Pull Station	
11	Х		223 Cumberland 2nd Floor Pull Station	
12	Х		223 Cumberland 3rd Floor Pull Station	
13	Х		223 Cumberland 4th Floor Pull Station	
18	Х		Sprinkler Waterflow	
19	Х		Sprinkler Tamper Left	
20	X		Sprinkler Tamper Right	
21	X		AES Troubl	е
	<u> </u>			