

56, Nilmot Street
FRONT

06-0-6

REQUEST FOR SERVICE

PORTLAND HEALTH DEPARTMENT

DATE RECEIVED	1-22-82	BY	Joyel	DISTRICT	Easton
REQUEST BY	NAME	Peggy Walsh -		773-2086-Marie	
	ADDRESS	56 Wilmot St.		Hastings	
OWNER	NAME	Peter Wolkovich			
	ADDRESS				
CONDITIONS	ADDRESS	56 Wilmot St. - 1 ST Fl. Rev - 26-0-6			
Insufficient heat					
COMMENTS	Tenant says has notified owner. 1/25/82 - OK - talked with Franie Hastings				
SPECIAL INSTRUCTIONS					
DIVISION	SANITATION		HOUSING		NURSING
PRIORITY	ROUTINE		SPECIAL		BY
	URGENT		REPORT TO		DATE

REQUEST FOR SERVICE

PORTLAND HEALTH DEPARTMENT

DATE RECEIVED	8-4-82	BY	Joyce	DISTRICT	City
REQUEST BY	NAME	Dorothy Lerley - 772-8583-Homr			
	ADDRESS	138 Oxford St., City (773-7118-Bus.)			
OWNER	NAME	New Owners (855)			
	ADDRESS				
CONDITIONS	ADDRESS	56 Wilmot St. (Front)			

Building leaning towards Christian assembly church after jacking requested by City. (Back Section)
Complainant owns church.

COMMENTS CNT - contractor to be connecting - GB

SPECIAL INSTRUCTIONS

DIVISION	SANITATION	HOUSING	NURSING
PRIORITY	ROUTINE	SPECIAL	BY
	URGENT	REPORT TO	DATE

CERTIFICATE
O I
COMPLIANCE

CITY OF PORTLAND

November 21, 1980

Department of Urban Development
Housing Inspections Division
Telephone: 775-5451 - Extension 311 - 312

Mr. Jacob E. Lamport, Devs.
c/o Rhoda Nathanson
35 Coyle Street
Portland, Maine 04103

Re: Premises located at 56 Wilmot (Front) NCP-FE 26-1-6

Dear Mrs. Nathanson:

A re-inspection of the premises noted above was made on November 20, 1980
by Housing Inspector Arthur Addato.

This is to certify that you have complied with our request to correct the
violation of the Municipal Codes relating to housing conditions as
described in our "Notice of Housing Conditions" dated September 11, 1979.

Thank you for your cooperation and your efforts to help us maintain
decent, safe and sanitary housing for all Portland residents.

In order to aid in the preservation of Portland's existing
housing inventory, it shall be the policy of this department
to inspect each residential building at least once every
five years. Although a property is subject to re-inspection
at any time during the said five-year period, the next
regular inspection of this property is scheduled for
November 1985.

Sincerely yours,

Joseph E. Gray, Jr., Director
Urban Development

Lyle D. Noyes

By _____
Lyle D. Noyes
Housing Code Administrator

Inspector *Arthur Addato*
Arthur Addato

jmr

ADMINISTRATIVE HEARING DECISION

OK
BY *[Signature]*
DATE 11-20-80

City of Portland
Department of Neighborhood Conservation
Housing Inspections Division
Telephone: 775-5451 - Ext. 448-- 358

773 6584

Date December 20, 1979

Jacob E. Nathanson C/O Rhoda Nathanson
35 Coyle Street
Portland, Maine 04103

Re: Premises located at 56 Wilmet (Front) MCP-EE 26-3-6

Dear Mr. Nathanson:

You are hereby notified that a reinspection and your request for additional time

on 12/17/79 regarding our "Notice of Housing Conditions" at the above referred premises resulted in the decision noted below

X Expiration time extended to 2/17/79 in order to complete the work in progress to correct the remaining eight (8) Housing Code Violations as shown on attached list.

Notice modified as follows

Please notify this office if all violations are corrected before the above mentioned dates, so that a "Certificate of Compliance" may be issued.

In Attendance:

Jacob E. Nathanson

C/O Rhoda Nathanson

Aldate, Inspector

dls

Very truly yours,
Joseph E. Gray, Jr., Director
Neighborhood Conservation

By Lyle D. Noyes
Lyle D. Noyes,
Chief of Housing Inspections

ADMINISTRATIVE HEARING DECISION

OK
BY [Signature]
DATE 11-20-80

City of Portland
Department of Neighborhood Conservation
Housing Inspections Division
Telephone: 775-5451 - Ext. 448-- 358

773 6589

Date December 20, 1979

Jacob E. Nathanson C/O Rhoda Nathanson
35 Coyle Street
Portland, Maine 04103

Re: Premises located at 56 Wilnot (Front) MCP-EE 26-Q-6

Dear Mr. Nathanson:

You are hereby notified that a reinspection and your request for additional time

on 12/17/79, regarding our "Notice of Housing Conditions" at the above referred premises resulted in the decision noted below.

1 Expiration time extended to 2/17/79 in order to complete the work in progress to correct the remaining eight (8) Housing Code Violations as shown on attached list.

Notice modified as follows _____

Please notify this office if all violations are corrected before the above mentioned dates, so that a "Certificate of Compliance" may be issued.

In Attendance:

Jacob E. Nathanson

C/O Rhoda Nathanson

addat, Inspector

[Signature]

Very truly yours,
Joseph E. Gray, Jr., Director
Neighborhood Conservation

By [Signature]
Lyle D. Noyes,
Chief of Housing Inspections

dld

56 Wilmot Street Front, Portland, Maine
Remaining Housing Code Violations to be corrected within time extension granted on attached
"Administrative Hearing Decision":

- 6/4 2 ✓ ~~RIGHT EXTERIOR FOUNDATION - replace missing mortar. 3c~~
11/20 2 ✓ ~~EXTERIOR CHIMNEY - replace missing mortar. 3c~~
4/29 2 ✓ ~~REAR WALL - determine the reason and remedy the condition which cause the
wall to tilt. 3a~~
- FIRST FLOOR
6/9 4 ✓ ~~REAR HALL FLOOR - determine the reason and remedy the condition which causes
the hall floor to sag. 3b~~
- SECOND FLOOR
4/29 5 ✓ ~~KITCHEN WALL - determine the reason and remedy the condition which causes the
kitchen wall to sag. 9b~~
4/29 5 ✓ ~~KITCHEN FLOOR - determine the reason and remedy the condition which causes the
kitchen floor to sag. 3b~~
4/21 1 ✓ ~~REAR BEDROOM FLOOR - determine the reason and remedy the condition which causes
the bedroom floor to sag. 3b~~
11/29 8 ✓ ~~BATHROOM LAVATORY - replace broken lavatory. 6d~~

NOTICE OF HOUSING CONDITIONS

DU 2

CITY OF PORTLAND
Department of Neighborhood Conservation
Housing Inspections Division
Tel. 775-5451- Ext. 358 - 448

Ch.-Bl.-Lot: 26-0-6
Location: 56 Front Wilnot Street
Project: MC⁷ Coyle West
Issued: 9/11/79
Expired: 12/11/79

Jacob E. Lamport, DEVS.
C/O Rhoda Mathanson
25 Coyle Street
Portland, Maine 04103

Dear Mr. Lamport:

An examination was made of the premises at 56 Front Wilnot Street Portland, Maine by Housing Inspector Addate. Violations of Municipal Codes relating to housing conditions were found as described in detail below.

In accordance with provisions of the above mentioned Codes, you are requested to correct these defects on or before 12/11/79. You may contact this office to arrange a satisfactory repair schedule if you are unable to make such repairs within the specified time. We will assume the repairs to be in progress if we do not hear from you within ten days from this date and, on reinspection within the time set forth above, will anticipate that the premises have been brought into compliance with Code Standards. Please contact this office if you have any questions regarding this Notice.

Your cooperation will help this Department in its goal to maintain all Portland residents in decent, safe and sanitary housing.

Very truly yours,

Joseph E. Jr. Director
Neighborhood Conservation

Inspector *Addate*
A. Addate

By *Lyle D. Noyes*
Lyle D. Noyes
Chief of Housing Inspections

EXISTING VIOLATIONS OF CHAPTER 307 - "MINIMUM STANDARDS FOR HOUSING" -		Section(s)
1.	RIGHT EXTERIOR FOUNDATION - replace missing mortar.	3a
2.	EXTERIOR CHIMNEY - replace missing mortar.	3a
*3.	REAR WALL - determine the reason and remedy the condition which causes the wall to tilt.	3a
4.	FIRST FLOOR	
12/17 4.	LIVINGROOM WINDOW, FRONT BEDROOM & KITCHEN WINDOWS - replace missing counter balance cords.	3c
12/17 5.	BATHROOM & KITCHEN CEILINGS - repair sagging plaster.	3b
4 3b.	REAR HALL FLOOR - determine the reason and remedy the condition which causes the hall floor to sag.	3b
12/17 3.	BATHROOM CEILING - remove peeling paint.	3b
	SECOND FLOOR	
12/17 8.	KITCHEN CEILING - repair sagging plaster.	3b
5 9.	KITCHEN WALL - determine the reason and remedy the condition which causes the kitchen wall to sag.	3b
6 10.	KITCHEN FLOOR - determine the reason and remedy the condition which causes the kitchen floor to sag.	3b
11.	KITCHEN WINDOW - replace broken glass.	3c

continued next page

36 Front Hill Street, Portland, Maine - Continued

- SECOND FLOOR continued
- | | | | |
|-------|-----|---|----|
| 12/17 | 12. | REAR BEDROOM WINDOW - replace broken glass. | 3c |
| 7 | 15. | REAR BEDROOM FLOOR - determine the reason and remedy the condition which causes the bedroom floor to sag. | 3b |
| 12/17 | 14. | REAR BEDROOM CEILING - replace broken ceiling fixture. | 3a |
| 12/17 | 15. | LIVINGROOM CEILING - repair loose ceiling fixture. | 3c |
| 12/17 | 16. | FRONT BEDROOM CEILING - repair loose ceiling fixture. | 3c |
| 12/17 | 17. | FRONT BEDROOM WINDOW - replace broken glass. | 3c |
| 8 | 18. | BATHROOM LAVATORY - replace broken lavatory. | 6d |

WHEN MAKING YOUR REPAIRS, FIRST PRIORITY IS TO BE GIVEN TO ITEMS WITH ASTERISKS, AS THEY CONSTITUTE EXTREME HAZARDS TO THE HEALTH OR SAFETY OF THE OCCUPANTS OF THIS STRUCTURE.

We suggest you contact the City of Portland Building Inspection Department, 339 Congress Street, Tel. 775-5451, to determine if any of the items listed above require a building or alteration permit.

P 032 223 721

RECEIPT FOR CERTIFIED MAIL

NO INSURANCE COVERED BY POST OFFICE
FOR REGISTERED MAIL

(See Reverse)

Send to	
Marigold Inc.	
Street or P.O. Box	
P. O. Box 1823	
P.O. State and ZIP Code	
223 Cumb. Ave., Port. 04104	
Postage	\$
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom and Date Delivered	
Return Receipt Showing to Whom Date and Address of Delivery	
TOTAL Postage and Fees	\$
Postmark or Date	

PS Form 3800, Feb. 1982
U.S.G.P.O. 1954-460-014

Re: 56 Wilnot St. - A. Addato - Hous.

PS Form 3811, July 1984 447 BMS

SENDER: Complete items 1, 2, 3 and 4.
Put your address in the "RETURN TO" space on the reverse side. Failure to do this will prevent this card from being returned to you. The return receipt fee will provide you the name of the person delivered to and the date of delivery. For additional fees the following services are available. Consult postmaster for fees and check boxes for services requested.

- Show to whom, date and address of delivery.
- Restricted Delivery.

3. Article Addressed to:
Marigold Inc.
P. O. Box 1823
223A Cumberland Ave.
Portland, ME 04104

4. Type of Service:	Article Number
<input checked="" type="checkbox"/> Registered <input type="checkbox"/> Insured <input type="checkbox"/> Certified <input type="checkbox"/> COD <input type="checkbox"/> Express Mail	223 721

Always obtain signature of addressee or agent and **DATE DELIVERED.**

5. Signature - Addressee
X *Anna P. Addato*

6. Signature - Agent
X

7. Date of Delivery

8. Addressee's Address (ONLY if requested and fee paid)

DOMESTIC RETURN RECEIPT

Re: 56 Wilnot St. - A. Addato - Housing



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

April 8, 1986

Marigold Inc.
P.O. Box 1823
223A Cumberland Avenue
Portland, ME 04104

Re. 56 Wilmot St. - 1,2 Floor Apartments

Dear Sir:

We recently received a complaint and an inspection was made by Code Enforcement Officer Arthur Addato of the property owned by you at 56 Wilmot Street, Portland, Maine. As a result of the inspection, you are hereby ordered to correct the following substandard housing conditions:

1. BATHROOM - window - loose sash. 108-3
2. BATHROOM - floor - holes. 108-2
3. BATHROOM - toilet - leaking seal. 111-1
4. LIVING ROOM - ceiling - sagging. 108-2
5. FRONT BEDROOM - ceiling - sagging. 108-2
6. REAR HALL - stairs - obstructed egress. 116-2
7. OVERALL DWELLING UNIT - excessive fuse blowing. 113
8. FUSE BOX - provide access. 113


FIRST FLOOR


9. LIVING ROOM - ceiling - leaking. 108-2
10. BATHROOM - ceiling - missing plaster. 108-2
11. KITCHEN - ceiling - inoperative light fixture. 113
12. BATHROOM - floor - holes. 108-2
13. BATHROOM - toilet - leaking seal. 111-1

The above mentioned conditions are in violation of Article V of the Municipal Code of the City of Portland, Maine, and must be corrected on or before April 18, 1986.

Failure to comply with this order may result in a complaint being filed for prosecution in District Court.

Sincerely yours,
Joseph E. Gray, Jr., Director of
Planning & Urban Development

By 
P. Samuel Hoffses
Chief of Inspection Services


Code Enforcement Officer - A. Addato (7)

jmr



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

April 8, 1986

OK
4-24-86
A. Addato

Marigold Inc.
P.O. Box 1823
223A Cumberland Avenue
Portland, ME 04104

Re: 56 Wilmot St. - 1,2 Floor Apartments

Dear Sir:

We recently received a complaint and an inspection was made by Code Enforcement Officer Arthur Addato of the property owned by you at 56 Wilmot Street, Portland, Maine. As a result of the inspection, you are hereby ordered to correct the following substandard housing conditions:

- 2 FL* 1. ~~BATHROOM - window - loose sash. 108-3~~
- 4-24-86* 2. ~~BATHROOM - floor - holes. 108-2~~
- 3. ~~BATHROOM - toilet - leaking seal. 111-1~~
- 4. ~~LIVING ROOM - ceiling - sagging. 108-2~~
- 5. ~~FRONT BEDROOM - ceiling - sagging. 108-2~~
- 6. ~~REAR HALL - stairs - obstructed egress. 116-2~~
- 7. ~~OVERALL DWELLING UNIT - excessive fuse blowing. 113~~
- 8. ~~FUSE BOX - provide access. 113~~

- 4/24/86* 9. ~~LIVING ROOM - ceiling - leaking. 108-2~~
- 10. ~~BATHROOM - ceiling - missing plaster. 108-2~~
- 11. ~~KITCHEN - ceiling - inoperative light fixture. 115~~
- 12. ~~BATHROOM - floor - holes. 108-2~~
- 13. ~~BATHROOM - toilet - leaking seal. 111-1~~

The above mentioned conditions are in violation of Article V of the Municipal Code of the City of Portland, Maine, and must be corrected on or before April 18, 1986.

Failure to comply with this order may result in a complaint being filed for prosecution in District Court.

Sincerely yours,
Joseph E. Gray, Jr., Director of
Planning & Urban Development

[Signature]
By _____
P. Samuel Hoffses
Chief of Inspection Services

[Signature]

Code Enforcement Officer - A. Addato (7)

jmr

REINSPECTION RECOMMENDATIONS

LOCATION 756 Walnut St.
 PROJECT NCP EE
 OWNER Margaret Jones

INSPECTOR Adkins

NOTICE OF HOUSING CONDITIONS		HEARING NOTICE		FINAL NOTICE	
Issued	Expired	Issued	Expired	Issued	Expired
<u>4-8-86</u>	<u>4-18-86</u>				

A reinspection was made of the above premises and I recommend the following action:

DATE	RECOMMENDATION
	ALL VIOLATIONS HAVE BEEN CORRECTED Send "CERTIFICATE OF COMPLIANCE" _____ "POSTING RELEASE" _____
	SATISFACTORY Rehabilitation in Progress Time Extended To: _____
	Time Extended To: _____
	Time Extended To: _____
	UNSATISFACTORY Progress Send "HEARING NOTICE" _____ "FINAL NOTICE" _____
	"NOTICE TO VACATE" POST Entire _____ POST Dwelling Units _____
	UNSATISFACTORY Progress "LEGAL ACTION" To be Taken _____

INSPECTOR'S REMARKS: Supervised as a mutual witness
for this property. 1-4 PM
4-23-86
4-24-86 iea RE/LD-LDC

INSTRUCTIONS TO INSPECTOR: _____



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

November 19, 1986

Marigold Inc.
223 1/2 Cumberland Avenue
Portland, Maine 04101

DU: 2

Dear Sir:

RE: 56 Wilmot Street
26-O-16 District 7


The Housing Inspections Division of the Department of Planning and Urban Development has recently completed an overall inspection of the above referred property.

Congratulations are extended to you for the general condition of your property which was found to meet the standards established by the City's Housing Code.

Good maintenance is the best way to protect the value of your property and neighborhood.

Please feel free to call on us if we can be of assistance to you.

Sincerely yours,
Joseph E. Gray, Jr., Director
Planning & Urban Development


P. Samuel Hoffses,
Chief of Inspection Services


Code Enforcement Officer

Arthur Addato (7)

jmr



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

NOTICE OF HOUSING CONDITIONS

DU: 4
CHART-BLOCK-LOT - 26-O-6
LOCATION: 56-56R Wilmot Street (BAYSIDE)

DISTRICT: 7
ISSUED: February 16, 1990
EXPIRES: April 16, 1990

Peter Wovkonish
223A Cumberland Avenue
Portland, ME 04101

Dear Mr. Wovkonish:

You are hereby notified, as owner or agent, that an inspection was made of the premises at 56-56R Wilmot Street by Code Enforcement Officer Mark Mitchell. Violations of Article V of the Municipal Ordinance (Housing Code) were found as described in detail on the attached "Housing Inspection Report".

In accordance with the provisions of the above mentioned Code, you are hereby ordered to correct those defects on or before April 16, 1990. If you are unable to make such repairs within the specified time, you may contact this office to arrange a satisfactory repair schedule. If we do not hear from you within ten (10) days from this date, we will assume the repairs to be in progress and, on re-inspection within the time set forth above, will anticipate that the premises have been brought into compliance with the Housing Code Standards.


Please Note: You should consult the inspection Services Division to insure that any corrective action you undertake complies with the building, plumbing, electrical, zoning and other Article of the City Code.


Please contact this office if you have any questions regarding this order.

Your cooperation will aid this department in its goal to maintain decent, safe, and sanitary housing for all of Portland's residents.

Very truly yours,

Joseph E. Gray, Jr., Director
Planning & Urban Development

By: 
P. Samuel Hoffman
Chief of Inspection Services


Mark Mitchell for Arthur Addato (7)
Code Enforcement Officer

Attachments

jmr

389 CONGRESS STREET • PORTLAND, MAINE 04101 • TELEPHONE (207) 775-5451

HOUSING INSPECTION REPORT

OWNER: Peter Wovkonish

LOCATION: 56-56R Wilmot St. 26-0-6

CODE ENFORCEMENT OFFICER: Mark Mitchell for Arthur Addato (7)

HOUSING CONDITIONS DATED: Feb. 16, 1990 EXPIRES: April 16, 1990

ITEMS LISTED BELOW ARE IN VIOLATION OF ARTICLE V OF THE MUNICIPAL CODES, "HOUSING CODE", AND MUST BE CORRECTED ON OR BEFORE THE EXPIRATION DATE.

- | | <u>SEC. (S)</u> |
|---|-----------------|
| 1. INTERIOR BASEMENT - no ground between panel and pipe. | 113 |
| 2. INTERIOR FIRST FLOOR, APT. #1 - living room - crack in wall, low left, drafty. | 108-2 |
| 3. INTERIOR FIRST FLOOR, APT. #1 - missing storms throughout. | 108-3 |
| 4. INTERIOR FIRST FLOOR, APT. #1 - bathroom - provide G.F.I. | 113 |
| <u>56R WILMOT STREET</u> | |
| 5. SECOND FLOOR, APT. #2 - hallway to #2 - window - no sash cord. | 108-3 |



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

CERTIFICATE OF COMPLIANCE

DATE: April 30, 1990

DU: 4

Housing Inspections Division
Telephone: 775-5451 - Extension 311

Peter Wovkonish
223A Cumberland Avenue
Portland, ME 04101

RE: Premises located at 56-56R Wilmot Street 26-0-6

Dear Mr. Wovkonish:

A re-inspection of the premises noted above was made on April 12, 1990
by Code Enforcement Officer Arthur Addato

This is to certify that you have complied with our request to correct the violation(s) of the Municipal Code relating to housing conditions as described in our "Notice of Housing Conditions" dated February 16, 1990.


Thank you for your cooperation and your efforts to help us maintain decent, safe and sanitary housing for all Portland residents.

In order to aid in the preservation of Portland's existing housing inventory, it shall be the policy of this department to inspect each residential building at least once every five years. Although a property is subject to re-inspection at any time during the said five-year period, the next regular inspection of this property is scheduled for April 1995.

Sincerely yours.

Joseph E. Gray, Jr., Director,
Planning & Urban Development

By 
P. Samuel Hoopes
Chief of Inspection Services


Arthur Addato (7)
Code Enforcement Officer

jmr



CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
INSPECTION SERVICES DIVISION

NOTICE OF HOUSING CONDITIONS

DU: 4
CHART-BLOCK-LOT - 26-O-6
LOCATION: 56-56R Wilmot Street (BAYSIDE)
DISTRICT: 7
ISSUED: February 16, 1990
EXPIRES: April 16, 1990

Peter Wovkonish
223A Cumberland Avenue
Portland, ME 04101

Dear Mr. Wovkonish:

You are hereby notified, as owner or agent, that an inspection was made of the premises at 56-56R Wilmot Street by Code Enforcement Officer Mark Mitchell. Violations of Article V of the Municipal Ordinance (Housing Code) were found as described in detail on the attached "Housing Inspection Report".

In accordance with the provisions of the above mentioned Code, you are hereby ordered to correct those defects on or before April 16, 1990. If you are unable to make such repairs within the specified time, you may contact this office to arrange a satisfactory repair schedule. If we do not hear from you within ten (10) days from this date, we will assume the repairs to be in progress and, on re-inspection within the time set forth above, will anticipate that the premises have been brought into compliance with the Housing Code Standards.


Please Note: You should consult the Inspection Services Division to insure that any corrective action you undertake complies with the building, plumbing, electrical, zoning and other Article of the City Code.


Please contact this office if you have any questions regarding this order.

Your cooperation will aid this department in its goal to maintain decent, safe, and sanitary housing for all of Portland's residents.

Very truly yours,

Joseph E. Gray, Jr., Director
Planning & Urban Development

By: 
P. Samuel Hoff, Jr.
Chief of Inspection Services


Mark Mitchell for Arthur Addato (7)
Code Enforcement Officer

Attachments

jmr

389 CONGRESS STREET • PORTLAND, MAINE 04101 • TELEPHONE (207) 775-5451

OK
C.O.C
4-12-90
a.a.

HOUSING INSPECTION REPORT

OWNER: Peter Wovkonish

LOCATION: 56-56R Wilmot St. 26-0-6

CODE ENFORCEMENT OFFICER: Mark Mitcheli for Arthur Addato (7)

HOUSING CONDITIONS DATED: Feb. 16, 1990 EXPIRES: April 16, 1990

ITEMS LISTED BELOW ARE IN VIOLATION OF ARTICLE V OF THE MUNICIPAL CODES, "HOUSING CODE", AND MUST BE CORRECTED ON OR BEFORE THE EXPIRATION DATE.

		SEC.(S)
4-12-90 OK	1 INTERIOR BASEMENT - no ground between panel and pipe.	113
	2 INTERIOR FIRST FLOOR, APT. #1 - living room - crack in wall, low left, drafty.	108-2
	3 INTERIOR FIRST FLOOR, APT. #1 - missing storms throughout.	108-3
	4 INTERIOR FIRST FLOOR, APT. #1 - bathroom - provide G.F.I.	113
	<u>56R WILMOT STREET</u>	
5 SECOND FLOOR, APT. #2 - hallway to #2 - window - no sash cord.	108-3	

