

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

50-52 WILMOT STREET LLC (Crandall Toothaker)

Located at

50 WILMOT ST (Building 1)

PERMIT ID: 2016-01486

ISSUE DATE: 07/22/2016

CBL: 026 0007001

has permission to **Remove existing, right side rear steps & add new 45 Sq. Ft. entry porch with steps. Add 2nd & 3rd floor covered decks above including slight expansion over existing porch**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Michael White

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

50 Wilmot - 3 dwelling units ; 52 Wilmot - 3 dwelling units.

Building Inspections

Use Group: R-2 **Type:** 5B
Residential Apartments - 3 Units
NFPA 13R sprinkler system
Multi-level decks
MUBEC/IBC 2009

Fire Department

Classification:
Apartment Building
ENTIRE
2009 NFPA 101

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Setbacks and Footings Prior to Pouring

Framing Only

Final - Commercial

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-01486	Date Applied For: 06/06/2016	CBL: 026 O007001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: 50 Wilmot - 3 Family	Proposed Project Description: Remove existing, right side rear steps & add new 45 Sq. Ft. entry porch with steps. Add 2nd & 3rd floor covered decks above including slight expansion over existing porch			
Dept: Zoning Status: Approved w/Conditions Reviewer: Ann Machado Approval Date: 07/13/2016 Note: R-6 Zone Ok to Issue: <input checked="" type="checkbox"/> - front - 5' min. - OK - rear - 10' min. - 31. 9' scaled - OK - side - 5' - 16.78' shown to building 2 on property - OK Conditions: 1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Jeanie Bourke Approval Date: 07/21/2016 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. 2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 3) The NFPA 13R sprinkler system is required to be continued onto the covered decks.				
Dept: Fire Status: Approved w/Conditions Reviewer: Michael White Approval Date: 07/19/2016 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) All construction shall comply with 2009 NFPA 101, Chapter 31 Existing Apartment Buildings. 2) All means of egress to remain accessible at all times. 3) All construction shall comply with 2009 NFPA 101, Chapter 43 Building Rehabilitation. 4) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4). 5) All construction shall comply with City Code, Chapter 10.				