

. . . Fire Protection by Computer Design

Residential Fire Protection
64 Daggett Hill Rd.
Greene, ME 04236
946-3473

Job Name : 52 WILMOT STREET APT
Building : WOOD STRUCTURE
Location : BASEMENT
System : WET
Contract : C16032
Data File : 52 WILMOT ST APT-BASEMENT.WXF

Hydraulic Design Information Sheet

Name - 52 WILMOT STREET APARTMENTS Date - 6/28/2017
 Location - BASEMENT
 Building - WOOD STRUCTURE System No. - WET
 Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - C16032
 Calculated By - T. PRAY Drawing No. - 1 OF 1
 Construction: (X) Combustible () Non-Combustible Ceiling Height - 7.54'
 Occupancy - BASEMENT SPACE

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. (X) 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 935	System Type	Sprinkler/Nozzle
	Density	- .15	(X) Wet	Make VIKING
D	Area Per Sprinkler	- 100-130	() Dry	Model VK300
E	Elevation at Highest Outlet	- 89.54	() Deluge	Size 1/2"
S	Hose Allowance - Inside	-	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	-	() Other	Temp.Rat.155
G	Hose Allowance - Outside	- 100		

N Note

Calculation Flow Required - 489.93 Press Required - 76.7 AT TEST
 Summary C-Factor Used: 120 Overhead 150 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 9/16/2016		Cap. -
T	Time of Test - N/A	Rated Cap.-	Elev.-
E	Static Press - 82	@ Press -	
R	Residual Press - 74	Elev. -	Well
S	Flow - 1453		Proof Flow
U	Elevation - 108.0'		

P Location - HYDRANTS ARE LOCATED ON WILMOT STREET, SEE PLOT PLAN FOR MORE
 P INFORMATION
 L Source of Information - PORTLAND WATER DISTRICT
 Y

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

E Horizontal Barriers Provided:

Water Supply Curve (C)

Residential Fire Protection
52 WILMOT STREET APT


Page 2
Date 10/26/16

City Water Supply:

C1 - Static Pressure : 82
C2 - Residual Pressure: 74
C2 - Residual Flow : 1453

Demand:

D1 - Elevation : -7.995
D2 - System Flow : 239.931
D2 - System Pressure : 76.696
Hose (Adj City) : _____
Hose (Demand) : 250
D3 - System Demand : 489.931
Safety Margin : 4.234



Fittings Used Summary

Residential Fire Protection
52 WILMOT STREET APT

Page 3
Date 10/26/16

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

Pressure / Flow Summary - STANDARD

Residential Fire Protection
52 WILMOT STREET APT

Page 4
Date 10/26/16

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DO01	0.0	5.6	12.13	na	19.5	0.15	130	7.0
30	89.54	5.6	7.17	na	15.0	0.15	100	7.0
31	89.54	5.6	7.79	na	15.63	0.15	100	7.0
32	89.54	5.6	12.1	na	19.48	0.15	100	7.0
50	89.54		12.4	na				
33	89.54	5.6	13.48	na	20.56	0.15	113	7.0
34	89.54	5.6	9.09	na	16.88	0.15	100	7.0
35	89.54	5.6	9.85	na	17.57	0.15	100	7.0
36	89.54	5.6	12.98	na	20.17	0.15	113	7.0
51	89.54		13.91	na				
52	89.54		15.11	na				
53	89.54		17.49	na				
37	88.12	5.6	19.95	na	25.01	0.15	100	7.0
38	89.25	K = K @ EQ01	27.13	na	28.8			
39	89.25	K = K @ EQ01	27.38	na	28.93			
54A	89.25		29.87	na				
54	88.67		35.28	na				
40	89.25	K = K @ EQ01	33.26	na	31.89			
55A	89.25		36.59	na				
55	88.67		38.56	na				
TOR	88.67		52.43	na				
BOR	83.05		65.91	na				
CITY	83.05		81.32	na	250.0			
TEST	108.0		76.7	na				

The maximum velocity is 25.54 and it occurs in the pipe between nodes BOR and CITY

Final Calculations - Hazen-Williams

Residential Fire Protection
52 WILMOT STREET APT

Page 5
Date 10/26/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DO01 to EQ01	19.50 19.5 0.0 19.50	1.049 120 0.1244	1E	2.0 0.0 0.0	0.500 2.000 2.500	12.125 0.0 0.311			K Factor = 5.60 Vel = 7.24	
						12.436			K Factor = 5.53	
30 to 31	15.00 15.0	1.049 120 0.0764		0.0 0.0 0.0	8.000 0.0 8.000	7.175 0.0 0.611			K Factor = 5.60 Vel = 5.57	
31 to 50	15.63 30.63 0.0 30.63	1.049 120 0.2863	1T	5.0 0.0 0.0	11.125 5.000 16.125	7.786 0.0 4.616			K Factor = 5.60 Vel = 11.37	
						12.402			K Factor = 8.70	
32 to 50	19.48 19.48	1.049 120 0.1240		0.0 0.0 0.0	2.420 0.0 2.420	12.102 0.0 0.300			K Factor = 5.60 Vel = 7.23	
50 to 33	30.63 50.11	1.38 120 0.1871	1E	3.0 0.0 0.0	2.750 3.000 5.750	12.402 0.0 1.076			Vel = 10.75	
33 to 53	20.56 70.67 0.0 70.67	1.61 120 0.1669	1E 1T	4.0 8.0 0.0	12.040 12.000 24.040	13.478 0.0 4.012			K Factor = 5.60 Vel = 11.14	
						17.490			K Factor = 16.90	
34 to 35	16.88 16.88	1.049 120 0.0951		0.0 0.0 0.0	8.000 0.0 8.000	9.087 0.0 0.761			K Factor = 5.60 Vel = 6.27	
35 to 51	17.57 34.45 0.0 34.45	1.049 120 0.3560		0.0 0.0 0.0	11.420 0.0 11.420	9.848 0.0 4.065			K Factor = 5.60 Vel = 12.79	
						13.913			K Factor = 9.24	
36 to 51	20.17 20.17	1.049 120 0.1322	1T	5.0 0.0 0.0	2.080 5.000 7.080	12.977 0.0 0.936			K Factor = 5.60 Vel = 7.49	
51 to 52	34.46 54.63	1.38 120 0.2196		0.0 0.0 0.0	5.460 0.0 5.460	13.913 0.0 1.199			Vel = 11.72	
52 to 53	0.0 54.63	1.38 120 0.2196	1E 1T	3.0 6.0 0.0	1.830 9.000 10.830	15.112 0.0 2.378			Vel = 11.72	
53 to 37	70.66 125.29	1.61 120 0.4817		0.0 0.0 0.0	3.830 0.0 3.830	17.490 0.615 1.845			Vel = 19.74	
37 to 54	25.02 150.31 0.0	1.61 120 0.6742	3E	12.0 0.0 0.0	11.090 12.000 23.090	19.950 -0.238 15.568			K Factor = 5.60 Vel = 23.69	

Final Calculations - Standard

Residential Fire Protection
52 WILMOT STREET APT

Page 6
Date 10/26/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	150.31					35.280			K Factor = 25.31	
38 to 54A	28.80 28.8	1.049 120 0.2555	1T	5.0 0.0	5.710 5.000	27.131 0.0			K Factor @ node EQ01	
	0.0 28.80				10.710	2.736			Vel = 10.69	
						29.867			K Factor = 5.27	
39 to 54A	28.93 28.93	1.049 120 0.2576	1T	5.0 0.0	4.670 5.000	27.376 0.0			K Factor @ node EQ01	
					9.670	2.491			Vel = 10.74	
54A to 54	28.80 57.73	1.049 120 0.9251	1T	5.0 0.0	0.580 5.000	29.867 0.251				Vel = 21.43
54 to 55	150.31 208.04	2.067 120 0.3643		0.0 0.0	9.000 0.0	35.280 0.0				Vel = 19.89
	0.0 208.04					9.000 3.279				
						38.559			K Factor = 33.50	
40 to 55A	31.89 31.89	1.049 120 0.3084	1T	5.0 0.0	5.790 5.000	33.258 0.0			K Factor @ node EQ01	
					10.790	3.328			Vel = 11.84	
55A to 55	0.0 31.89	1.049 120 0.3086	1T	5.0 0.0	0.580 5.000	36.586 0.251				Vel = 11.84
55 to TOR	208.04 239.93	2.067 120 0.4744	1E	5.0 0.0	24.250 5.000	38.559 0.0				Vel = 22.94
TOR to BOR	0.0 239.93	2.067 120 0.4744	1Z	5.0 0.0	5.625 5.000	52.434 8.434			* Fixed loss = 6	Vel = 22.94
BOR to CITY	0.0 239.93	1.959 150 0.4077	1G 1T	1.164 11.635	25.000 12.799	65.908 0.0				Vel = 25.54
CITY to TEST	250.00 489.93	4.1 140 0.0476		0.0 0.0	130.000 0.0	81.318 -10.806			Qa = 250	Vel = 11.91
	0.0 489.93				130.000	6.184				
						76.696			K Factor = 55.94	