

**. . . Fire Protection by Computer Design**

Residential Fire Protection  
64 Daggett Hill Rd.  
Greene, ME 04236  
(207)946-343

Job Name : 48 WILLOT STREET APT  
Building : WOOD STRUCTURE  
Location : OUTSIDE DECK  
System : WET  
Contract : 16025  
Data File : 48 WILMOT ST APT-HYD CALC-AFLW XF.WXF

Hydraulic Design Information Sheet

Name - 48 WILMOT STREET APT Date - 9/2/16  
 Location - OUTSIDE DECK  
 Building - WOOD STRUCTURE System No. - WET  
 Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - 16025  
 Calculated By - Drawing No. - 1 OF 2  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - 7'-9"  
 Occupancy - DECK

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 1 HEAD	System Type	Sprinkler/Nozzle
	Density	- .1	( ) Wet	Make VIKING
D	Area Per Sprinkler	- 149	( ) Dry	Model VK305
E	Elevation at Highest Outlet	-	( ) Deluge	Size 1/2"
S	Hose Allowance - Inside	-	( ) Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	-	( ) Other	Temp.Rat.155
G	Hose Allowance - Outside	- 100		

N Note

Calculation Flow Required - 114.9 Press Required - 29.54 AT TEST  
 Summary C-Factor Used: 120 Overhead 150 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 6/20/2012		Cap. -
T	Time of Test - N/A	Rated Cap.-	Elev.-
E	Static Press - 96	@ Press -	
R	Residual Press - 94	Elev. -	Well
S	Flow - 1352		Proof Flow
U	Elevation - 99.0		

P Location - HYDRANTS ARE LOCATED ON WILMOT STREET, SEE PLOT PLAN

L Source of Information - PORTLAND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T	( ) Mult. Row		( ) Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

E Horizontal Barriers Provided:

# Water Supply Curve (C)

Residential Fire Protection  
48 WILLOT STREET APT


Page 2  
Date 8/30/16

### City Water Supply:

C1 - Static Pressure : 96  
C2 - Residual Pressure: 94  
C2 - Residual Flow : 1352

### Demand:

D1 - Elevation : 11.425  
D2 - System Flow : 14.9  
D2 - System Pressure : 29.543  
Hose ( Adj City ) : \_\_\_\_\_  
Hose ( Demand ) : 100  
D3 - System Demand : 114.9  
Safety Margin : 66.436



# Fittings Used Summary

Residential Fire Protection  
48 WILLOT STREET APT

Page 3  
Date 8/30/16

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	Generic Swing Check Valve	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

# Pressure / Flow Summary - STANDARD

Residential Fire Protection  
48 WILLOT STREET APT

Page 4  
Date 8/30/16

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
100	125.38	5.6	7.08	na	14.9	0.1	149	7.0
101	125.38		10.16	na				
102	125.38		17.63	na				
57	98.62		29.23	na				
58	98.62		29.42	na				
59	98.62		29.48	na				
TOR	98.62		29.5	na				
BFP	94.62		31.28	na				
BOR	94.62		31.3	na				
TEST	99.0		29.54	na	100.0			

The maximum velocity is 5.53 and it occurs in the pipe between nodes 100 and 101

# Final Calculations - Hazen-Williams

Residential Fire Protection  
48 WILLOT STREET APT

Page 5  
Date 8/30/16

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
100 to 101	14.90 14.9	1.049 120 0.0755	5E 10.0 0.0 0.0	30.750 10.000 40.750	7.079 0.0 3.077		K Factor = 5.60 Vel = 5.53		
101 to 102	0.0 14.9	1.049 120 0.0755	2T 10.0 4E 8.0 1S 5.0	76.040 23.000 99.040	10.156 0.0 7.476		Vel = 5.53		
102 to 57	0.0 14.9	1.61 150 0.0052	0.0 0.0 0.0	0.580 0.0 0.580	17.632 11.590 0.003		Vel = 2.35		
57 to 58	0.0 14.9	1.61 120 0.0094	1E 4.0 0.0 0.0	16.580 4.000 20.580	29.225 0.0 0.193		Vel = 2.35		
58 to 59	0.0 14.9	2.067 120 0.0028	2E 10.0 0.0 0.0	13.960 10.000 23.960	29.418 0.0 0.066		Vel = 1.42		
59 to TOR	0.0 14.9	2.067 120 0.0028	1E 5.0 0.0 0.0	1.830 5.000 6.830	29.484 0.0 0.019		Vel = 1.42		
TOR to BFP	0.0 14.9	2.067 120 0.0028	1Z 5.0 1E 5.0 0.0	5.000 10.000 15.000	29.503 1.732 0.042		Vel = 1.42		
BFP to BOR	0.0 14.9	2.067 120 0.0029	1E 5.0 0.0 0.0	2.000 5.000 7.000	31.277 0.0 0.020		Vel = 1.42		
BOR to TEST	0.0 14.9	1.72 150 0.0045	1G 0.617 1T 6.174 0.0	25.000 6.792 31.792	31.297 -1.897 0.143		Vel = 2.06		
	100.00 114.90				29.543		Qa = 100.00 K Factor = 21.14		