

. . . Fire Protection by Computer Design

Residential Fire Protection
64 Daggett Hill Rd.
Greene, ME 04236
(207)946-343

Job Name : 48 WILMOT STREET APT'S
Building : WOOD STRUCTURE
Location : BASEMENT
System : WET
Contract : 16025
Data File : 48 WILMOT ST APT-HYD CALC-BASEMENT.WXF

Hydraulic Design Information Sheet

Name - 48 WILMOT STREET APT Date - 9/2/16
 Location - BASEMENT
 Building - WOOD STRUCTURE System No. - WET
 Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - 16025
 Calculated By - Drawing No. - 1 OF 2
 Construction: (X) Combustible () Non-Combustible Ceiling Height - 6'-6 1/2
 Occupancy - BASEMENT

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. (X) 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 946	System Type	Sprinkler/Nozzle
	Density	- .15	() Wet	Make VIKING
D	Area Per Sprinkler	- 130	() Dry	Model VK300
E	Elevation at Highest Outlet	-	() Deluge	Size 1/2"
S	Hose Allowance - Inside	-	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	-	() Other	Temp.Rat.200
G	Hose Allowance - Outside	- 250		

N Note

Calculation Flow Required - 478.92 Press Required - 85.06 AT TEST
 Summary C-Factor Used: 120 Overhead 150 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 6/20/2012		Cap. -
T	Time of Test - N/A	Rated Cap.-	Elev.-
E	Static Press - 96	@ Press -	
R	Residual Press - 94	Elev. -	Well
S	Flow - 1352		Proof Flow
U	Elevation - 99.0		

P Location - HYDRANTS ARE LOCATED ON WILMOT STREET, SEE PLOT PLAN

L Source of Information - PORTLAND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

E Horizontal Barriers Provided:

Water Supply Curve (C)

Residential Fire Protection
48 WILMOT STREET APT'S


Page 2
Date 8/30/16

City Water Supply:

C1 - Static Pressure : 96
C2 - Residual Pressure: 94
C2 - Residual Flow : 1352

Demand:

D1 - Elevation : -0.165
D2 - System Flow : 228.916
D2 - System Pressure : 85.055
Hose (Adj City) : _____
Hose (Demand) : 250
D3 - System Demand : 478.916
Safety Margin : 10.652



Fittings Used Summary

Residential Fire Protection
48 WILMOT STREET APT'S

Page 3
Date 8/30/16

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

Pressure / Flow Summary - STANDARD

Residential Fire Protection
48 WILMOT STREET APT'S

Page 4
Date 8/30/16

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	98.62	5.6	12.13	na	19.5	0.15	130	7.0
2	98.62	5.6	12.87	na	20.09	0.15	130	7.0
3	98.62	5.6	15.63	na	22.14	0.15	130	7.0
4	98.62	5.6	17.15	na	23.19	0.15	130	7.0
5	98.62	5.6	18.79	na	24.27	0.15	130	7.0
6	98.62	5.6	21.4	na	25.91	0.15	130	7.0
7	98.62	5.6	13.53	na	20.6	0.15	130	7.0
8	98.62	5.6	14.9	na	21.62	0.15	130	7.0
9	98.62	5.6	19.65	na	24.83	0.15	130	7.0
10	98.62	5.6	22.86	na	26.78	0.15	130	7.0
59	98.62		28.34	na				
57	98.62		28.41	na				
58	98.62		39.8	na				
60	97.95		44.02	na				
TR	97.95		46.99	na				
BFP	93.95		54.81	na				
BR	93.95		64.85	na				
TEST	99.0		85.06	na	250.0			

The maximum velocity is 31.61 and it occurs in the pipe between nodes BR and TEST

Final Calculations - Hazen-Williams

Residential Fire Protection
48 WILMOT STREET APT'S

Page 5
Date 8/30/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1	19.50	1.049			6.000	12.125				
to		120		0.0	0.0	0.0			K Factor = 5.60	
2	19.5	0.1242			6.000	0.745			Vel = 7.24	
2	20.09	1.049			6.000	12.870			K Factor = 5.60	
to		120		0.0	0.0	0.0				
3	39.59	0.4603			6.000	2.762			Vel = 14.70	
3	22.14	1.38			5.500	15.632			K Factor = 5.60	
to		120		0.0	0.0	0.0				
4	61.73	0.2753			5.500	1.514			Vel = 13.24	
4	23.19	1.61			7.000	17.146			K Factor = 5.60	
to		120		0.0	0.0	0.0				
5	84.92	0.2346			7.000	1.642			Vel = 13.38	
5	24.27	1.61			7.000	18.788			K Factor = 5.60	
to		120		0.0	0.0	0.0				
6	109.19	0.3733			7.000	2.613			Vel = 17.21	
6	25.91	2.067			42.750	21.401			K Factor = 5.60	
to		120		0.0	0.0	0.0				
57	135.1	0.1639			42.750	7.008			Vel = 12.92	
	0.0									
	135.10					28.409			K Factor = 25.35	
7	20.60	1.049			10.000	13.528			K Factor = 5.60	
to		120		0.0	0.0	0.0				
8	20.6	0.1374			10.000	1.374			Vel = 7.65	
8	21.61	1.049			9.170	14.902			K Factor = 5.60	
to		120		0.0	0.0	0.0				
9	42.21	0.5183			9.170	4.753			Vel = 15.67	
9	24.83	1.38			10.000	19.655			K Factor = 5.60	
to		120		0.0	0.0	0.0				
10	67.04	0.3207			10.000	3.207			Vel = 14.38	
10	26.78	1.61			19.420	22.862			K Factor = 5.60	
to		120		0.0	0.0	0.0				
59	93.82	0.2819			19.420	5.475			Vel = 14.79	
59	0.0	1.61	1E	4.0	42.590	28.337				
to		120	1T	8.0	12.000	0.290				
60	93.82	0.2819			54.590	15.391			Vel = 14.79	
	0.0									
	93.82					44.018			K Factor = 14.14	
57	135.10	1.61	1E	4.0	16.580	28.409				
to		120		0.0	4.000	0.0				
58	135.1	0.5535			20.580	11.391			Vel = 21.29	
58	0.0	2.067	2E	10.0	13.960	39.800				
to		120		0.0	10.000	0.290				
60	135.1	0.1639			23.960	3.928			Vel = 12.92	
60	93.82	2.067	1E	5.0	1.830	44.018				
to		120		0.0	5.000	0.0				
TR	228.92	0.4348			6.830	2.970			Vel = 21.89	
TR	0.0	2.067	1Z	5.0	4.000	46.988				
to		120	1E	5.0	10.000	1.732				
BFP	228.92	0.4349			14.000	6.088			Vel = 21.89	

Final Calculations - Standard

Residential Fire Protection
48 WILMOT STREET APT'S

Page 6
Date 8/30/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BFP to BR	0.0 228.92	2.067 120 0.4349	1E	5.0 0.0 7.000	2.000 5.000 7.000	54.808 7.000 3.044		* Fixed loss = 7 Vel = 21.89	
BR to TEST	0.0 228.92	1.72 150 0.7043	1G 1T	0.617 6.174 0.0	25.000 6.792 31.792	64.852 -2.187 22.390		Vel = 31.61	
	250.00 478.92					85.055		Qa = 250.00 K Factor = 51.93	