DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





This is to certify that

48 WILMOT STREET LLC

Located at

48 WILMOT ST

has permission to For the installation of a water-based fire suppression system.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Michael White

/s/ Michael Russell, MS, Director

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases 6 months.
- If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop W Order" and subsequent release to continue.

REQUIRED INSPECTIONS:

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

PERMIT ID: 2016-02649 **Located at:** 48 WILMOT ST **CBL:** 026 O008001

	refinit No.	Date Applied For:	CBL.		
4-8716	2016-02649	10/07/2016	026 O008001		
Proposed	Project Description:		-		
Same: Apartment building For the installat			stallation of a water-based fire suppression system.		
viewer:	Jennifer Thompso	on Approval Da	ite: 11/28/2016		
	Proposed For the	4-8716 2016-02649 Proposed Project Description: For the installation of a w	4-8716 2016-02649 10/07/2016 Proposed Project Description: For the installation of a water-based fire suppressions.		

Conditions:

Note:

- 1) The installation of the equipment and products shall be done per the manufacturers specifications.
- 2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.

Ok to Issue:

 Dept:
 Fire
 Status:
 Approved w/Conditions
 Reviewer:
 Michael White
 Approval Date:
 10/17/2016

 Note:
 Ok to Issue:
 ✓

Conditions:

- 1) Fire department connection type and location shall be approved by the AHJ.
- 2) Sprinkler supervisory systems shall monitor for water flow and sprinkler supervisory signals via an approved fire alarm panel to central station. One smoke detector shall be located over the panel, a manual pull station located at the front door, and an audible water flow alarm provided. A separate Fire Alarm Permit is required from a certified fire alarm company. This review does not include approval of system design or installation.
- 3) Sprinkler system installation shall comply with NFPA 13R.
- 4) All construction shall comply with 2009 NFPA 101, Chapter 9 Building Service and Fire Protection Equipment.
- 5) A Knox Box is required.
- 6) Application requires State Fire Marshal approval.
- 7) All construction shall comply with 2009 NFPA 101, Chapter 30 New Apartment Buildings.
- 8) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4).
- 9) All construction shall comply with City Code, Chapter 10.

PERMIT ID: 2016-02649 **Located at:** 48 WILMOT ST **CBL:** 026 O008001