PLAN NORTH

THIRD FLOOR FIRE ALARM PLAN

SCALE: 1/8"=1'-0"

0 4' 8' 16'

SHEET NOTES:

1. ADDRESSABLE MONITOR MODULE PROVIDED TO MONITOR THE CONVENTIONAL PULL STATION. INSTALLING CONTRACTOR SHALL FIELD VERIFY EXACT MOUNTING, CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY EXACT QUANTITY AND LOCATION(S).
2. FIELD VERIFY EXACT LOCATION FOR AES RADIO.

RESERVED FOR CITY STAMP

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	11/10/2016

SEACOAST SECURITY
4 Summer Street • Freeport, Maine 04032
Office: (207) 706-3369 • Fax: (207) 865-0852

15 UNIT APARTMENT BUILDING
48 WILMOT STREET
PORTLAND, MAINE 04101
THIRD FLOOR FIRE ALARM PLAN

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 12/14/16

CITY OF PORTLAND, MAINE RESURGAM

shop drawings
created by:
5794 W. 4600 So.,
Hooper, UT 84315
Office: 801.985.0410
UNI
www.unicad.net
Fire Alarm Des