PLAN NORTH

SECOND FLOOR FIRE ALARM PLAN

SCALE: 1/8"=1'-0"

0 4' 8' 16'

RESERVED FOR CITY STAMP

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	11/10/2016

SEACOAST SECURITY

4 Summer Street • Freeport, Maine 04032
Office: (207) 706-3369 • Fax: (207) 865-0852

15 UNIT APARTMENT BUILDING
48 WILMOT STREET
PORTLAND, MAINE 04101
SECOND FLOOR FIRE ALARM PLAN

SHEET NOTES:

1. ADDRESSABLE MONITOR MODULE PROVIDED TO MONITOR THE CONVENTIONAL PULL STATION. INSTALLING CONTRACTOR SHALL FIELD VERIFY EXACT MOUNTING, CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY EXACT QUANTITY AND LOCATION(S).

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 12/14/16

CITY OF PORTLAND, MAINE — RESURGAM

shop drawings created by:
5794 W. 4600 So.,
Hooper, UT 84315
Office: 801.985.0410
UNI
www.unicad.net Fire Alarm Des