

ZONE	ADDRESS	DEVICE	FLOOR	DESCRIPTION	TEST RESULTS
1	1D001	SMOKE DETECTOR	BASEMENT	ABOVE FACP	PASS
2	1D002	SMOKE DETECTOR	BASEMENT	NORTH CENTER	PASS
3	1D003	SMOKE DETECTOR	BASEMENT	CENTER AREA	PASS
4	1D004	SMOKE DETECTOR	BASEMENT	SOUTH CENTER	PASS
5	1D005	SMOKE DETECTOR	BASEMENT	SOUTH	PASS
6	1D006	SMOKE DETECTOR	2ND	STAIRWAY BY UNIT A-22	PASS
7	1D007	SMOKE DETECTOR	2ND	STAIRWAY BY UNIT C-21	PASS
8	1D008	SMOKE DETECTOR	2ND	STAIRWAY BY UNIT E-2	PASS
9	1D009	SMOKE DETECTOR	3RD	STAIRWAY BY UNIT E-3	PASS
10	1D010	SMOKE DETECTOR	3RD	STAIRWAY BY UNIT C-32	PASS
11	1D011	SMOKE DETECTOR	3RD	STAIRWAY BY UNIT A-32	PASS
160	1M001	SPRINKLER	BASEMENT	WATERFLOW	PASS
161	1M002	SPRINKLER	BASEMENT	GATE VALVE #1	PASS
162	1M003	PULL STATION	BASEMENT	EXIT	PASS
165	1M006	PULL STATION	1ST	STAIRWAY BY UNIT E-1	PASS
166	1M007	PULL STATION	1ST	UNIT D	PASS
167	1M008	PULL STATION	1ST	STAIRWAY BY UNIT C-1	PASS
168	1M009	PULL STATION	1ST	UNIT B	PASS
169	1M010	PULL STATION	1ST	STAIRWAY BY UNIT A-1	PASS
170	1M011	PULL STATION	2ND	STAIRWAY BY UNIT A-22	PASS
171	1M012	PULL STATION	2ND	STAIRWAY BY UNIT C-21	PASS
172	1M013	PULL STATION	2ND	STAIRWAY BY UNIT E-2	PASS
173	1M014	PULL STATION	3RD	STAIRWAY BY UNIT E-3	PASS
174	1M015	PULL STATION	3RD	STAIRWAY BY UNIT C-32	PASS
175	1M016	PULL STATION	3RD	STAIRWAY BY UNIT A-32	PASS
176	1M017	RADIO	BASEMENT	AES TROUBLE	PASS
177	1M018	SPRINKLER	BASEMENT	GATE VALVE #2	PASS

DEVICE	FLOOR	DESCRIPTION	TEST RESULTS
HORN/STROBE	BASEMENT	BY FACP	PASS
HORN/STROBE	BASEMENT	NORTH CENTER	PASS
HORN/STROBE	BASEMENT	CENTER	PASS
HORN/STROBE	BASEMENT	SOUTH CENTER	PASS
HORN/STROBE	BASEMENT	SOUTH	PASS
STROBE	BASEMENT	BATHROOM	PASS
MINI SOUNDER	1ST	UNIT A-1 BEDROOM	PASS
HORN/STROBE	1ST	STAIRWAY BY UNIT A-1	PASS
MINI SOUNDER	1ST	UNIT B BEDROOM	PASS
MINI SOUNDER	1ST	UNIT C-1 BEDROOM	PASS
HORN/STROBE	1ST	STAIRWAY BY UNIT C-1	PASS
MINI SOUNDER	1ST	UNIT D BEDROOM	PASS
HORN/STROBE	1ST	STAIRWAY BY UNIT E-1	PASS
MINI SOUNDER	1ST	UNIT E-1 BEDROOM	PASS
MINI SOUNDER	2ND	UNIT A-22 BEDROOM	PASS
HORN/STROBE	2ND	STAIRWAY BY UNIT A-22	PASS
MINI SOUNDER	2ND	UNIT A-21 BEDROOM	PASS
MINI SOUNDER	2ND	UNIT C-22 BEDROOM	PASS
HORN/STROBE	2ND	STAIRWAY BY UNIT C-21	PASS
MINI SOUNDER	2ND	UNIT C-21 BEDROOM	PASS
HORN/STROBE	2ND	STAIRWAY BY UNIT E-2	PASS
MINI SOUNDER	2ND	UNIT E-2 BEDROOM	PASS
MINI SOUNDER	2ND	UNIT A-32 BEDROOM	PASS
HORN/STROBE	3RD	STAIRWAY BY UNIT A-32	PASS
MINI SOUNDER	3RD	UNIT A-31 BEDROOM	PASS
MINI SOUNDER	3RD	UNIT C-32 BEDROOM	PASS
HORN/STROBE	3RD	STAIRWAY BY UNIT C-32	PASS
MINI SOUNDER	3RD	UNIT C-31 BEDROOM	PASS
HORN/STROBE	3RD	STAIRWAY BY UNIT E-3	PASS
MINI SOUNDER	3RD	UNIT E-3 BEDROOM	PASS