

**. . . Fire Protection by Computer Design**

Residential Fire Protection  
64 Daggett Hill Rd.  
Greene, ME 04236  
(207)946-343

Job Name : 223 CUMBERLAND AVE APT'S  
Building : WOOD STRUCTURE  
Location : 3RD FLOOR  
System : WET  
Contract : C16005  
Data File : 223 CUMBERLAND AVE APT-3RD FLR.WXF

Hydraulic Design Information Sheet

Name - 223 CUMBERLAND AVE APT'S Date - 2/29/16  
 Location - 3RD FLOOR  
 Building - WOOD STRUCTURE System No. - WET  
 Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - C16005  
 Calculated By - T. PRAY Drawing No. - 1 OF 2  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - 8'-2.5"  
 Occupancy - RESIDENTIAL

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 4 HD'S	System Type	Sprinkler/Nozzle
	Density	- .0508	(X) Wet	Make VIKING
D	Area Per Sprinkler	- 256	( ) Dry	Model VK468
E	Elevation at Highest Outlet	- 127.75	( ) Deluge	Size 7/16"
S	Hose Allowance - Inside	-	( ) Preaction	K-Factor 4.9
I	Rack Sprinkler Allowance	-	( ) Other	Temp.Rat.155
G	Hose Allowance - Outside	- 100		

N Note

Calculation Flow Required - 160.69 Press Required - 71.07 AT TEST  
 Summary C-Factor Used: 150 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 6/20/2012		Cap. -
T	Time of Test - N/A	Rated Cap.-	Elev.-
E	Static Press - 96	@ Press -	
R	Residual Press - 94	Elev. -	Well
S	Flow - 1352		Proof Flow
U	Elevation - 99.0'		

P Location - TEST HYDRANT LOCATED AT THE CORNER OF CUMBERLAND AVE AND WILMOT ST

P Source of Information - PORTLAND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T	( ) Mult. Row		( ) Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

E Horizontal Barriers Provided:


# Water Supply Curve (C)

Residential Fire Protection  
223 CUMBERLAND AVE APT'S

Page 2  
Date 2/25/16

City Water Supply:  
C1 - Static Pressure : 96  
C2 - Residual Pressure: 94  
C2 - Residual Flow : 1352

Demand:  
D1 - Elevation : 12.452  
D2 - System Flow : 60.693  
D2 - System Pressure : 71.069  
Hose ( Adj City ) : \_\_\_\_\_  
Hose ( Demand ) : 100  
D3 - System Demand : 160.693  
Safety Margin : 24.892



# Fittings Used Summary

Residential Fire Protection  
223 CUMBERLAND AVE APT'S

Page 3  
Date 2/25/16

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

# Pressure / Flow Summary - STANDARD

Residential Fire Protection  
223 CUMBERLAND AVE APT'S

Page 4  
Date 2/25/16

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DO01	0.0	4.9	7.04	na	13.0	0.0508	256	7.0
DO02	0.0	4.9	7.04	na	13.0	0.0508	256	7.0
10	127.75	K = K @ EQ01	7.47	na	13.0			
11	127.75	K = K @ EQ02	8.56	na	13.58			
12	127.75	K = K @ EQ01	11.43	na	16.09			
51	127.75		11.57	na				
52	127.75		12.48	na				
13	127.75	K = K @ EQ01	14.35	na	18.02			
53	126.5		17.3	na				
53A	126.5		18.41	na				
54	126.5		28.34	na				
55	108.0		41.95	na				
56	108.0		45.02	na				
38	97.67		54.66	na				
39	97.67		57.33	na				
40	97.67		60.0	na				
41	97.67		62.67	na				
42	97.67		65.97	na				
43	97.67		65.97	na				
61	97.75		65.93	na				
62	97.75		65.93	na				
TOR	97.75		66.17	na				
BOR	94.29		73.03	na				
TEST	99.0		71.07	na	100.0			

The maximum velocity is 20.45 and it occurs in the pipe between nodes 53A and 54

# Final Calculations - Hazen-Williams

Residential Fire Protection  
223 CUMBERLAND AVE APT'S

Page 5  
Date 2/25/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DO01 to EQ01	13.00 13.0	0.874 150 0.0946	1E	4.026 0.0	0.500 4.026 4.526	7.044 0.0			K Factor = 4.90	
	0.0 13.00						7.472		K Factor = 4.76	
DO02 to EQ02	13.00 13.0	0.874 150 0.0945	1T	8.053 0.0	0.500 8.052 8.552	7.044 0.0			K Factor = 4.90	
	0.0 13.00						7.852		K Factor = 4.64	
10 to 11	13.00 13.0	0.874 150 0.0944	1E	4.026 0.0	7.500 4.026 11.526	7.472 0.0			K Factor @ node EQ01	
							1.088		Vel = 6.95	
11 to 52	13.58 26.58	0.874 150 0.3547	1T	8.053 0.0	3.000 8.052 11.052	8.560 0.0			K Factor @ node EQ02	
	0.0 26.58						12.480		Vel = 14.21	
									K Factor = 7.52	
12 to 51	16.09 16.09	0.874 150 0.1400		0.0 0.0	1.000 0.0 1.000	11.435 0.0			K Factor @ node EQ01	
							0.140		Vel = 8.60	
51 to 52	0.0 16.09	0.874 150 0.1401		0.0 0.0	6.460 0.0 6.460	11.575 0.0			Vel = 8.60	
							0.905			
52 to 53	26.58 42.67	1.101 150 0.2764	2E	7.65 0.0	7.840 7.650 15.490	12.480 0.541			Vel = 14.38	
	0.0 42.67						17.303			
									K Factor = 10.26	
13 to 53A	18.02 18.02	0.874 150 0.1728	1E 1T	4.026 8.053	8.300 12.078 20.378	14.347 0.541			K Factor @ node EQ01	
	0.0 18.02						3.521		Vel = 9.64	
									K Factor = 4.20	
53 to 53A	42.67 42.67	1.101 150 0.2765		0.0 0.0	4.000 0.0 4.000	17.303 0.0			Vel = 14.38	
							1.106			
53A to 54	18.02 60.69	1.101 150 0.5305	1T 1E	9.563 3.825	5.340 13.387 18.727	18.409 0.0			Vel = 20.45	
	0.0 60.69						9.935			
54 to 55	0.0 60.69	1.394 150 0.1681	3E	14.285 0.0	19.000 14.285 33.285	28.344 8.012			Vel = 12.76	
							5.596			
55 to 56	0.0 60.69	1.394 150 0.1681	2E	9.523 0.0	8.740 9.523 18.263	41.952 0.0			Vel = 12.76	
							3.070			
56 to 38	0.0 60.69	1.38 120 0.2669	2E	6.0 0.0	13.370 6.000 19.370	45.022 4.474			Vel = 13.02	
							5.169			

# Final Calculations - Standard

Residential Fire Protection  
223 CUMBERLAND AVE APT'S

Page 6  
Date 2/25/16

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
38	0.0	1.38		0.0	10.000	54.665				
to		120		0.0	0.0	0.0				
39	60.69	0.2668		0.0	10.000	2.668		Vel = 13.02		
39	0.0	1.38		0.0	10.000	57.333				
to		120		0.0	0.0	0.0				
40	60.69	0.2669		0.0	10.000	2.669		Vel = 13.02		
40	0.0	1.38		0.0	10.000	60.002				
to		120		0.0	0.0	0.0				
41	60.69	0.2668		0.0	10.000	2.668		Vel = 13.02		
41	0.0	1.61	1E	4.0	14.170	62.670				
to		120	1T	8.0	12.000	-0.035				
62	60.69	0.1260		0.0	26.170	3.297		Vel = 9.56		
	0.0									
	60.69					65.932		K Factor = 7.47		
42	0.0	1.38		0.0	10.000	65.966				
to		120		0.0	0.0	0.0				
43	0.0	0.0		0.0	10.000	0.0		Vel = 0		
43	0.0	1.61	1E	4.0	14.330	65.966				
to		120	1T	8.0	12.000	-0.035				
61	0.0	0.0		0.0	26.330	0.001		Vel = 0		
61	0.0	2.635		0.0	1.080	65.932				
to		120		0.0	0.0	0.0				
62	0.0	0.0		0.0	1.080	0.0		Vel = 0		
62	60.69	2.635	1T	16.474	4.460	65.932				
to		120		0.0	16.474	0.0				
TOR	60.69	0.0114		0.0	20.934	0.239		Vel = 3.57		
TOR	0.0	2.635	2I	16.474	7.000	66.171				
to		120	1Z	8.237	24.711	6.499		* Fixed loss = 5		
BOR	60.69	0.0114		0.0	31.711	0.362		Vel = 3.57		
BOR	0.0	4.1	1E	14.534	30.000	73.032				
to		140	1G	2.907	46.508	-2.040				
TEST	60.69	0.0010	1T	29.067	76.508	0.077		Vel = 1.47		
	100.00							Qa = 100.00		
	160.69					71.069		K Factor = 19.06		