

(Revised)
STRUCTURAL ANALYSIS REPORT

For

ME 5040 (LTE 4C)
AWE-MUNJOY HILL
211 Cumberland Avenue
Portland, ME 04101

**Antennas Mounted on Building Façade and on Ballast Frames;
Equipment Room in Basement**



Prepared for:




Dated: July 29, 2015 (Rev.2)

April 24, 2015 (Rev.1)

January 21, 2015

Prepared by:



1600 Osgood Street Building 20 North, Suite 3090
North Andover, MA 01845
Phone: (978) 557-5553
www.hudsondesigngroupllc.com



SCOPE OF WORK:

Hudson Design Group LLC (HDG) has been authorized by AT&T to conduct a structural evaluation of the structure that will support the existing AT&T equipment located in the areas depicted in the latest HDG's construction drawings.

This report represents this office's findings, conclusions and recommendations' pertaining to the support of AT&T's proposed equipment.

An on-site visual survey of the above areas was performed by ProVertic on December 5, 2014. Attendees included Nick Bestor and Mark Gormley (ProVertic Field Technicians).

CONCLUSION SUMMARY:

Building plans prepared by Leasure, Tuttle, Lee dated 03/23/1967 were obtained for our use. A limited visual survey of the structure was completed in or near the areas of the proposed work.

Based on our evaluation, we have determined that the existing structure **IS CAPABLE** of supporting the proposed equipment loading with the following modifications:

- Add ballast to the existing Alpha and Beta sector frames. See the chart below for ballast requirements.

MINIMUM BALLAST REQUIREMENTS		
SIDE	A (Back)	B (Front)
NUMBER OF BLOCKS	32	19
SIZE OF BLOCKS	4"x8"X16" Solid	
WEIGHT OF BLOCKS	38 lbs./ ea.	
TOTAL BALLAST WEIGHT	1938 lbs.	

- Relocate the Alpha sector antenna frame at least 4 feet away from the parapets to meet the roof design loads provided in the building plans.



APPURTENACE/EQUIPMENT CONFIGURATION:

(2) HPA-65R-BUU-H6 Antennas (72"x14.8"x9" - Wt. = 56 lbs. /ea.) (Beta & Gamma sector)

(1) SBNH-1D6565C Antenna (96.4"x11.9"x7.1" – Wt. = 61 lbs.) (Alpha sector)

(3) A2 Module (16.4"x15.2"x3.4" – Wt. = 22 lbs. /ea.) (One per sector)

(6) RRH (RRUS-11) (19.69"x16.97"x7.17" – Wt. = 50.7 lbs. /ea.) (Two per sector)

(3) Surge Arrestors (Wt. = 32.8 lbs. /ea.) (One per sector)

(1) Power Plant (Wt. = 1900 lbs.)

(1) Battery Rack (Wt. = 2500 lbs.)

(6) 7750 Antennas (57"x11"x5" Wt. = 35 lbs. /ea.) (Two per Sector)

(2) AM-X-CD-16-65-00T-RET Antennas (72"x11.8"x5.9" Wt. = 48.5 lbs. /ea.) (Beta & Gamma sector)

(1) AM-X-CD-14-65-00T-RET Antenna (48"x11.8"x5.9" Wt. = 36.5 lbs.) (Alpha sector)

(3) 9E Surge Arrestors (Wt. = 43.5 lbs. /ea.) (One per sector)

(6) RRH (RRUS-11) (19.69"x16.97"x7.17" – Wt. = 50.7 lbs. /ea.) (Two per sector)



DESIGN CRITERIA:

1. International Building Code (IBC) 2009, and ASCE 7-05 (Minimum Design Loads for Buildings and Other Structures).

Wind Analysis:

Reference Wind Speed:	100 mph	(FIG 6-1C; ASCE 7-05)
Category:	B	(Section 6.5.6.3; ASCE 7-05)

Roof:

Ground Snow, P_g :	60 psf	(FIG 7-1; ASCE 7-05)
Importance Factor, I :	1.0	(Category II)
Exposure Factor, C_e :	1.0	(Exp. B- Partially Exposed)
Thermal Factor, C_t :	1.0	(Typical Structure)
Flat Roof Snow Load:	42 psf	($P_f=0.7 \cdot C_e \cdot C_t \cdot I \cdot P_g$)

2. EIA/TIA -222- G Structural Standards for Steel Antenna Towers and Antenna Supporting Structures

City/Town:	Portland
County:	Cumberland
Wind Load:	100 mph
Nominal Ice Thickness:	1 inch

3. Approximate height above grade to the center of the Antennas:

161'-6" +/- (Alpha & Beta)
155'-0" +/- (Gamma)



ANTENNA SUPPORT RECOMMENDATIONS:

- The new Alpha and Beta sector antennas are proposed to be mounted on new and existing pipe masts secured to the existing non-penetrating ballast frames located on the roof.
- The new Gamma sector antennas are proposed to be mounted on new and existing pipe masts secured to the existing building façade with epoxy anchors.

RRH SUPPORT RECOMMENDATIONS:

The new RRH's are proposed to be mounted on new non-penetrating ballast frames located on the roof. Install the new RRH frames at least 4 feet away from the parapets. See the chart below for ballast requirements.

MINIMUM BALLAST REQUIREMENTS	
NUMBER OF BLOCKS PER SIDE	2
TOTAL NUMBER OF BLOCKS	4
SIZE OF BLOCKS	4"x8"X16" Solid
WEIGHT OF BLOCKS	38 lbs./ ea.
TOTAL BALLAST WEIGHT	152 lbs.

EQUIPMENT SUPPORT RECOMMENDATIONS:

The new power plant and battery rack are proposed to be installed inside the AT&T equipment room located in the basement.



Limitations and assumptions:

1. Reference the latest HDG construction drawings for all the equipment locations details.
2. Mount all equipment per manufacturer's specifications.
3. All structural members and their connections are assumed to be in good condition and are free from defects with no deterioration to its member capacities.
4. All antennas, coax cables and waveguide cables are assumed to be properly installed and supported as per the manufacturer requirements.
5. HDG is not responsible for any modifications completed prior to and hereafter which HDG was not directly involved.
6. If field conditions differ from what is assumed in this report, then the engineer of record is to be notified as soon as possible.

FIELD PHOTOS:



Photo 1: Sample photo illustrating the existing Alpha sector antennas.



Photo 2: Sample photo illustrating the existing Beta sector antennas.



Photo 3: Sample photo illustrating the existing Gamma sector antennas.



Photo 4: Sample photo illustrating the existing Gamma sector RRH's.



**Alpha and Beta Sector
Antenna Calculations**

Date: 4-24-15

Project Name: AWE-MUNJOY HILL

Project Number: ME5040

Designed By: AA Checked By: MSC



2.6.5.2 Velocity Pressure Coeff:

$$K_z = 2.01 (z/z_g)^{2/\alpha}$$

z= 161.5 (ft)

z_g= 1200 (ft)

α= 7

ALPHA SECTOR ANTENNAS

K_z= 1.133

$$K_{zmin} \leq K_z \leq 2.01$$

Table 2-4

Exposure	Z _g	α	K _{zmin}	K _e
B	1200 ft	7	0.70	0.90
C	900 ft	9.5	0.85	1
D	700 ft	11.5	1.03	1.10

2.6.6.4 Topographic Factor:

Table 2-5

Topo. Category	K _t	f
2	0.43	1.25
3	0.53	2
4	0.72	1.5

$$K_{zt} = [1 + (K_e K_t / K_h)]^2$$

$$K_h = e^{(f \cdot z / H)}$$

K_{zt}= #DIV/0!

K_h= #DIV/0!

K_e= 0 (from Table 2-4)

K_t= 0 (from Table 2-5)

f= 0 (from Table 2-5)

z= 161.5

H= 0 (Ht. of the crest above surrounding terrain)

K_{zt}= 1.00

(If Category 1 then K_{zt}=1.0)

Category= 1

Date: 4-24-15

Project Name: AWE-MUNJOY HILL

Project Number: ME5040

Designed By: AA Checked By: MSC



2.6.7 Gust Effect Factors

2.6.7.1 Self Supporting Lattice Structures

Gh = 1.0 Latticed Structures > 600 ft

Gh = 0.85 Latticed Structures 450 ft or less

Gh = 0.85 + 0.15 [h/150 - 3.0] h= ht. of structure

h= 161.5 Gh= 0.5615

2.6.7.2 Guyed Masts

Gh= 0.85

2.6.7.3 Pole Structures

Gh= 1.1

2.6.7.4 Structures Supported on Other Structures

(Cantilevered tubular or latticed spines, pole, structures on buildings (ht. : width ratio > 5)

Gh= 1.35

Gh= 1.35

Date: 4-24-15
 Project Name: AWE-MUNJOY HILL
 Project Number: ME5040
 Designed By: AA Checked By: MSC



2.6.8 Design Ice Thickness:

$$t_{iz} = 2.0 * t_i * I * K_{iz} * (K_{zt})^{0.35}$$

$$t_{iz} = 2.34$$

$$t_i = 1$$

$$I = 1$$

$$K_{iz} = 1.17$$

$$K_{zt} = 1$$

$$K_{iz} = [z/33]^{0.10} \leq 1.4$$

$$K_{iz} = 1.17$$

Calculating the weight of ice, the cross-sectional area of ice shall be determined by:

$$A_{iz} = \pi * t_{iz} * (D_c + t_{iz})$$

$$D_c = 72 \text{ (in) Largest Dim of Member}$$

$$A_{iz} = 547.51$$

2.6.9 Design Wind Load:

$$F = q_z * G * h * (\text{EPA's})$$

$$q_z = 0.00256 * K_z * K_{zt} * K_d * V_{max}^2$$

$$q_z = 27.56$$

$$K_z = 1.133$$

$$K_{zt} = 1$$

$$K_d = 0.95$$

$$V_{max} = 100$$

Table 2-2

Structure Type	Wind Direction Probability Factor, Kd
Latticed structures with triangular, square or rectangular cross sections	0.85
Tubular pole structures, latticed structures with other cross sections, appurtenances.	0.95

Date: 4-24-15
 Project Name: AWE-MUNJOY HILL
 Project Number: ME5040
 Designed By: AA Checked By: MSC



Determine Cf:

If lattice Structure See Manual

If Tubular Pole Structure, Use Corrected Value from Table 2.7 Below

C mph.ft	Round	18 Sided	16 Sided	12 Sided	8 Sided
< 32 (Subcritical)	1.2	1.2	1.2	1.2	1.2
32 to 64 (Transitional)	$38.4/C^{1.0}$	$25.8/C^{0.885}$	$12.6/C^{0.678}$	$2.99/C^{0.263}$	1.2
> 64 (Supercritical)	0.6	0.65	0.75	1	1.2

$$C = (I * K_{zt} * K_z)^{0.5} * V * D$$

Dp = Outside Diameter or Out to Out: 0.2 feet

C= 21.29

Cf= 1.2

<u>Appurtenances</u>	<u>Height</u>	<u>Width</u>	<u>Depth</u>	<u>Flat Area</u>	<u>Force Per Appurtenance</u>
(E) Antenna	96.4	11.9	7.1	7.97	355.69 (lbs)
(E) Antenna	57	11	5	4.35	194.41 (lbs)
(E) Antenna	57	11	5	4.35	194.41 (lbs)
(P) Antenna	48	11.8	5.9	3.93	175.62 (lbs)
Item No.5	0	0	0	0.00	0.00 (lbs)

TOTAL FORCE (ΣF_A) =	920.14 (lbs)
--	---------------------

Date: 4-24-15

Project Name: AWE-MUNJOY HILL

Project Number: ME5040

Designed By: AA Checked By: MSC



2.6.5.2 Velocity Pressure Coeff:

$$K_z = 2.01 (z/z_g)^{2/\alpha}$$

z= 161.5 (ft)

BETA SECTOR ANTENNAS

z_g= 1200 (ft)

α= 7

K_z= 1.133

$$K_{zmin} \leq K_z \leq 2.01$$

Table 2-4

Exposure	Z _g	α	K _{zmin}	K _e
B	1200 ft	7	0.70	0.90
C	900 ft	9.5	0.85	1
D	700 ft	11.5	1.03	1.10

2.6.6.4 Topographic Factor:

Table 2-5

Topo. Category	K _t	f
2	0.43	1.25
3	0.53	2
4	0.72	1.5

$$K_{zt} = [1 + (K_e K_t / K_h)]^2$$

$$K_h = e^{(f \cdot z / H)}$$

K_{zt}= #DIV/0!

K_h= #DIV/0!

K_e= 0 (from Table 2-4)

K_t= 0 (from Table 2-5)

f= 0 (from Table 2-5)

z= 161.5

H= 0 (Ht. of the crest above surrounding terrain)

K_{zt}= 1.00

(If Category 1 then K_{zt}=1.0)

Category= 1

Date: 4-24-15

Project Name: AWE-MUNJOY HILL

Project Number: ME5040

Designed By: AA Checked By: MSC



2.6.7 Gust Effect Factors

2.6.7.1 Self Supporting Lattice Structures

Gh = 1.0 Latticed Structures > 600 ft

Gh = 0.85 Latticed Structures 450 ft or less

Gh = 0.85 + 0.15 [h/150 - 3.0] h= ht. of structure

h= 161.5 Gh= 0.5615

2.6.7.2 Guyed Masts Gh= 0.85

2.6.7.3 Pole Structures Gh= 1.1

2.6.7.4 Structures Supported on Other Structures
(Cantilevered tubular or latticed spines, pole, structures on buildings (ht. : width ratio > 5)

Gh= 1.35 Gh= 1.35

Date: 4-24-15
 Project Name: AWE-MUNJOY HILL
 Project Number: ME5040
 Designed By: AA Checked By: MSC



2.6.8 Design Ice Thickness:

$$t_{iz} = 2.0 * t_i * I * K_{iz} * (K_{zt})^{0.35}$$

$$t_i = 1$$

$$I = 1$$

$$K_{iz} = 1.17$$

$$K_{zt} = 1$$

$$t_{iz} = 2.34$$

$$K_{iz} = [z/33]^{0.10} \leq 1.4$$

$$K_{iz} = 1.17$$

Calculating the weight of ice, the cross-sectional area of ice shall be determined by:

$$A_{iz} = \pi * t_{iz} * (D_c + t_{iz})$$

$$D_c = 72 \text{ (in) Largest Dim of Member}$$

$$A_{iz} = 547.51$$

2.6.9 Design Wind Load:

$$F = q_z * G * h * (EPA's)$$

$$q_z = 0.00256 * K_z * K_{zt} * K_d * V_{max}^2$$

$$K_z = 1.133$$

$$K_{zt} = 1$$

$$K_d = 0.95$$

$$V_{max} = 100$$

$$q_z = 27.56$$

Table 2-2

Structure Type	Wind Direction Probability Factor, Kd
Latticed structures with triangular, square or rectangular cross sections	0.85
Tubular pole structures, latticed structures with other cross sections, appurtenances.	0.95

Date: 4-24-15
 Project Name: AWE-MUNJOY HILL
 Project Number: ME5040
 Designed By: AA Checked By: MSC



Determine Cf:

If lattice Structure See Manual

If Tubular Pole Structure, Use Corrected Value from Table 2.7 Below

C mph.ft	Round	18 Sided	16 Sided	12 Sided	8 Sided
< 32 (Subcritical)	1.2	1.2	1.2	1.2	1.2
32 to 64 (Transitional)	$38.4/C^{1.0}$	$25.8/C^{0.885}$	$12.6/C^{0.678}$	$2.99/C^{0.263}$	1.2
> 64 (Supercritical)	0.6	0.65	0.75	1	1.2

$$C = (I * K_{zt} * K_z)^{0.5} * V * D$$

Dp = Outside Diameter or Out to Out: 0.2 feet

C= 21.29 Cf= 1.2

Appurtenances	Height	Width	Depth	Flat Area	Force Per Appurtenance
(E) Antenna	57	11	5	4.35	194.41 (lbs)
(E) Antenna	57	11	5	4.35	194.41 (lbs)
(E) Antenna	72	11.8	5.9	5.90	263.43 (lbs)
(P) Antenna	72	14.8	9	7.40	330.41 (lbs)
Item No.5	0	0	0	0.00	0.00 (lbs)

TOTAL FORCE (ΣF_A) =	982.66 (lbs)
--	---------------------

Date: 4-24-15

Project Name: AWE-MUNJOY HILL

Project Number: ME5040

Designed By: AA Checked By: MSC



2.6.5.2 Velocity Pressure Coeff:

$$K_z = 2.01 (z/z_g)^{2/\alpha}$$

z = 157 (ft)

z_g = 1200 (ft)

α = 7

ALPHA & BETA SECTOR RRH

K_z = 1.124

$$K_{zmin} \leq K_z \leq 2.01$$

Table 2-4

Exposure	Z _g	α	K _{zmin}	K _e
B	1200 ft	7	0.70	0.90
C	900 ft	9.5	0.85	1
D	700 ft	11.5	1.03	1.10

2.6.6.4 Topographic Factor:

Table 2-5

Topo. Category	K _t	f
2	0.43	1.25
3	0.53	2
4	0.72	1.5

$$K_{zt} = [1 + (K_e K_t / K_h)]^2$$

$$K_h = e^{(fz/H)}$$

K_{zt} = #DIV/0!

K_h = #DIV/0!

K_e = 0 (from Table 2-4)

K_t = 0 (from Table 2-5)

f = 0 (from Table 2-5)

z = 157

H = 0 (Ht. of the crest above surrounding terrain)

K_{zt} = 1.00

(If Category 1 then K_{zt} = 1.0)

Category = 1

Date: 4-24-15
Project Name: AWE-MUNJOY HILL
Project Number: ME5040
Designed By: AA Checked By: MSC



2.6.7 Gust Effect Factors

2.6.7.1 Self Supporting Lattice Structures

Gh = 1.0 Latticed Structures > 600 ft

Gh = 0.85 Latticed Structures 450 ft or less

Gh = 0.85 + 0.15 [h/150 - 3.0] h= ht. of structure

h= 157 Gh= 0.557

2.6.7.2 Guyed Masts Gh= 0.85

2.6.7.3 Pole Structures Gh= 1.1

2.6.7.4 Structures Supported on Other Structures

(Cantilevered tubular or latticed spines, pole, structures on buildings (ht. : width ratio > 5)

Gh= 1.35 Gh= 1.35

Date: 4-24-15
 Project Name: AWE-MUNJOY HILL
 Project Number: ME5040
 Designed By: AA Checked By: MSC



2.6.8 Design Ice Thickness:

$$t_{iz} = 2.0 * t_i * I * K_{iz} * (K_{zt})^{0.35}$$

$$t_i = 1$$

$$I = 1$$

$$K_{iz} = 1.17$$

$$K_{zt} = 1$$

$$t_{iz} = 2.34$$

$$K_{iz} = [z/33]^{0.10} \leq 1.4$$

$$K_{iz} = 1.17$$

Calculating the weight of ice, the cross-sectional area of ice shall be determined by:

$$A_{iz} = \pi * t_{iz} * (D_c + t_{iz})$$

$$D_c = 20.4 \text{ (in) Largest Dim of Member}$$

$$A_{iz} = 166.98$$

2.6.9 Design Wind Load:

$$F = q_z * G * h * (EPA's)$$

$$q_z = 0.00256 * K_z * K_{zt} * K_d * V_{max}^2$$

$$K_z = 1.124$$

$$K_{zt} = 1$$

$$K_d = 0.95$$

$$V_{max} = 100$$

$$q_z = 27.34$$

Table 2-2

Structure Type	Wind Direction Probability Factor, Kd
Latticed structures with triangular, square or rectangular cross sections	0.85
Tubular pole structures, latticed structures with other cross sections, appurtenances.	0.95

Date: 4-24-15
 Project Name: AWE-MUNJOY HILL
 Project Number: ME5040
 Designed By: AA Checked By: MSC



Determine Cf:

If lattice Structure See Manual

If Tubular Pole Structure, Use Corrected Value from Table 2.7 Below

C mph.ft	Round	18 Sided	16 Sided	12 Sided	8 Sided
< 32 (Subcritical)	1.2	1.2	1.2	1.2	1.2
32 to 64 (Transitional)	$38.4/C^{1.0}$	$25.8/C^{0.885}$	$12.6/C^{0.678}$	$2.99/C^{0.263}$	1.2
> 64 (Supercritical)	0.6	0.65	0.75	1	1.2

$$C = (I * K_{zt} * K_z)^{0.5} * V * D$$

Dp = Outside Diameter or Out to Out: 0.2 feet

C= 21.21 Cf= 1.2

Appurtenances	Height	Width	Depth	Flat Area	Force Per Appurtenance
RRH-11	19.7	17	7.2	2.33	103.01 (lbs)
RRH-12	20.4	18.5	7.5	2.62	116.08 (lbs)
FIBER BOX	20	20	10	2.78	123.03 (lbs)
SURGE ARRESTOR	11.5	10.4	6.3	0.83	36.79 (lbs)
Item No.5	0	0	0	0.00	0.00 (lbs)

TOTAL FORCE (ΣF_A) =	378.90 (lbs)
--	---------------------



**Gamma Sector
Antenna Calculations**

Date: 4-24-15

Project Name: AWE-MUNJOY HILL

Project Number: ME5040

Designed By: AA Checked By: MSC



2.6.5.2 Velocity Pressure Coeff:

$$K_z = 2.01 (z/z_g)^{2/\alpha}$$

z= 155 (ft)

GAMMA SECTOR ANTENNAS

z_g= 1200 (ft)

α= 7

K_z= 1.120

$$K_{zmin} \leq K_z \leq 2.01$$

Table 2-4

Exposure	Z _g	α	K _{zmin}	K _e
B	1200 ft	7	0.70	0.90
C	900 ft	9.5	0.85	1
D	700 ft	11.5	1.03	1.10

2.6.6.4 Topographic Factor:

Table 2-5

Topo. Category	K _t	f
2	0.43	1.25
3	0.53	2
4	0.72	1.5

$$K_{zt} = [1 + (K_e K_t / K_h)]^2$$

$$K_h = e^{(f \cdot z / H)}$$

K_{zt}= #DIV/0!

K_h= #DIV/0!

K_e= 0 (from Table 2-4)

K_t= 0 (from Table 2-5)

f= 0 (from Table 2-5)

z= 155

H= 0 (Ht. of the crest above surrounding terrain)

K_{zt}= 1.00

(If Category 1 then K_{zt} = 1.0)

Category= 1

Date: 4-24-15
Project Name: AWE-MUNJOY HILL
Project Number: ME5040
Designed By: AA Checked By: MSC



2.6.7 Gust Effect Factors

2.6.7.1 Self Supporting Lattice Structures

Gh = 1.0 Latticed Structures > 600 ft

Gh = 0.85 Latticed Structures 450 ft or less

Gh = 0.85 + 0.15 [h/150 - 3.0] h= ht. of structure

h= 155

Gh= 0.555

2.6.7.2 Guyed Masts

Gh= 0.85

2.6.7.3 Pole Structures

Gh= 1.1

2.6.7.4 Structures Supported on Other Structures

(Cantilevered tubular or latticed spines, pole, structures on buildings (ht. : width ratio > 5)

Gh= 1.35

Gh= 1.35

Date: 4-24-15
 Project Name: AWE-MUNJOY HILL
 Project Number: ME5040
 Designed By: AA Checked By: MSC



2.6.8 Design Ice Thickness:

$$t_{iz} = 2.0 * t_i * I * K_{iz} * (K_{zt})^{0.35}$$

$t_{iz} = 2.33$

$t_i = 1$

$I = 1$

$K_{iz} = 1.17$

$K_{zt} = 1$

$$K_{iz} = [z/33]^{0.10} \leq 1.4$$

$K_{iz} = 1.17$

Calculating the weight of ice, the cross-sectional area of ice shall be determined by:

$$A_{iz} = \pi * t_{iz} * (D_c + t_{iz})$$

$D_c = 48$ (in) Largest Dim of Member

$A_{iz} = 369.17$

2.6.9 Design Wind Load:

$$F = qz * Gh * (EPA's)$$

$$q_z = 0.00256 * K_z * K_{zt} * K_d * V_{max}^2$$

$q_z = 27.24$

$K_z = 1.120$

$K_{zt} = 1$

$K_d = 0.95$

$V_{max} = 100$

Table 2-2

Structure Type	Wind Direction Probability Factor, K_d
Latticed structures with triangular, square or rectangular cross sections	0.85
Tubular pole structures, latticed structures with other cross sections, appurtenances.	0.95

Date: 4-24-15

Project Name: AWE-MUNJOY HILL

Project Number: ME5040

Designed By: AA Checked By: MSC



Determine Cf:

If lattice Structure See Manual

If Tubular Pole Structure, Use Corrected Value from Table 2.7 Below

C mph.ft	Round	18 Sided	16 Sided	12 Sided	8 Sided
< 32 (Subcritical)	1.2	1.2	1.2	1.2	1.2
32 to 64 (Transitional)	$38.4/C^{1.0}$	$25.8/C^{0.885}$	$12.6/C^{0.678}$	$2.99/C^{0.263}$	1.2
> 64 (Supercritical)	0.6	0.65	0.75	1	1.2

$$C = (I * K_{zt} * K_z)^{0.5} * V * D$$

Dp = Outside Diameter or Out to Out: 0.2 feet

C= 21.17

Cf= 1.2

Appurtenances	Height	Width	Depth	Flat Area	Force Per Appurtenance
(E) Antenna	57	11	5	4.35	192.14 (lbs)
(E) Antenna	57	11	5	4.35	192.14 (lbs)
(E) Antenna	48	11.8	5.9	3.93	173.57 (lbs)
(P) Antenna	48	14.8	9	4.93	217.70 (lbs)
Item No.5	0	0	0	0.00	0.00 (lbs)

TOTAL FORCE (ΣF_A) =	775.56 (lbs)
--	---------------------

ICE WEIGHT CALCULATIONS

Project: ME5040

Thickness of ice: 1

Weight of ice based on total radial SF area:

Antenna

Depth (in): 9

height (in): 48

Width (in): 14.9

Total weight of ice on object: 74 pounds ice

Weight of object: 34 pounds

Combined weight of ice and object: 108 pounds

Per foot weight of ice:

Pipe

pipe weight per foot: 3.65

pipe length (ft): 5

diameter (in): 2.375

Per foot weight of ice on object: 3 pounds ice /ft

Total weight of ice on object: 15 pounds

Total weight of pipe: 18.25 pounds

Combined weight of pipe and ice: 33 pounds

* Density of ice used = 56 PCF

Total Weight: 141 pounds

Site Name: AWE-MUNJOY HILL
Site No. ME5040
Done by: AA **Checked by:** MSC
Date: 4/24/2015



CHECK CONNECTION CAPACITY

Reference: Hilti Volume 2: Anchor Fastening Technical Guide

Epoxy Type = HIT-HY20
Anchor Diameter = 3/8 in. (Assumed)
Min. Embedment Depth = 2 in. (Assumed)

Allowable Tensile Load =
 $F_{Tall} =$ 525 lbs.

Allowable Shear Load =
 $F_{Vall} =$ 790 lbs.

WIND FORCES

Reaction $F =$ 220 lbs.

GRAVITY LOADS

Ice and Equipment 141 lbs.

No. of Supports = 2
No. of Anchors / Support = 2

Tension Design Load / Anchor =
 $f_t =$ 55.00 lbs. < 525 lbs. **Therefore, OK !**

Shear Design Load / Anchor =
 $f_v =$ 35.25 lbs. < 790 lbs. **Therefore, OK !**

CHECK COMBINED TENSION AND SHEAR

$$\begin{array}{rclclcl}
 f_t / F_T & + & f_v / F_V & \leq & 1.0 & \\
 0.105 & + & 0.045 & = & 0.149 & < & 1.0 & \text{Therefore, OK !}
 \end{array}$$



RRH Frame Calculations

Date: 4-24-15

Project Name: AWE-MUNJOY HILL

Project Number: ME5040

Designed By: AA Checked By: MSC



2.6.5.2 Velocity Pressure Coeff:

$$K_z = 2.01 (z/z_g)^{2/\alpha}$$

z= 157 (ft)

RRH FRAME

z_g= 1200 (ft)

K_z= 1.124

α= 7

$$K_{zmin} \leq K_z \leq 2.01$$

Table 2-4

Exposure	Z _g	α	K _{zmin}	K _e
B	1200 ft	7	0.70	0.90
C	900 ft	9.5	0.85	1
D	700 ft	11.5	1.03	1.10

2.6.6.4 Topographic Factor:

Table 2-5

Topo. Category	K _t	f
2	0.43	1.25
3	0.53	2
4	0.72	1.5

$$K_{zt} = [1 + (K_e K_t / K_h)]^2$$

$$K_h = e^{(f \cdot z / H)}$$

K_{zt}= #DIV/0!

K_h= #DIV/0!

K_e= 0 (from Table 2-4)

(If Category 1 then K_{zt}=1.0)

K_t= 0 (from Table 2-5)

f= 0 (from Table 2-5)

Category= 1

z= 157

H= 0 (Ht. of the crest above surrounding terrain)

K_{zt}= 1.00

Date: 4-24-15
Project Name: AWE-MUNJOY HILL
Project Number: ME5040
Designed By: AA Checked By: MSC



2.6.7 Gust Effect Factors

2.6.7.1 Self Supporting Lattice Structures

Gh = 1.0 Latticed Structures > 600 ft

Gh = 0.85 Latticed Structures 450 ft or less

Gh = 0.85 + 0.15 [h/150 - 3.0] h= ht. of structure

h= 157 Gh= 0.557

2.6.7.2 Guyed Masts Gh= 0.85

2.6.7.3 Pole Structures Gh= 1.1

2.6.7.4 Structures Supported on Other Structures

(Cantilevered tubular or latticed spines, pole, structures on buildings (ht. : width ratio > 5)

Gh= 1.35 Gh= 1.35

Date: 4-24-15
 Project Name: AWE-MUNJOY HILL
 Project Number: ME5040
 Designed By: AA Checked By: MSC



2.6.8 Design Ice Thickness:

$$t_{iz} = 2.0 * t_i * I * K_{iz} * (K_{zt})^{0.35}$$

t_{iz} = 2.34

t_i = 1

I = 1

K_{iz} = 1.17

K_{zt} = 1

$$K_{iz} = [z/33]^{0.10} \leq 1.4$$

K_{iz} = 1.17

Calculating the weight of ice, the cross-sectional area of ice shall be determined by:

$$A_{iz} = \pi * t_{iz} * (D_c + t_{iz})$$

D_c = 20.4 (in) Largest Dim of Member

A_{iz} = 166.98

2.6.9 Design Wind Load:

$$F = q_z * Gh * (EPA's)$$

$$q_z = 0.00256 * K_z * K_{zt} * K_d * V_{max}^2$$

q_z = 27.34

K_z = 1.124

K_{zt} = 1

K_d = 0.95

V_{max} = 100

Table 2-2

Structure Type	Wind Direction Probability Factor, K _d
Latticed structures with triangular, square or rectangular cross sections	0.85
Tubular pole structures, latticed structures with other cross sections, appurtenances.	0.95

Date: 4-24-15
 Project Name: AWE-MUNJOY HILL
 Project Number: ME5040
 Designed By: AA Checked By: MSC



Determine Cf:

If lattice Structure See Manual

If Tubular Pole Structure, Use Corrected Value from Table 2.7 Below

C mph.ft	Round	18 Sided	16 Sided	12 Sided	8 Sided
< 32 (Subcritical)	1.2	1.2	1.2	1.2	1.2
32 to 64 (Transitional)	$38.4/C^{1.0}$	$25.8/C^{0.885}$	$12.6/C^{0.678}$	$2.99/C^{0.263}$	1.2
> 64 (Supercritical)	0.6	0.65	0.75	1	1.2

$$C = (I * K_{zt} * K_r)^{0.5} * V * D$$

Dp = Outside Diameter or Out to Out: 0.2 feet

C= 21.21

Cf= 1.2

<u>Appurtenances</u>	<u>Height</u>	<u>Width</u>	<u>Depth</u>	<u>Flat Area</u>	<u>Force Per Appurtenance</u>
RRH-11	19.7	17	7.2	2.33	103.01 (lbs)

Site Name: AWE-MUNJOY HILL

Site No.: ME5040

Done by: AA

Checked by: MSC

Date: 4/24/2015



Calculate Total Ballast Required for Ballast Mount

Assume (2) RRH's as projected area

Force (F) = 207 lbs.


Height (H) = 3 ft

Weight (W) = 350 lbs.

Frame Width/2 (X) = 1.5 ft

Length (L) = 2.2 ft

Ballast (Wb) = TBD



Overturning at Ballast

$\Sigma M = 0 = (F * H) - (W * X) - (Wb * L) \text{ ---> } Wb = [(F*H-W*X)/L]*SF = 44 \text{ lbs.}$

Determine Number of Blocks Required

(assume 4"x8"x16" solid blocks @ 38 lbs. each)

Number of Blocks Required = **2 BLOCKS PER SIDE**

-Total Weight of Fully Loaded Frame = 502 lbs.

-Footprint Area Under Ballast Frame = 10.5 sqft.

-Distributed Load Under Ballast Frame = 48 psf



Roof Calculations

Date: 04-24-2015

Project Name: AWE-MUNJOY HILL

Project Number: ME5040


Designed By: AA Checked By: MSC



Calculate Drift Snow:

Ground Snow Load, P_g	60 psf
Calculated Flat Roof Snow:	42 psf
Minimum Roof/Parapet Length, L_u	25 ft.
Snow Density, Y	21.8 pcf
Height of Parapet, h	3.5 ft.
Balance Snow Height, h_b	1.93 ft.
Clear Ht. from top of balanced snow load to parapet, h_c	1.57 ft.
$h_c/h_b > 0.2$	0.82 Therefore, design for drift
Height of Snow Drift, h_d	1.5 Figure 7-9 (ASCE 7-05)
Width of snow drift, w	6 ft.

Surcharge load, p_d **32.7 psf**



Date: 04-24-2015

Project Name: AWE-MUNJOY HILL

Project Number: ME5040

Designed By: AA Checked By: MSC



Check Roof Capacity:

Reference: _____ • Building Plans by Leasure, Tuttle, Lee dated 03/23/1967.

Roof Design LL: 100 psf

Calculated Flat Roof Snow: 42 psf

Calculated Drift Snow: 32.7 psf

Net Available Load: 25.3 psf

Antenna Ballast Frame Load: 48 psf > 25.3 PSF **N.G!**

HGD recommends relocating the existing Alpha sector ballasted frame at least 4 ft. away from the parapets to meet the roof design loads provided in the building plans.

GENERAL NOTES

1. ROOF DESIGN LL = $50^{\circ}/\text{FT}^2$ + DRIPPING LL = $100^{\circ}/\text{FT}^2$
FLOOR DESIGN LL = $50^{\circ}/\text{FT}^2$ + PARTITION DL = $20^{\circ}/\text{FT}^2$
2. ALLOWABLE SOIL PRESSURE = 2000 PSF
3. CONCRETE TO BE 3000 PSI W/ GRADE TO REINFORCING.
4. MASONRY WALLS TO HAVE DUR-O-WALL REINFORCING @ EVERY 16" O.C.
5. STEEL TO BE A36 EXCEPT TUBE TO BE A500 GRADE B - 46 KSI, DETAIL, FABRICATED, AND ERECT PER AISC STANDARDS AND SPECIFICATIONS.
6. JOIST TO BE DETAIL FABRICATED AND ERECT PER SOI STANDARDS AND SPECIFICATIONS.
7. ROOF DECK TO BE 1/2" X 22 GA. TYPE B GALVANIZED, FLOOR DECK TO BE 1/4" X 22 GA. UNIFORM UPS GALV.
8. ALL LINTELS & BEAMS TO BEAR 6" MIN ON TO WALLS, FILL ONE BLOCK BELOW THE LINTEL & BEAMS W/ GROUT.
9. # INDICATES JOIST W/ BOLTED CONNECTIONS.
10. 19.0' INDICATES BOTTOM OF FOOTING ELEV. (100.0') INDICATES TOP OF WALL ELEV.

PHN PROJECT

ST

Notes:
 1. The design is based on the data provided in the program.
 2. The design is based on the data provided in the program.
 3. The design is based on the data provided in the program.



Structural Design & Construction Details



Item	Description	Quantity	Unit	Notes
1	Concrete	100	cu yd	
2	Reinforcing Steel	100	lb	
3	Formwork	100	sq ft	
4	Bricks	100	1000	
5	Mortar	100	cu yd	
6	Paint	100	gal	
7	Plaster	100	cu yd	
8	Insulation	100	sq ft	
9	Roofing	100	sq ft	
10	Windows	100	unit	
11	Doors	100	unit	
12	Lighting	100	unit	
13	Electrical	100	unit	
14	Plumbing	100	unit	
15	HVAC	100	unit	
16	Landscaping	100	unit	
17	Site Work	100	unit	
18	Foundation	100	unit	
19	Structural Steel	100	lb	
20	Welding	100	unit	
21	Paint	100	gal	
22	Plaster	100	cu yd	
23	Insulation	100	sq ft	
24	Roofing	100	sq ft	
25	Windows	100	unit	
26	Doors	100	unit	
27	Lighting	100	unit	
28	Electrical	100	unit	
29	Plumbing	100	unit	
30	HVAC	100	unit	
31	Landscaping	100	unit	
32	Site Work	100	unit	
33	Foundation	100	unit	
34	Structural Steel	100	lb	
35	Welding	100	unit	
36	Paint	100	gal	
37	Plaster	100	cu yd	
38	Insulation	100	sq ft	
39	Roofing	100	sq ft	
40	Windows	100	unit	
41	Doors	100	unit	
42	Lighting	100	unit	
43	Electrical	100	unit	
44	Plumbing	100	unit	
45	HVAC	100	unit	
46	Landscaping	100	unit	
47	Site Work	100	unit	
48	Foundation	100	unit	
49	Structural Steel	100	lb	
50	Welding	100	unit	
51	Paint	100	gal	
52	Plaster	100	cu yd	
53	Insulation	100	sq ft	
54	Roofing	100	sq ft	
55	Windows	100	unit	
56	Doors	100	unit	
57	Lighting	100	unit	
58	Electrical	100	unit	
59	Plumbing	100	unit	
60	HVAC	100	unit	
61	Landscaping	100	unit	
62	Site Work	100	unit	
63	Foundation	100	unit	
64	Structural Steel	100	lb	
65	Welding	100	unit	
66	Paint	100	gal	
67	Plaster	100	cu yd	
68	Insulation	100	sq ft	
69	Roofing	100	sq ft	
70	Windows	100	unit	
71	Doors	100	unit	
72	Lighting	100	unit	
73	Electrical	100	unit	
74	Plumbing	100	unit	
75	HVAC	100	unit	
76	Landscaping	100	unit	
77	Site Work	100	unit	
78	Foundation	100	unit	
79	Structural Steel	100	lb	
80	Welding	100	unit	
81	Paint	100	gal	
82	Plaster	100	cu yd	
83	Insulation	100	sq ft	
84	Roofing	100	sq ft	
85	Windows	100	unit	
86	Doors	100	unit	
87	Lighting	100	unit	
88	Electrical	100	unit	
89	Plumbing	100	unit	
90	HVAC	100	unit	
91	Landscaping	100	unit	
92	Site Work	100	unit	
93	Foundation	100	unit	
94	Structural Steel	100	lb	
95	Welding	100	unit	
96	Paint	100	gal	
97	Plaster	100	cu yd	
98	Insulation	100	sq ft	
99	Roofing	100	sq ft	
100	Windows	100	unit	