

# STRUCTURAL ANALYSIS REPORT

For

## ME5040 (LTE 5C)

MUNJOY HILL

211 Cumberland Avenue  
Portland, ME 04101

**Antennas Mounted on Building Façade and on Ballast Frames;  
Equipment Room in Basement**




Prepared for:



Dated: February 12, 2016

Prepared by:



1600 Osgood Street Building 20 North, Suite 3090  
North Andover, MA 01845  
Phone: (978) 557-5553  
[www.hudsondesigngroupllc.com](http://www.hudsondesigngroupllc.com)



**SCOPE OF WORK:**

Hudson Design Group LLC (HDG) has been authorized by AT&T to conduct a structural evaluation of the structure that will support the existing AT&T equipment located in the areas depicted in the latest HDG's construction drawings.

This report represents this office's findings, conclusions and recommendations pertaining to the support of AT&T's proposed equipment.

This office conducted an on-site visual survey of the above areas on January 27, 2016. Attendees included Manuel Tejada (HDG – Field Technician).

**CONCLUSION SUMMARY:**

Building plans prepared by Leasure, Tuttle, Lee dated 03/23/1967 were obtained for our use. A limited visual survey of the structure was completed in or near the areas of the proposed work.

Based on our evaluation, we have determined that the existing structure **IS CAPABLE** of supporting the proposed equipment loading with the following modifications:

- Add ballast to the existing Alpha and Beta sector frames. See the chart below for ballast requirements.

<b>MINIMUM BALLAST REQUIREMENTS</b>		
SIDE	A (Back)	B (Front)
NUMBER OF BLOCKS	34	20
SIZE OF BLOCKS	4"x8"X16" Solid	
WEIGHT OF BLOCKS	38 lbs./ ea.	
TOTAL BALLAST WEIGHT	2052 lbs.	

HDG did not perform a condition assessment of the structure. All structural members and their connections are assumed to be in good condition and are free from defects with no deterioration to its member capacities.



**APPURTENANCE/EQUIPMENT CONFIGURATION:**

**(3) QS66512-3 Antennas (72"x12"x9.6" - Wt. = 48 lbs. /ea.) (One per sector)**

**(6) RRH (RRUS-32) (26.7"x12.1"x6.7") (Wt. = 77 lbs. /each) (Two per sector)**

**(6) Triplexers (5.83"x9.65"x2.05" - Wt. = 7.5 lbs. /ea.) (Two per sector)**

(3) 7750 Antennas (57"x11"x5" Wt. = 35 lbs. /ea.) (One per Sector)

(2) HPA-65R-BUU-H6 Antennas (72"x14.8"x9" - Wt. = 56 lbs. /ea.) (Alpha & Gamma sector)

(1) SBNH-1D6565C Antenna (96.4"x11.9"x7.1" - Wt. = 61 lbs.) (Beta sector)

(2) AM-X-CD-16-65-00T-RET Antennas (72"x11.8"x5.9" Wt. = 48.5 lbs. /ea.) (Alpha & Gamma sector)

(1) AM-X-CD-14-65-00T-RET Antenna (48"x11.8"x5.9" Wt. = 36.5 lbs.) (Beta sector)

(3) A2 Module (16.4"x15.2"x3.4" - Wt. = 22 lbs. /ea.) (One per sector)

(9) RRH (RRUS-11) (19.69"x16.97"x7.17" - Wt. = 50.7 lbs. /ea.) (Three per sector)

(3) Surge Arrestors (Wt. = 32.8 lbs. /ea.) (One per sector)

(3) 9E Surge Arrestors (Wt. = 43.5 lbs. /ea.) (One per sector)

(6) Powerwave LGP21401 TMAs (14.4"x9.0"x2.7" - Wt. = 19 lbs. /ea.) (Two per sector)

**\*Proposed loading shown in bold.**



**DESIGN CRITERIA:**

1. International Building Code (IBC) 2009, and ASCE 7-05 (Minimum Design Loads for Buildings and Other Structures).

Wind Analysis:

Reference Wind Speed:	100 mph	(FIG 6-1C; ASCE 7-05)
Category:	B	(Section 6.5.6.3; ASCE 7-05)

Roof:

Ground Snow, $P_g$ :	60 psf	(FIG 7-1; ASCE 7-05)
Importance Factor, $I$ :	1.0	(Category II)
Exposure Factor, $C_e$ :	1.0	(Exp. B- Partially Exposed)
Thermal Factor, $C_t$ :	1.0	(Typical Structure)
<b>Flat Roof Snow Load:</b>	<b>42 psf</b>	<b>(<math>P_f=0.7 \cdot C_e \cdot C_t \cdot P_g</math>)</b>

2. EIA/TIA -222- G Structural Standards for Steel Antenna Towers and Antenna Supporting Structures

City/Town:	Portland
County:	Cumberland
Wind Load:	100 mph
Nominal Ice Thickness:	1 inch

3. Approximate height above grade to the center of the Antennas:

160'-0" +/- (Alpha & Beta)
155'-0" +/- (Gamma)



### **ANTENNA SUPPORT RECOMMENDATIONS:**

- The new Alpha and Beta sector antennas are proposed to be mounted on existing pipe masts secured to the existing non-penetrating ballast frames located on the roof.
- The new Gamma sector antennas are proposed to be mounted on the existing pipe mast secured to the existing building façade with epoxy anchors.

### **RRH SUPPORT RECOMMENDATIONS:**

The new RRH's are proposed to be mounted on the existing non-penetrating ballast frames located on the roof.

#### Limitations and assumptions:

1. Reference the latest HDG construction drawings for all the equipment locations details.
2. Mount all equipment per manufacturer's specifications.
3. All structural members and their connections are assumed to be in good condition and are free from defects with no deterioration to its member capacities.
4. All antennas, coax cables and waveguide cables are assumed to be properly installed and supported as per the manufacturer requirements.
5. HDG is not responsible for any modifications completed prior to and hereafter which HDG was not directly involved.
6. If field conditions differ from what is assumed in this report, then the engineer of record is to be notified as soon as possible.
7. A condition assessment of the existing structure was not part of the scope of work.



**FIELD PHOTOS:**



**Photo 1:** Sample photo illustrating the existing Alpha sector antennas.



**Photo 2:** Sample photo illustrating the existing Beta sector antennas.



**Photo 3:** Sample photo illustrating the existing Gamma sector antennas.



**Photo 4:** Sample photo illustrating the existing Gamma sector RRH's.



**Alpha & Beta Sector  
Antenna Calculations**



Date: 02-12-16

Project Name: MUNJOY HILL

Project Number: ME5040

Designed By: AA      Checked By: MSC



**2.6.5.2 Velocity Pressure Coeff:**

$$K_z = 2.01 (z/z_g)^{2/\alpha}$$

z= 160 (ft)

ALPHA SECTOR ANTENNAS

z<sub>g</sub>= 1200 (ft)

K<sub>z</sub>= 1.130

α= 7

$$K_{zmin} \leq K_z \leq 2.01$$

Table 2-4

Exposure	Z <sub>g</sub>	α	K <sub>zmin</sub>	K <sub>e</sub>
B	1200 ft	7	0.70	0.90
C	900 ft	9.5	0.85	1
D	700 ft	11.5	1.03	1.10

**2.6.6.4 Topographic Factor:**

Table 2-5

Topo. Category	K <sub>t</sub>	f
2	0.43	1.25
3	0.53	2
4	0.72	1.5

$$K_{zt} = [1 + (K_e K_t / K_h)]^2$$

$$K_h = e^{(f \cdot z / H)}$$

K<sub>zt</sub>= #DIV/0!

K<sub>h</sub>= #DIV/0!

K<sub>e</sub>= 0 (from Table 2-4)

K<sub>t</sub>= 0 (from Table 2-5)

f= 0 (from Table 2-5)

z= 160

H= 0 (Ht. of the crest above surrounding terrain)

K<sub>zt</sub>= 1.00

(If Category 1 then K<sub>zt</sub>=1.0)

Category= 1

Date: 02-12-16  
Project Name: MUNJOY HILL  
Project Number: ME5040  
Designed By: AA      Checked By: MSC



**2.6.7 Gust Effect Factors**

**2.6.7.1 Self Supporting Lattice Structures**

Gh = 1.0 Latticed Structures > 600 ft

Gh = 0.85 Latticed Structures 450 ft or less

Gh = 0.85 + 0.15 [h/150 - 3.0]      h= ht. of structure

h=      154      Gh=      0.554

**2.6.7.2 Guyed Masts**

Gh=      0.85

**2.6.7.3 Pole Structures**

Gh=      1.1

**2.6.7.4 Structures Supported on Other Structures**

*(Cantilevered tubular or latticed spines, pole, structures on buildings (ht. : width ratio > 5)*

Gh=      1.35      Gh=      1.35

Date: 02-12-16

Project Name: MUNJOY HILL

Project Number: ME5040

Designed By: AA Checked By: MSC



**2.6.8 Design Ice Thickness:**

$$t_{iz} = 2.0 * t_i * I * K_{iz} * (K_{zt})^{0.35}$$

$$t_i = 1$$

$$I = 1$$

$$K_{iz} = 1.17$$

$$K_{zt} = 1$$

$$t_{iz} = 2.34$$

$$K_{iz} = [z/33]^{0.10} \leq 1.4$$

$$K_{iz} = 1.17$$

Calculating the weight of ice, the cross-sectional area of ice shall be determined by:

$$A_{iz} = \pi * t_{iz} * (D_c + t_{iz})$$

$$D_c = 72 \text{ (in) Largest Dim of Member}$$

$$A_{iz} = 546.98$$

**2.6.9 Design Wind Load:**

$$F = q_z * G * h * (EPA's)$$

$$q_z = 0.00256 * K_z * K_{zt} * K_d * V_{max}^2$$

$$K_z = 1.130$$

$$K_{zt} = 1$$

$$K_d = 0.95$$

$$V_{max} = 100$$

$$q_z = 27.49$$

Table 2-2

Structure Type	Wind Direction Probability Factor, Kd
Latticed structures with triangular, square or rectangular cross sections	0.85
Tubular pole structures, latticed structures with other cross sections, appurtenances.	0.95

Date: 02-12-16

Project Name: MUNJOY HILL

Project Number: ME5040

Designed By: AA      Checked By: MSC



**Determine Cf:**

If lattice Structure See Manual

If Tubular Pole Structure, Use Corrected Value from Table 2.7 Below

C mph.ft	Round	18 Sided	16 Sided	12 Sided	8 Sided
< 32 (Subcritical)	1.2	1.2	1.2	1.2	1.2
32 to 64 (Transitional)	$38.4/C^{1.0}$	$25.8/C^{0.885}$	$12.6/C^{0.678}$	$2.99/C^{0.263}$	1.2
> 64 (Supercritical)	0.6	0.65	0.75	1	1.2

$$C = (I * K_{zt} * K_r)^{0.5} * V * D$$

Dp = Outside Diameter or Out to Out:      0.2      feet

**C= 21.26**

**Cf= 1.2**

<u>Appurtenances</u>	<u>Height</u>	<u>Width</u>	<u>Depth</u>	<u>Flat Area</u>	<u>Force Per Appurtenance</u>
(E) Antenna	57	11	5	4.35	<b>193.89 (lbs)</b>
(E) Antenna	72	14.8	9	7.40	<b>329.53 (lbs)</b>
(E) Antenna	72	11.8	5.9	5.90	<b>262.73 (lbs)</b>
(P) Antenna	72	12	9.6	6.00	<b>267.18 (lbs)</b>



Date: 02-12-16

Project Name: MUNJOY HILL

Project Number: ME5040

Designed By: AA      Checked By: MSC



**2.6.5.2 Velocity Pressure Coeff:**

$$K_z = 2.01 (z/z_g)^{2/\alpha}$$

z = 160 (ft)

z<sub>g</sub> = 1200 (ft)

α = 7

**K<sub>z</sub> = 1.130**

**BETA SECTOR ANTENNAS**

$$K_{zmin} \leq K_z \leq 2.01$$

**Table 2-4**

Exposure	Z <sub>g</sub>	α	K <sub>zmin</sub>	K <sub>e</sub>
B	1200 ft	7	0.70	0.90
C	900 ft	9.5	0.85	1
D	700 ft	11.5	1.03	1.10

**2.6.6.4 Topographic Factor:**

**Table 2-5**

Topo. Category	K <sub>t</sub>	f
2	0.43	1.25
3	0.53	2
4	0.72	1.5

$$K_{zt} = [1 + (K_e K_t / K_h)]^2$$

$$K_h = e^{-(f+z/H)}$$

**K<sub>zt</sub> = #DIV/0!**

K<sub>h</sub> = #DIV/0!

K<sub>e</sub> = 0 (from Table 2-4)

K<sub>t</sub> = 0 (from Table 2-5)

f = 0 (from Table 2-5)

z = 160

H = 0 (Ht. of the crest above surrounding terrain)

K<sub>zt</sub> = 1.00

(If Category 1 then K<sub>zt</sub> = 1.0)

**Category = 1**

Date: 02-12-16

Project Name: MUNJOY HILL

Project Number: ME5040

Designed By: AA      Checked By: MSC



**2.6.7 Gust Effect Factors**

**2.6.7.1 Self Supporting Lattice Structures**

Gh = 1.0 Latticed Structures > 600 ft

Gh = 0.85 Latticed Structures 450 ft or less

Gh = 0.85 + 0.15 [h/150 - 3.0]      h= ht. of structure

h=      154      Gh=      0.554

**2.6.7.2 Guyed Masts**      Gh=      0.85

**2.6.7.3 Pole Structures**      Gh=      1.1

**2.6.7.4 Structures Supported on Other Structures**

*(Cantilevered tubular or latticed spines, pole, structures on buildings (ht. : width ratio > 5)*

Gh=      1.35      Gh=      1.35

Date: 02-12-16

Project Name: MUNJOY HILL

Project Number: ME5040

Designed By: AA      Checked By: MSC



**2.6.8 Design Ice Thickness:**

$$t_{iz} = 2.0 * t_i * I * K_{iz} * (K_{zt})^{0.35}$$

$$t_i = 1$$

$$I = 1$$

$$K_{iz} = 1.17$$

$$K_{zt} = 1$$

$$t_{iz} = 2.34$$

$$K_{iz} = [z/33]^{0.10} \leq 1.4$$

$$K_{iz} = 1.17$$

Calculating the weight of ice, the cross-sectional area of ice shall be determined by:

$$A_{iz} = \pi * t_{iz} * (D_c + t_{iz})$$

$$D_c = 96.4 \text{ (in) Largest Dim of Member}$$

$$A_{iz} = 726.51$$

**2.6.9 Design Wind Load:**

$$F = q_z * G * h * (EPA's)$$

$$q_z = 0.00256 * K_z * K_{zt} * K_d * V_{max}^2$$

$$K_z = 1.130$$

$$K_{zt} = 1$$

$$K_d = 0.95$$

$$V_{max} = 100$$

$$q_z = 27.49$$

Table 2-2

Structure Type	Wind Direction Probability Factor, Kd
Latticed structures with triangular, square or rectangular cross sections	0.85
Tubular pole structures, latticed structures with other cross sections, appurtenances.	0.95

Date: 02-12-16

Project Name: MUNJOY HILL

Project Number: ME5040

Designed By: AA      Checked By: MSC



**Determine Cf:**

If lattice Structure See Manual

If Tubular Pole Structure, Use Corrected Value from Table 2.7 Below

C mph.ft	Round	18 Sided	16 Sided	12 Sided	8 Sided
< 32 (Subcritical)	1.2	1.2	1.2	1.2	1.2
32 to 64 (Transitional)	$38.4/C^{1.0}$	$25.8/C^{0.885}$	$12.6/C^{0.678}$	$2.99/C^{0.263}$	1.2
> 64 (Supercritical)	0.6	0.65	0.75	1	1.2

$$C = (I * K_{zt} * K_z)^{0.5} * V * D$$

Dp = Outside Diameter or Out to Out:      0.2      feet

**C= 21.26**

**Cf= 1.2**

<u>Appurtenances</u>	<u>Height</u>	<u>Width</u>	<u>Depth</u>	<u>Flat Area</u>	<u>Force Per Appurtenance</u>
(E) Antenna	57	11	5	4.35	193.89 (lbs)
(E) Antenna	96.4	11.9	7.1	7.97	354.75 (lbs)
(E) Antenna	48	11.8	5.9	3.93	175.15 (lbs)
(P) Antenna	72	12	9.6	6.00	267.18 (lbs)



Date: 02-12-16

Project Name: AWE-MUNJOY HILL

Project Number: ME5040

Designed By: AA      Checked By: MSC



**2.6.5.2 Velocity Pressure Coeff:**

$$K_z = 2.01 (z/z_g)^{2/\alpha}$$

z = 157 (ft)

ALPHA & BETA SECTOR RRH

z<sub>g</sub> = 1200 (ft)

α = 7

**K<sub>z</sub> = 1.124**

$$K_{zmin} \leq K_z \leq 2.01$$

**Table 2-4**

Exposure	Z <sub>g</sub>	α	K <sub>zmin</sub>	K <sub>e</sub>
B	1200 ft	7	0.70	0.90
C	900 ft	9.5	0.85	1
D	700 ft	11.5	1.03	1.10

**2.6.6.4 Topographic Factor:**

**Table 2-5**

Topo. Category	K <sub>t</sub>	f
2	0.43	1.25
3	0.53	2
4	0.72	1.5

$$K_{zt} = [1 + (K_e K_t / K_h)]^2$$

$$K_h = e^{(f \cdot z / H)}$$

**K<sub>zt</sub> = #DIV/0!**

K<sub>h</sub> = #DIV/0!

K<sub>e</sub> = 0 (from Table 2-4)

K<sub>t</sub> = 0 (from Table 2-5)

f = 0 (from Table 2-5)

z = 157

H = 0 (Ht. of the crest above surrounding terrain)

K<sub>zt</sub> = 1.00

(If Category 1 then K<sub>zt</sub> = 1.0)

**Category = 1**

Date: 02-12-16  
 Project Name: AWE-MUNJOY HILL  
 Project Number: ME5040  
**Designed By:** AA      **Checked By:** MSC



**2.6.7 Gust Effect Factors**

**2.6.7.1 Self Supporting Lattice Structures**

Gh = 1.0 Latticed Structures > 600 ft

Gh = 0.85 Latticed Structures 450 ft or less

Gh = 0.85 + 0.15 [h/150 - 3.0]      h= ht. of structure

h=      154	Gh=      0.554
-------------	----------------

**2.6.7.2 Guyed Masts**

Gh=      0.85

**2.6.7.3 Pole Structures**

Gh=      1.1

**2.6.7.4 Structures Supported on Other Structures**

*(Cantilevered tubular or latticed spines, pole, structures on buildings (ht. : width ratio > 5)*

Gh=      1.35	Gh=      1.35
---------------	---------------

Date: 02-12-16

Project Name: AWE-MUNJOY HILL

Project Number: ME5040

Designed By: AA      Checked By: MSC



**2.6.8 Design Ice Thickness:**

$$t_{iz} = 2.0 * t_i * I * K_{iz} * (K_{zt})^{0.35}$$

$$t_i = 1$$

$$I = 1$$

$$t_{iz} = 2.34$$

$$K_{iz} = 1.17$$

$$K_{zt} = 1$$

$$K_{iz} = [z/33]^{0.10} \leq 1.4$$

$$K_{iz} = 1.17$$

Calculating the weight of ice, the cross-sectional area of ice shall be determined by:

$$A_{iz} = \pi * t_{iz} * (D_c + t_{iz})$$

$$D_c = 26.7 \text{ (in) Largest Dim of Member}$$

$$A_{iz} = 213.25$$

**2.6.9 Design Wind Load:**

$$F = q_z * G * h * (\text{EPA's})$$

$$q_z = 0.00256 * K_z * K_{zt} * K_d * V_{max}^2$$

$$K_z = 1.124$$

$$K_{zt} = 1$$

$$q_z = 27.34$$

$$K_d = 0.95$$

$$V_{max} = 100$$

**Table 2-2**

Structure Type	Wind Direction Probability Factor, Kd
Latticed structures with triangular, square or rectangular cross sections	0.85
Tubular pole structures, latticed structures with other cross sections, appurtenances.	0.95





Site Name: MUNJOY HILL  
 Site No. ME5040  
 Done by: AA  
 Date: 2/12/2016

Checked by: MSC



Calculate Total Ballast Required for Ballast Mount

WIND FORCES

F antennas = at 7.5 ft. 194 lbs.  
 at 7 ft. 860 lbs.

F RRH/SURGE/FIBER BOX 363 lbs.

Antenna Height = 7.5 ft  
 7 ft

RRH/Surge/Fiber Box= 3 ft

Overturning at Ballast

Moment = 10276.8 lbs.-ft

Hold Down Force = 1417.49 lbs. Per Side

Wa Ballast

Equipment  
 Frame = 150 lbs.

Total Ballast Required Wa= 1267.49 lbs.

Blocks Required Wa = 34 Assumed 38lbs Block (4"x8"x16" Solid)

Wb Ballast


Equipment  
 Frame 300 lbs.  
 -4 Antennas 190 lbs.  
 RRH's 130 lbs.  
 Surge Arrestor/Box 75 lbs.  
 Total = 695 lbs.

Total Ballast Required Wb = 722.49 lbs.

Blocks Required Wb= 20 Assumed 38lbs Block (4"x8"x16" Solid)

Footprint Area under Ballast Frame= 58.34 sq. ft.

Distributed Load under Ballast Frame= 50.13 psf



Length = 7.25 ft

SF = 1.2



**Gamma Sector  
Antenna Calculations**

Date: 2-12-16

Project Name: MUNJOY HILL

Project Number: ME5040

Designed By: AA      Checked By: MSC



**2.6.5.2 Velocity Pressure Coeff:**

$$K_z = 2.01 (z/z_g)^{2/\alpha}$$

z= 155 (ft)

z<sub>g</sub>= 1200 (ft)

α= 7

**GAMMA SECTOR ANTENNAS**

**K<sub>z</sub>= 1.120**

$$K_{zmin} \leq K_z \leq 2.01$$

**Table 2-4**

Exposure	Z <sub>g</sub>	α	K <sub>zmin</sub>	K <sub>e</sub>
B	1200 ft	7	0.70	0.90
C	900 ft	9.5	0.85	1
D	700 ft	11.5	1.03	1.10

**2.6.6.4 Topographic Factor:**

**Table 2-5**

Topo. Category	K <sub>t</sub>	f
2	0.43	1.25
3	0.53	2
4	0.72	1.5

$$K_{zt} = [1 + (K_e K_t / K_h)]^2$$

$$K_h = e^{(fz/H)}$$

**K<sub>zt</sub>= #DIV/0!**

K<sub>h</sub>= #DIV/0!

K<sub>e</sub>= 0 (from Table 2-4)

K<sub>t</sub>= 0 (from Table 2-5)

f= 0 (from Table 2-5)

z= 155

H= 0 (Ht. of the crest above surrounding terrain)

K<sub>zt</sub>= 1.00

*(If Category 1 then K<sub>zt</sub>=1.0)*

**Category= 1**

Date: 2-12-16  
Project Name: MUNJOY HILL  
Project Number: ME5040  
Designed By: AA      Checked By: MSC



**2.6.7 Gust Effect Factors**

**2.6.7.1 Self Supporting Lattice Structures**

Gh = 1.0 Latticed Structures > 600 ft

Gh = 0.85 Latticed Structures 450 ft or less

Gh = 0.85 + 0.15 [h/150 - 3.0]      h= ht. of structure

h=      154      Gh=      0.554

**2.6.7.2 Guyed Masts**

Gh=      0.85

**2.6.7.3 Pole Structures**

Gh=      1.1

**2.6.7.4 Structures Supported on Other Structures**

*(Cantilevered tubular or latticed spines, pole, structures on buildings (ht. : width ratio > 5)*

Gh=      1.35      Gh=      1.35



Date: 2-12-16

Project Name: MUNJOY HILL

Project Number: ME5040

Designed By: AA      Checked By: MSC



**2.6.8 Design Ice Thickness:**

$$t_{iz} = 2.0 * t_i * I * K_{iz} * (K_{zt})^{0.35}$$

$$t_i = 1$$

$$I = 1$$

$$t_{iz} = 2.33$$

$$K_{iz} = 1.17$$

$$K_{zt} = 1$$

$$K_{iz} = [z/33]^{0.10} \leq 1.4$$

$$K_{iz} = 1.17$$

Calculating the weight of ice, the cross-sectional area of ice shall be determined by:

$$A_{iz} = \pi * t_{iz} * (D_c + t_{iz})$$

$$D_c = 72 \text{ (in) Largest Dim of Member}$$

$$A_{iz} = 545.20$$

**2.6.9 Design Wind Load:**

$$F = q_z * G * h * (\text{EPA's})$$

$$q_z = 0.00256 * K_z * K_{zt} * K_d * V_{max}^2$$

$$K_z = 1.120$$

$$K_{zt} = 1$$

$$q_z = 27.24$$

$$K_d = 0.95$$

$$V_{max} = 100$$

**Table 2-2**

Structure Type	Wind Direction Probability Factor, Kd
Latticed structures with triangular, square or rectangular cross sections	0.85
Tubular pole structures, latticed structures with other cross sections, appurtenances.	0.95

Date: 2-12-16

Project Name: MUNJOY HILL

Project Number: ME5040

Designed By: AA      Checked By: MSC



**Determine Cf:**

If lattice Structure See Manual

If Tubular Pole Structure, Use Corrected Value from Table 2.7 Below

C mph.ft	Round	18 Sided	16 Sided	12 Sided	8 Sided
< 32 (Subcritical)	1.2	1.2	1.2	1.2	1.2
32 to 64 (Transitional)	$38.4/C^{1.0}$	$25.8/C^{0.885}$	$12.6/C^{0.678}$	$2.99/C^{0.263}$	1.2
> 64 (Supercritical)	0.6	0.65	0.75	1	1.2

$$C = (I * K_{zt} * K_z)^{0.5} * V * D$$

Dp = Outside Diameter or Out to Out:      0.2      feet

**C=      21.17**

**Cf=      1.2**

<u>Appurtenances</u>	<u>Height</u>	<u>Width</u>	<u>Depth</u>	<u>Flat Area</u>	<u>Force Per Appurtenance</u>
(E) Antenna	57	11	5	4.35	<b>192.14</b> (lbs)
(E) Antenna	72	14.8	9	7.40	<b>326.55</b> (lbs)
(E) Antenna	72	11.8	5.9	5.90	<b>260.36</b> (lbs)
(P) Antenna	72	12	9.6	6.00	<b>264.77</b> (lbs)

## ICE WEIGHT CALCULATIONS

Project: ME5040

Thickness of ice: 1

Weight of ice based on total radial SF area: **Antenna**

Depth (in): 9.6

height (in): 72

Width (in): 12

Total weight of ice on object: 101 pounds ice

Weight of object: 48 pounds

**Combined weight of ice and object: 149 pounds**

Per foot weight of ice: **Pipe**

pipe weight per foot: 3.65

pipe length (ft): 6

diameter (in): 2.375

Per foot weight of ice on object: 3 pounds ice /ft

Total weight of ice on object: 17 pounds

Total weight of pipe: 21.9 pounds

**Combined weight of pipe and ice: 39 pounds**

\* Density of ice used = 56 PCF

**Total Weight: 188 pounds**

Site Name: MUNJOY HILL

Site No. ME5040

Done by: AA

Checked by: MSC

Date: 2/12/2016



### CHECK CONNECTION CAPACITY

Reference: Hilti Volume 2: Anchor Fastening Technical Guide

Epoxy Type = HIT-HY20  
Anchor Diameter = 3/8 in. (Assumed)  
Min. Embedment Depth = 2 in. (Assumed)

#### Allowable Tensile Load =

$F_{Tall} = 525 \text{ lbs.}$

#### Allowable Shear Load =

$F_{vall} = 790 \text{ lbs.}$

### WIND FORCES

Reaction  $F = 265 \text{ lbs.}$

### GRAVITY LOADS

Ice and Equipment 188 lbs.

No. of Supports = 2

No. of Anchors / Support = 2

#### Tension Design Load / Anchor =

$f_t = 66.25 \text{ lbs.} < 525 \text{ lbs.}$  Therefore, OK !

#### Shear Design Load / Anchor =

$f_v = 47.00 \text{ lbs.} < 790 \text{ lbs.}$  Therefore, OK !

### CHECK COMBINED TENSION AND SHEAR

$f_t / F_T + f_v / F_V \leq 1.0$   
0.126 + 0.059 = 0.186 < 1.0 Therefore, OK !



## RRH Frame Calculations

Date: 02-12-16

Project Name: MUNJOY HILL

Project Number: ME5040

Designed By: AA      Checked By: MSC



**2.6.5.2 Velocity Pressure Coeff:**

$$K_z = 2.01 (z/z_g)^{2/\alpha}$$

$z = 157 \text{ (ft)}$       **RRH**  
 $z_g = 1200 \text{ (ft)}$   
 $\alpha = 7$   
 **$K_z = 1.124$**

$K_{zmin} \leq K_z \leq 2.01$

**Table 2-4**

Exposure	$Z_g$	$\alpha$	$K_{zmin}$	$K_e$
B	1200 ft	7	0.70	0.90
C	900 ft	9.5	0.85	1
D	700 ft	11.5	1.03	1.10

**2.6.6.4 Topographic Factor:**

**Table 2-5**

Topo. Category	$K_t$	f
2	0.43	1.25
3	0.53	2
4	0.72	1.5

$K_{zt} = [1 + (K_e K_t / K_h)]^2$

$K_h = e^{(fz/H)}$

**$K_{zt} = \text{\#DIV/0!}$**

$K_h = \text{\#DIV/0!}$

$K_e = 0$  (from Table 2-4)

$K_t = 0$  (from Table 2-5)

f = 0 (from Table 2-5)

z = 157

H = 0 (Ht. of the crest above surrounding terrain)

$K_{zt} = 1.00$

(If Category 1 then  $K_{zt} = 1.0$ )

**Category = 1**

Date: 02-12-16  
Project Name: MUNJOY HILL  
Project Number: ME5040  
Designed By: AA      Checked By: MSC



**2.6.7 Gust Effect Factors**

**2.6.7.1 Self Supporting Lattice Structures**

Gh = 1.0 Latticed Structures > 600 ft

Gh = 0.85 Latticed Structures 450 ft or less

Gh = 0.85 + 0.15 [h/150 - 3.0]      h= ht. of structure  
h=      154      Gh=      0.554

**2.6.7.2 Guyed Masts**      Gh=      0.85

**2.6.7.3 Pole Structures**      Gh=      1.1

**2.6.7.4 Structures Supported on Other Structures**  
(Cantilevered tubular or latticed spines, pole, structures on buildings (ht. : width ratio > 5))

Gh=      1.35      Gh=      1.35

Date: 02-12-16

Project Name: MUNJOY HILL

Project Number: ME5040

Designed By: AA      Checked By: MSC



**2.6.8 Design Ice Thickness:**

$$t_{iz} = 2.0 * t_i * I * K_{iz} * (K_{zt})^{0.35}$$

$$t_i = 1$$

$$I = 1$$

$$K_{iz} = 1.17$$

$$K_{zt} = 1$$

$$t_{iz} = 2.34$$

$$K_{iz} = [z/33]^{0.10} \leq 1.4$$

$$K_{iz} = 1.17$$

Calculating the weight of ice, the cross-sectional area of ice shall be determined by:

$$A_{iz} = \pi * t_{iz} * (D_c + t_{iz})$$

$$D_c = 26.7 \text{ (in) Largest Dim of Member}$$

$$A_{iz} = 213.25$$

**2.6.9 Design Wind Load:**

$$F = q_z * G * h * (\text{EPA's})$$

$$q_z = 0.00256 * K_z * K_{zt} * K_d * V_{max}^2$$

$$K_z = 1.124$$

$$K_{zt} = 1$$

$$K_d = 0.95$$

$$V_{max} = 100$$

$$q_z = 27.34$$

Table 2-2

Structure Type	Wind Direction Probability Factor, Kd
Latticed structures with triangular, square or rectangular cross sections	0.85
Tubular pole structures, latticed structures with other cross sections, appurtenances.	0.95



Date: 02-12-16

Project Name: MUNJOY HILL

Project Number: ME5040

Designed By: AA      Checked By: MSC



**Determine Cf:**

If lattice Structure See Manual

If Tubular Pole Structure, Use Corrected Value from Table 2.7 Below

C mph.ft	Round	18 Sided	16 Sided	12 Sided	8 Sided
< 32 (Subcritical)	1.2	1.2	1.2	1.2	1.2
32 to 64 (Transitional)	$38.4/C^{1.0}$	$25.8/C^{0.885}$	$12.6/C^{0.678}$	$2.99/C^{0.263}$	1.2
> 64 (Supercritical)	0.6	0.65	0.75	1	1.2

$$C = (I * K_{zt} * K_z)^{0.5} * V * D$$

Dp = Outside Diameter or Out to Out:      0.2      feet

**C= 21.21**

**Cf= 1.2**

<u>Appurtenances</u>	<u>Height</u>	<u>Width</u>	<u>Depth</u>	<u>Flat Area</u>	<u>Force Per Appurtenance</u>
RRH-11	19.7	17	7.2	2.33	<b>103.01 (lbs)</b>
RRH-32	26.7	12.1	6.7	2.24	<b>99.37 (lbs)</b>
Squid	24	9.7	9.7	1.62	<b>71.60 (lbs)</b>

Site Name: MUNJOY HILL  
 Site No.: ME5040  
 Done by: AA  
 Date: 2/12/2016


Checked by: MSC



**Calculate Total Ballast Required for Ballast Mount**

\*Assume (2) RRH's as projected area\*

**Force (F) =** 207 lbs.  
**Height (H) =** 3 ft  
**Weight (W) =** 380 lbs.  
**Frame Width/2 (X) =** 1.5 ft  
**Length (L) =** 2.2 ft  
**Ballast (Wb) =** TBD



**Overturning at Ballast**

$$\Sigma M = 0 = (F * H) - (W * X) - (Wb * L) \text{ ---> } Wb = [(F*H-W*X)/L]*SF = \mathbf{23 \text{ lbs.}}$$

**Determine Number of Blocks Required**

(assume 4"x8"x16" solid blocks @ 38 lbs. each)

Number of Blocks Required = 1 BLOCKS PER SIDE

-Total Weight of Fully Loaded Frame = 532 lbs.  
 -Footprint Area Under Ballast Frame = 10.5 sqft.  
 -Distributed Load Under Ballast Frame = 51 psf



## Roof Calculations

Date: 02-12-2016  
Project Name: MUNJOY HILL  
Project Number: ME5040  
Designed By: AA Checked By: MSC



**Check Roof Capacity:**

Reference: \_\_\_\_\_ • Building Plans by Leasure, Tuttle, Lee dated 03/23/1967.

Roof Design LL:	100 psf
Calculated Flat Roof Snow:	42 psf
Miscellaneous:	5 psf

**Net Available Load:** 53 psf

**Antenna Ballast Frame Load:** 50.13 psf < **53 PSF O.K!**

**Antenna Ballast Frame Load:** 51 psf < **53 PSF O.K!**

NORTH WALL ELEVATION  
SCALE 1/8" = 1'-0"

GENERAL NOTES

- 1. ROOF DESIGN LL = 50#/FT<sup>2</sup> + DRIFTING LL = 100#/FT<sup>2</sup>  
FLOOR DESIGN LL = 50#/FT<sup>2</sup> + PARTITION D.L. = 20#/FT<sup>2</sup>
- 2. ALLOWABLE SOIL PRESSURE = 2000 PSF
- 3. CONCRETE TO BE 3000 PSI W/ GRADE 40 REINFORCING.
- 4. MASONRY WALLS TO HAVE DUR-O-WALL REINFORCING @ EVERY 16" O.C.
- 5. STEEL TO BE A36 EXCEPT TUBE TO BE A500 GRADE B - 92 KSI, DETAIL, FABRICATED, AND ERECT PER AISC STANDARDS AND SPECIFICATIONS.
- 6. JOIST TO BE DETAIL FABRICATED AND ERECTED PER AISC STANDARDS AND SPECIFICATIONS.
- 7. ROOF DECK TO BE 1/2" X 22 GA. TYPE B GALVANIZED. FLOOR DECK TO BE 1/4" X 29 GA. UNIFORM OPS GALV.
- 8. ALL LINTELS & BEAMS TO BEAR ON TO WALLS. FILL ONE BLOCK BELOW THE LINTEL N BEAMS W/ DROUT.
- 9. # INDICATES JOIST W/ BOLTED CONNECTIONS.
- 10. 11.0' INDICATES BOTTOM OF FOOTING ELEV. (705.6') INDICATES TOP OF WALL ELEV.

THICK DIMENSIONS  
IN 3/16"

**BEAM SCHEDULE**


NOTE: See notes on page 20 for details of beam schedule.

Beam No.	Span	Supports	Notes
1	10'-0" x 12'-0"	1, 2	1st floor
2	10'-0" x 12'-0"	1, 2	1st floor
3	10'-0" x 12'-0"	1, 2	1st floor
4	10'-0" x 12'-0"	1, 2	1st floor
5	10'-0" x 12'-0"	1, 2	1st floor
6	10'-0" x 12'-0"	1, 2	1st floor
7	10'-0" x 12'-0"	1, 2	1st floor
8	10'-0" x 12'-0"	1, 2	1st floor
9	10'-0" x 12'-0"	1, 2	1st floor
10	10'-0" x 12'-0"	1, 2	1st floor
11	10'-0" x 12'-0"	1, 2	1st floor
12	10'-0" x 12'-0"	1, 2	1st floor
13	10'-0" x 12'-0"	1, 2	1st floor
14	10'-0" x 12'-0"	1, 2	1st floor
15	10'-0" x 12'-0"	1, 2	1st floor
16	10'-0" x 12'-0"	1, 2	1st floor
17	10'-0" x 12'-0"	1, 2	1st floor
18	10'-0" x 12'-0"	1, 2	1st floor
19	10'-0" x 12'-0"	1, 2	1st floor
20	10'-0" x 12'-0"	1, 2	1st floor
21	10'-0" x 12'-0"	1, 2	1st floor
22	10'-0" x 12'-0"	1, 2	1st floor
23	10'-0" x 12'-0"	1, 2	1st floor
24	10'-0" x 12'-0"	1, 2	1st floor
25	10'-0" x 12'-0"	1, 2	1st floor
26	10'-0" x 12'-0"	1, 2	1st floor
27	10'-0" x 12'-0"	1, 2	1st floor
28	10'-0" x 12'-0"	1, 2	1st floor
29	10'-0" x 12'-0"	1, 2	1st floor
30	10'-0" x 12'-0"	1, 2	1st floor
31	10'-0" x 12'-0"	1, 2	1st floor
32	10'-0" x 12'-0"	1, 2	1st floor
33	10'-0" x 12'-0"	1, 2	1st floor
34	10'-0" x 12'-0"	1, 2	1st floor
35	10'-0" x 12'-0"	1, 2	1st floor
36	10'-0" x 12'-0"	1, 2	1st floor
37	10'-0" x 12'-0"	1, 2	1st floor
38	10'-0" x 12'-0"	1, 2	1st floor
39	10'-0" x 12'-0"	1, 2	1st floor
40	10'-0" x 12'-0"	1, 2	1st floor
41	10'-0" x 12'-0"	1, 2	1st floor
42	10'-0" x 12'-0"	1, 2	1st floor
43	10'-0" x 12'-0"	1, 2	1st floor
44	10'-0" x 12'-0"	1, 2	1st floor
45	10'-0" x 12'-0"	1, 2	1st floor
46	10'-0" x 12'-0"	1, 2	1st floor
47	10'-0" x 12'-0"	1, 2	1st floor
48	10'-0" x 12'-0"	1, 2	1st floor
49	10'-0" x 12'-0"	1, 2	1st floor
50	10'-0" x 12'-0"	1, 2	1st floor
51	10'-0" x 12'-0"	1, 2	1st floor
52	10'-0" x 12'-0"	1, 2	1st floor
53	10'-0" x 12'-0"	1, 2	1st floor
54	10'-0" x 12'-0"	1, 2	1st floor
55	10'-0" x 12'-0"	1, 2	1st floor
56	10'-0" x 12'-0"	1, 2	1st floor
57	10'-0" x 12'-0"	1, 2	1st floor
58	10'-0" x 12'-0"	1, 2	1st floor
59	10'-0" x 12'-0"	1, 2	1st floor
60	10'-0" x 12'-0"	1, 2	1st floor
61	10'-0" x 12'-0"	1, 2	1st floor
62	10'-0" x 12'-0"	1, 2	1st floor
63	10'-0" x 12'-0"	1, 2	1st floor
64	10'-0" x 12'-0"	1, 2	1st floor
65	10'-0" x 12'-0"	1, 2	1st floor
66	10'-0" x 12'-0"	1, 2	1st floor
67	10'-0" x 12'-0"	1, 2	1st floor
68	10'-0" x 12'-0"	1, 2	1st floor
69	10'-0" x 12'-0"	1, 2	1st floor
70	10'-0" x 12'-0"	1, 2	1st floor
71	10'-0" x 12'-0"	1, 2	1st floor
72	10'-0" x 12'-0"	1, 2	1st floor
73	10'-0" x 12'-0"	1, 2	1st floor
74	10'-0" x 12'-0"	1, 2	1st floor
75	10'-0" x 12'-0"	1, 2	1st floor
76	10'-0" x 12'-0"	1, 2	1st floor
77	10'-0" x 12'-0"	1, 2	1st floor
78	10'-0" x 12'-0"	1, 2	1st floor
79	10'-0" x 12'-0"	1, 2	1st floor
80	10'-0" x 12'-0"	1, 2	1st floor
81	10'-0" x 12'-0"	1, 2	1st floor
82	10'-0" x 12'-0"	1, 2	1st floor
83	10'-0" x 12'-0"	1, 2	1st floor
84	10'-0" x 12'-0"	1, 2	1st floor
85	10'-0" x 12'-0"	1, 2	1st floor
86	10'-0" x 12'-0"	1, 2	1st floor
87	10'-0" x 12'-0"	1, 2	1st floor
88	10'-0" x 12'-0"	1, 2	1st floor
89	10'-0" x 12'-0"	1, 2	1st floor
90	10'-0" x 12'-0"	1, 2	1st floor
91	10'-0" x 12'-0"	1, 2	1st floor
92	10'-0" x 12'-0"	1, 2	1st floor
93	10'-0" x 12'-0"	1, 2	1st floor
94	10'-0" x 12'-0"	1, 2	1st floor
95	10'-0" x 12'-0"	1, 2	1st floor
96	10'-0" x 12'-0"	1, 2	1st floor
97	10'-0" x 12'-0"	1, 2	1st floor
98	10'-0" x 12'-0"	1, 2	1st floor
99	10'-0" x 12'-0"	1, 2	1st floor
100	10'-0" x 12'-0"	1, 2	1st floor

**PERMANENT ROOF FRAMING PLAN**  
Scale 1/4" = 1'-0"



**MACHINE ROOM FLOOR FRAMING PLAN**  
Scale 1/4" = 1'-0"



**ROOF FRAMING PLAN**  
Scale 1/4" = 1'-0"

NOTE: For Column Schedule, Spacing and  
Reinforcing Bars see page 20 and  
page 21. For details of machine  
room layout see page 22 and  
page 23. For details of machine  
room layout see page 24 and  
page 25.