Inspections Division
Date: 01/08/14

RSD Plumbing & Heating inc.
License & Insured 25 Years
Residential & Commercial
Robert S. Dorr
(207) 415-3375
rsdorr@yahoo.com
17 Milliken Road Scarborough, ME 04074

Job Description

January 8, 2014

Ref; Slab Pizza

After meeting with Nathanael Towl at proposed site and discussing drain and venting for plumbing fixtures and receptacles.

Bathroom area doesn't oppose any problems with waste or vent. Adequate drain size in basement and current vents in crawl space above ceiling to accommodate fixture load.

Kitchen area mostly the same as bathrooms. Drains in basement area are adequately sized for kitchen equipment. One or two areas for vents might have to be soffit to get into crawl space above.

NOTE: That not a large amount of grease will be generated in food preparation or cleaning of pots, pans, plates etc. Model of grease trap proposed to be indoor type. Thermaco Big Dipper # W-200-15

Bar area some existing drains in concrete slab to be camera to confirm they will be adequate for fixture load. Vents for bar area would be two island vent location under each end of bar to vent fixture per State Plumbing Code, these vents would also need to be soffit back into crawl space.