

POWER PAY OFFICE FIT UP



SEE HEAT PUMP SYSTEM
DIAGRAMS ON SHEETS
M13 & M14 FOR REFRIGERANT
LINE SIZING. ALL COND.
DRAIN LINES AT INDIVIDUAL
HEAT PUMPS AND B.C.C.
CONTROLLERS TO BE 1".

CONDENSING UNITS
MOUNTED ON EXIST'G
EQUIPMENT SLINGS
ON ROOF. S.C. TO
PROVIDE ADDITIONAL
SUPPORT STEEL AS
NECESSARY.

CONDENSING UNITS
MOUNTED ON EXIST'G
EQUIPMENT SLINGS
ON ROOF.

March 24, 2009 - 1:57 PM
\\mechsys\Projects\0837 Power Pay\Drawings\0837 M7-M10.dwg

Winton Scott
Architects
5 Milk Street
Portland, Maine 04101

Wright Ryan
Construction, Inc.
10 Danforth Street
Portland, Maine 04101

Becker Structural
Engineers, Inc.
75 York Street
Portland, Maine 04101



Mechanical
Systems
Engineers
10 Royal River Center
Yarmouth, Maine 04096

Bartlett Design
942 Washington Ave.
Bath, Maine 04530

Fore Solutions
386 Fore Street
Portland, Maine 04101

MEZZANINE NORTH
REFRIGERANT
PIPING PLAN

M9



MECHANICAL SYSTEMS ENGINEERS
ROYAL RIVER CENTER, UNIT #10
10 FOREST FALLS DRIVE
YARMOUTH, MAINE 04096
VOICE: (207) 846-1441
FAX: (207) 846-1443
mechsys@maine.me
© COPYRIGHT 2009

Scale: 1/8" = 1'-0" Date: 03.20.09
M.S.E. Proj: 0837