

**... Fire Protection by Computer Design**

EASTERN FIRE PROTECTION  
170 KITTY HAWK AVE  
AUBURN, ME 04210  
207-784-1507

Job Name : 465 CONGRESS THIRD FLOOR  
Drawing : 1 OF 1  
Location : PORTLAND, ME  
Remote Area : 1  
Contract : 5019-13  
Data File : 465 CONGRESS 3rd floor withOUT pump 1.5 MAIN.WXF

---

**HYDRAULIC CALCULATIONS**  
*for*

**Project name:** 465 CONGRESS THIRD FLOOR  
**Location:** PORTLAND, ME  
**Drawing no:** 1 OF 1  
**Date:** 4/17/13

**Design**

**Remote area number:** 1  
**Remote area location:** OFFICE SPACE  
**Occupancy classification:** LIGHT HAZARD  
**Density:** .1 - Gpm/SqFt  
**Area of application:** 980 - SqFt  
**Coverage per sprinkler:** 150/210 - SqFt  
**Type of sprinklers calculated:** TYCO TY-FRB PENDENT K=5.6 200  
**No. of sprinklers calculated:** 8  
**In-rack demand:** - GPM  
**Hose streams:** 100 - GPM  
**Total water required (including hose streams):** 166.38 - GPM @ 70.397 - Psi  
**Type of system:** WET CITY SUPPLY  
**Volume of dry or preaction system:** - Gal

**Water supply information**

**Date:** 9/13/2011  
**Location:** CONGRESS ST.  
**Source:** PORTLAND WATER DISTRICT

**Name of contractor:** EASTERN FIRE PROTECTION  
**Address:** 170 KITTY HAWK AVE / / AUBURN, ME 04210  
**Phone number:** 207-784-1507  
**Name of designer:** ROBERT PETERS  
**Authority having jurisdiction:** STATE FIRE MARSHAL  
**Notes: (Include peaking information or gridded systems here.)**  
AREA REDUCTION TAKEN PER NFPA 13 2010 EDITION SECTION 11.2.3.2.3.1


# Water Supply Curve C

EASTERN FIRE PROTECTION  
465 CONGRESS THIRD FLOOR

Page 2  
Date 4/17/13

City Water Supply:  
C1 - Static Pressure : 78  
C2 - Residual Pressure: 74  
C2 - Residual Flow : 1138

Demand:  
D1 - Elevation : 21.222  
D2 - System Flow : 166.372  
D2 - System Pressure : 70.397  
Hose ( Demand ) : \_\_\_\_\_  
D3 - System Demand : 166.372  
Safety Margin : 7.489



# Fittings Used Summary

EASTERN FIRE PROTECTION  
465 CONGRESS THIRD FLOOR

Page 3  
Date 4/17/13

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	NFPA 13 Long Turn Elbow	0.5	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
S	NFPA 13 Swing Check Valve	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zac	Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																			

## Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

**SUPPLY ANALYSIS**

<b>Node at Source</b>	<b>Static Pressure</b>	<b>Residual Pressure</b>	<b>Flow</b>	<b>Available Pressure</b>	<b>Total Demand</b>	<b>Required Pressure</b>
TEST	78.0	74	1138.0	77.886	166.37	70.397

**NODE ANALYSIS**

<b>Node Tag</b>	<b>Elevation</b>	<b>Node Type</b>	<b>Pressure at Node</b>	<b>Discharge at Node</b>	<b>Notes</b>
LIN	100.0	5.6	14.06	21.0	
LIN2	100.0	5.6	7.0	14.82	
1	149.0	5.44	11.47	18.43	K=K @ DRP1
2	149.0	5.44	12.04	18.89	K=K @ DRP1
2A	149.0		14.32		
3	149.0	5.45	16.25	21.97	K=K @ DRP
4	149.0	5.45	17.39	22.73	K=K @ DRP
5	149.0	5.44	14.09	20.43	K=K @ DRP1
6	149.0	5.44	15.18	21.2	K=K @ DRP1
7	149.0	5.45	14.85	21.0	K=K @ DRP
7A	149.0		15.74		
8	149.0	5.45	15.9	21.73	K=K @ DRP
#	100.0		36.07		
B	149.0		18.14		
A	149.0		18.18		
C	149.0		21.52		
I	149.0		34.3		
D	149.0		20.76		
E	149.0		20.91		
F	149.0		23.9		
G	149.0		33.34		
H	146.833		38.16		
FCV	146.833		44.06		
J	129.667		51.8		
K	107.167		62.68		
L	107.167		62.93		
BFP	93.0		69.65		
BASE	93.0		73.33		
TEST	100.0		70.4		

# Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION  
465 CONGRESS THIRD FLOOR

Page 5  
Date 4/17/13

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
LIN to DRP	100 100	5.60	21.00 21.0	1 1.101	1T 0.0	9.563 0.0	1.000 9.562	150 0.0	14.062 0.0		
			0.0			0.0	10.562	0.0745	0.787	Vel = 7.08	
DRP			21.00						14.849	K Factor = 5.45	
LIN2 to DRP1	100 100	5.60	14.82 14.82	1 1.101	1T 0.0	9.563 0.0	1.000 9.562	150 0.0	7.000 0.0		
			0.0			0.0	10.562	0.0391	0.413	Vel = 4.99	
DRP1			14.82						7.413	K Factor = 5.44	
1 to 2	149 149	5.44	18.43 18.43	1 1.101		0.0 0.0	9.875 0.0	150 0.0	11.467 0.0	K = K @ DRP1	
						0.0	9.875	0.0584	0.577	Vel = 6.21	
2 to 2A	149 149	5.44	18.88 37.31	1 1.101	1T 0.0	9.563 0.0	1.000 9.562	150 0.0	12.044 0.0	K = K @ DRP1	
			0.0			0.0	10.562	0.2157	2.278	Vel = 12.57	
2A to A	149 149		0.0 37.31	1 1.101	1T 0.0	9.563 0.0	8.333 9.562	150 0.0	14.322 0.0		
						0.0	17.895	0.2157	3.860	Vel = 12.57	
A			37.31						18.182	K Factor = 8.75	
3 to 4	149 149	5.45	21.97 21.97	1 1.101		0.0 0.0	14.083 0.0	150 0.0	16.253 0.0	K = K @ DRP	
						0.0	14.083	0.0809	1.140	Vel = 7.40	
4 to C	149 149	5.45	22.73 44.7	1 1.101	1T 0.0	9.563 0.0	4.125 9.562	150 0.0	17.393 0.0	K = K @ DRP	
			0.0			0.0	13.687	0.3012	4.123	Vel = 15.06	
C			44.70						21.516	K Factor = 9.64	
5 to 6	149 149	5.44	20.43 20.43	1 1.101	2E 0.0	7.65 0.0	7.667 7.650	150 0.0	14.092 0.0	K = K @ DRP1	
						0.0	15.317	0.0708	1.084	Vel = 6.88	
6 to B	149 149	5.44	21.20 41.63	1 1.101	1T 0.0	9.563 0.0	1.667 9.562	150 0.0	15.176 0.0	K = K @ DRP1	
			0.0			0.0	11.229	0.2640	2.965	Vel = 14.03	
B			41.63						18.141	K Factor = 9.77	
7 to 7A	149 149	5.45	21.00 21.0	1 1.101	1T 0.0	9.563 0.0	2.417 9.562	150 0.0	14.849 0.0	K = K @ DRP	
						0.0	11.979	0.0745	0.892	Vel = 7.08	
7A to 8	149 149		0.0 21.0	1 1.101		0.0 0.0	2.167 0.0	150 0.0	15.741 0.0		
						0.0	2.167	0.0743	0.161	Vel = 7.08	
8 to E	149 149	5.45	21.73 42.73	1 1.101	1T 0.0	9.563 0.0	8.500 9.562	150 0.0	15.902 0.0	K = K @ DRP	
			0.0			0.0	18.062	0.2772	5.007	Vel = 14.40	
E			42.73						20.909	K Factor = 9.34	

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION  
465 CONGRESS THIRD FLOOR

Page 6  
Date 4/17/13

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
B	149		41.63	1.5		0.0	0.960	150	18.141			
to						0.0	0.0		0.0			
A	149		41.63	1.598		0.0	0.960	0.0427	0.041	Vel =	6.66	
A	149		37.31	1.5	1T	11.656	6.667	150	18.182			
to						0.0	11.656		0.0			
D	149		78.94	1.598		0.0	18.323	0.1406	2.576	Vel =	12.63	
			0.0									
D			78.94						20.758	K Factor =	17.33	
C	149		-46.19	1.5	1T	11.656	2.875	150	21.516			
to						0.0	11.656		0.0			
D	149		-46.19	1.598		0.0	14.531	-0.0522	-0.758	Vel =	7.39	
			0.0									
D			-46.19						20.758	K Factor =	-10.14	
C	149		90.89	1.5	1T	11.656	58.417	150	21.516			
to						0.0	11.656		0.0			
I	149		90.89	1.598		0.0	70.073	0.1825	12.787	Vel =	14.54	
I	149		0.0	1.5	1T	11.656	4.333	150	34.303			
to						0.0	11.656		0.939			
H	146.833		90.89	1.598		0.0	15.989	0.1825	2.918	Vel =	14.54	
			0.0									
H			90.89						38.160	K Factor =	14.71	
D	149		32.75	1.5		0.0	5.458	150	20.758			
to						0.0	0.0		0.0			
E	149		32.75	1.598		0.0	5.458	0.0277	0.151	Vel =	5.24	
E	149		42.73	1.5	1E	5.828	17.250	150	20.909			
to						0.0	5.828		0.0			
F	149		75.48	1.598		0.0	23.078	0.1294	2.986	Vel =	12.07	
F	149		0.0	1.5	1T	11.656	61.292	150	23.895			
to						0.0	11.656		0.0			
G	149		75.48	1.598		0.0	72.948	0.1294	9.440	Vel =	12.07	
G	149		0.0	1.5	1T	11.656	18.375	150	33.335			
to						0.0	11.656		0.939			
H	146.833		75.48	1.598		0.0	30.031	0.1294	3.886	Vel =	12.07	
			0.0									
H			75.48						38.160	K Factor =	12.22	
H	146.833		166.37	2.5	2E	16.474	18.042	120	38.160			
to					1S	19.22	61.778		0.0			
FCV	146.833		166.37	2.635	1T	16.474	79.820	0.0739	5.896	Vel =	9.79	
					1B	9.61						
FCV	146.833		0.0	4	1T	26.334	17.167	120	44.056			
to						0.0	26.334		7.435			
J	129.667		166.37	4.26		0.0	43.501	0.0071	0.309	Vel =	3.74	
J	129.667		0.0	4	8E	105.337	54.250	120	51.800			
to						0.0	105.337		9.745			
K	107.167		166.37	4.26		0.0	159.587	0.0071	1.136	Vel =	3.74	
K	107.167		0.0	4	1E	13.167	22.500	120	62.681			
to						0.0	13.167		0.0			
L	107.167		166.37	4.26		0.0	35.667	0.0071	0.254	Vel =	3.74	

# Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION  
465 CONGRESS THIRD FLOOR

Page 7  
Date 4/17/13

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
L to BFP	107.167 93		0.0 166.37	4 4.26	3E	39.501	41.250 0.0 39.501 80.751	120 0.0071	62.935 6.136 0.574		Vel = 3.74	
BFP to BASE	93 93		0.0 166.37	6 6.357	1Zac 1S 2G 1T 6E	0.0 40.235 7.544 37.72 105.616	82.875 191.115 273.990	120 0.0010	69.645 3.408 0.278		* * Fixed Loss = 3.408 Vel = 1.68	
BASE to TEST	93 100		0.0 166.37	6 6.16	1L 1G 1T	12.911 4.304 43.037	50.000 60.252 110.252	140 0.0009	73.331 -3.032 0.098		Vel = 1.79	
TEST			0.0 166.37						70.397		K Factor = 19.83	