

... Fire Protection by Computer Design

EASTERN FIRE PROTECTION
170 KITTY HAWK AVE
AUBURN, ME 04210
207-784-1507

Job Name : 465 CONGRESS TENTH FLOOR UPRIGHT
Drawing : 1 OF 1
Location : PORTLAND, ME
Remote Area : 1
Contract : 5057-13
Data File : 465 CONGRESS 10th floor UPRIGHT.WXF

Water Supply Curve C

EASTERN FIRE PROTECTION
465 CONGRESS TENTH FLOOR UPRIGHT

City Water Supply:

C1 - Static Pressure : 78
C2 - Residual Pressure: 74
C2 - Residual Flow : 1138

City Water Adjusted to Pump Inlet
for Pf - Elev - Hose Flow


A1 - Adjusted Static: 80.987
A2 - Adj Resid : 73.464 @ 750
A3 - Adj Resid : 65.36 @ 1125

Pump Data:

P1 - Pump Churn Pressure : 96
P2 - Pump Rated Pressure : 80
P2 - Pump Rated Flow : 750
P3 - Pump Pressure @ Max Flow : 52
P3 - Pump Max Flow : 1125
City Residual Flow @ 0 = 5668.37
City Residual Flow @ 20 = 4829.57
City Water @ 150% of Pump = 74.08

Demand:

D1 - Elevation : 59.551
D2 - System Flow : 192.135
D2 - System Pressure : 119.465
Hose (Demand) : 192.135
D3 - System Demand : 100
Hose (Adj City) : 56.436
Safety Margin : 56.436



Fittings Used Summary

EASTERN FIRE PROTECTION
465 CONGRESS TENTH FLOOR UPRIGHT

Fitting Legend Abbrev. Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	0.5	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
S	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zac	Ames 2000SS																			
	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

SUPPLY ANALYSIS

Node at Source	Static Pressure	Residual Pressure	Flow	Available Pressure	Total Demand	Required Pressure
PO	See Information on Pump Curve			175.901	192.14	119.465
TEST	78.0	74	1138.0	77.677	292.14	77.677

NODE ANALYSIS

Node Tag	Elevation	Node Type	Pressure at Node	Discharge at Node	Notes
LIN	100.0	5.6	7.0	14.82	
LIN1	100.0	5.6	7.0	14.82	
8	237.5	5.39	12.24	18.86	K=K @ SPRG
9	235.5	5.39	12.86	19.34	K=K @ SPRG
8A	235.5		13.68		
17	235.5	5.39	15.84	21.46	K=K @ SPRG
13	235.5	5.39	14.76	20.72	K=K @ SPRG
16	235.5	5.39	16.15	21.67	K=K @ SPRG
16A	231.5		20.67		
17A	231.5		25.76		
10	235.5	5.39	9.01	16.19	K=K @ SPR1
11	237.5	5.39	7.55	14.82	K=K @ SPR1
11A	235.5		9.28		
12	235.5	5.39	11.65	18.41	K=K @ SPR1
KK	229.5		19.8		
14	235.5	5.39	13.5	19.82	K=K @ SPR1
15	235.5	5.39	14.93	20.84	K=K @ SPR1
LL	229.5		22.85		
C	229.5		42.95		
B	229.5		42.94		
M	229.5		42.0		
JJ	229.5		45.44		
6A	229.5		43.47		
D	229.5		43.64		
E	229.5		44.46		
F	229.5		45.76		
G	229.5		47.2		
H	229.5		47.67		
HH	229.5		47.76		
FCV	227.25		55.03		
J	129.667		98.47		
K	107.167		109.69		
L	107.167		110.02		
BFP	93.0		116.28		
PO	93.0		119.46		
PI	93.0		80.29		
BASE	93.0		80.58		
TEST	100.0		77.68	100.0	

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION
465 CONGRESS TENTH FLOOR UPRIGHT

Page 4
Date 7/18/13

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
LIN to SPRG	100 100	5.60	14.82 14.82	1 1.049	1E	2.0 0.0 0.0	5.333 2.000 7.333	120 0.0747	7.000 0.0 0.548			Vel = 5.50
SPRG			0.0 14.82						7.548			K Factor = 5.39
LIN1 to SPR1	100 100	5.60	14.82 14.82	1 1.049	1E	2.0 0.0 0.0	5.333 2.000 7.333	120 0.0747	7.000 0.0 0.548			Vel = 5.50
SPR1			0.0 14.82						7.548			K Factor = 5.39
8 to 8A	237.500 235.500	5.39	18.86 18.86	1 1.049		0.0 0.0 0.0	5.000 0.0 5.000	120 0.1168	12.235 0.866 0.584			K = K @ SPRG Vel = 7.00
8A			0.0 18.86						13.685			K Factor = 5.10
9 to 8A	235.500 235.500	5.39	19.34 19.34	1 1.049	1T	5.0 0.0 0.0	1.708 5.000 6.708	120 0.1224	12.864 0.0 0.821			K = K @ SPRG Vel = 7.18
8A to 17	235.500 235.500		18.87 38.21	1 1.049		0.0 0.0 0.0	5.000 0.0 5.000	120 0.4310	13.685 0.0 2.155			Vel = 14.18
17 to 17A	235.500 231.500	5.39	21.46 59.67	1 1.049	1E 1T	2.0 5.0 0.0	1.333 7.000 8.333	120 0.9832	15.840 1.732 8.193			K = K @ SPRG Vel = 22.15
17A			0.0 59.67						25.765			K Factor = 11.76
13 to 16	235.500 235.500	5.39	20.72 20.72	1 1.049		0.0 0.0 0.0	10.000 0.0 10.000	120 0.1390	14.763 0.0 1.390			K = K @ SPRG Vel = 7.69
16 to 16A	235.500 231.500	5.39	21.68 42.4	1 1.049	2E	4.0 0.0 0.0	1.333 4.000 5.333	120 0.5224	16.153 1.732 2.786			K = K @ SPRG Vel = 15.74
16A to 17A	231.500 231.500		0.0 42.4	1 1.049		0.0 0.0 0.0	9.750 0.0 9.750	120 0.5225	20.671 0.0 5.094			Vel = 15.74
17A to HH	231.500 229.500		59.67 102.07	1 1.049	1E 1T	2.0 5.0 0.0	0.960 7.000 7.960	120 2.6540	25.765 0.866 21.126			Vel = 37.89
HH			0.0 102.07						47.757			K Factor = 14.77
10 to 11A	235.500 235.500	5.39	16.19 16.19	1 1.049		0.0 0.0 0.0	3.083 0.0 3.083	120 0.0879	9.011 0.0 0.271			K = K @ SPR1 Vel = 6.01
11A			0.0 16.19						9.282			K Factor = 5.31
11 to 11A	237.500 235.500	5.39	14.82 14.82	1 1.049	1E 1T	2.0 5.0 0.0	4.625 7.000 11.625	120 0.0747	7.548 0.866 0.868			K = K @ SPR1 Vel = 5.50

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION
465 CONGRESS TENTH FLOOR UPRIGHT

Page 5
Date 7/18/13

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
11A to 12	235.500 235.500		16.18 31.0	1 1.049		0.0 0.0	8.083 0.0	120 0.2928	9.282 0.0			
											Vel = 11.51	
12 to KK	235.500 229.500	5.39	18.41 49.41	1 1.049	2E	4.0 0.0	4.000 4.000	120 0.6935	11.649 2.599		K = K @ SPR1	
											Vel = 18.34	
KK to LL	229.500 229.500		0.0 49.41	1 1.101		0.0 0.0	8.417 0.0	150 0.3626	19.796 0.0			
											Vel = 16.65	
LL			0.0 49.41						22.848		K Factor = 10.34	
14 to 15	235.500 235.500	5.39	19.82 19.82	1 1.049		0.0 0.0	11.167 0.0	120 0.1280	13.503 0.0		K = K @ SPR1	
											Vel = 7.36	
15 to LL	235.500 229.500	5.39	20.84 40.66	1 1.049	1E 1T	2.0 5.0	4.000 7.000	120 0.4834	14.932 2.599		K = K @ SPR1	
											Vel = 15.09	
LL to M	229.500 229.500		49.41 90.07	1 1.101	1T	9.563 0.0	7.833 9.562	150 1.1011	22.848 0.0			
											Vel = 30.35	
M			0.0 90.07						42.002		K Factor = 13.90	
C to B	229.500 229.500		-32.96 -32.96	1.5 1.598		0.0 0.0	0.500 0.0	150 -0.0280	42.953 0.0			
											Vel = 5.27	
B to M	229.500 229.500		0.0 -32.96	1.5 1.598	1E	5.828 0.0	27.708 5.828	150 -0.0279	42.939 0.0			
											Vel = 5.27	
M to JJ	229.500 229.500		90.07 57.11	1.5 1.598	1T	11.656 0.0	32.875 11.656	150 0.0772	42.002 0.0			
											Vel = 9.14	
JJ to H	229.500 229.500		0.0 57.11	1.5 1.598	1T	11.656 0.0	17.208 11.656	150 0.0772	45.442 0.0			
											Vel = 9.14	
H			0.0 57.11						47.671		K Factor = 8.27	
C to 6A	229.500 229.500		32.96 32.96	1.5 1.598	1T	11.656 0.0	6.792 11.656	150 0.0279	42.953 0.0			
											Vel = 5.27	
6A to D	229.500 229.500		0.0 32.96	1.5 1.598		0.0 0.0	6.000 0.0	150 0.0280	43.468 0.0			
											Vel = 5.27	
D to E	229.500 229.500		0.0 32.96	1.5 1.598	1T	11.656 0.0	17.792 11.656	150 0.0279	43.636 0.0			
											Vel = 5.27	
E to F	229.500 229.500		0.0 32.96	1.5 1.598	1T	11.656 0.0	34.875 11.656	150 0.0279	44.458 0.0			
											Vel = 5.27	

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION
465 CONGRESS TENTH FLOOR UPRIGHT

Page 6
Date 7/18/13

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
F to G	229.500 229.500		0.0 32.96	1.5 1.598	1E 1T	5.828 11.656	34.000 17.484	150	45.758 0.0			
						0.0	51.484	0.0280	1.439	Vel =	5.27	
G to H	229.500 229.500		0.0 32.96	1.5 1.598	1T	11.656 0.0	5.333 11.656	150	47.197 0.0			
						0.0	16.989	0.0279	0.474	Vel =	5.27	
H to HH	229.500 229.500		57.11 90.07	2.5 2.635		0.0 0.0	3.625 3.625	120	47.671 0.0			
						0.0	3.625	0.0237	0.086	Vel =	5.30	
HH to FCV	229.500 227.250		102.07 192.14	2.5 2.635	1S 1T 2E	19.22 16.474 16.474	13.167 52.168 65.335	120	47.757 0.974 6.300			Vel = 11.30
FCV to J	227.250 129.667		0.0 192.14	4 4.26	1T	26.334 0.0	99.834 26.334	120	55.031 42.263			Vel = 4.33
J to K	129.667 107.167		0.0 192.14	4 4.26	8E	105.337 0.0	54.250 105.337	120	98.466 9.745			Vel = 4.33
K to L	107.167 107.167		0.0 192.14	4 4.26	1E	13.167 0.0	22.500 13.167	120	109.694 0.0			Vel = 4.33
L to BFP	107.167 93		0.0 192.14	6 6.357	3E	52.808 0.0	41.250 52.808	120	110.025 6.136			Vel = 1.94
BFP to PO	93 93		0.0 192.14	6 6.357	1Zac 1S 1B	0.0 40.235 12.573	10.000 52.808 62.808	120	116.285 3.096 0.084		** Fixed Loss = 3.096	Vel = 1.94
PO			0.0 192.14						119.465		K Factor = 17.58	
System Demand Pressure									119.465			
Safety Margin									56.436			
Continuation Pressure									175.901			
Pressure @ Pump Outlet									175.901			
Pressure From Pump Curve									-95.614			
Pressure @ Pump Inlet									80.287			
PI to BASE	93 93		0.0 192.14	6 6.357	1G 1T 6E	3.772 37.72 105.616	74.958 147.108 222.066	120	80.287 0.0 0.293			Vel = 1.94
BASE to TEST	93 100		0.0 192.14	6 6.16	1L 1G 1T	12.911 4.304 43.037	50.000 60.252 110.252	140	80.580 -3.032 0.128			Vel = 2.07
TEST			100.00 292.14						77.676		Qa = 100.00 K Factor = 33.15	