TECHNICAL NOTES:

1. LOWER EXISTING MANUAL PULL STATION TO 48" AFF.
2. PROVIDE CONTROL MODULE FOR RELEASE OF MAGNETIC DOOR HOLDER.



KEY PLAN

LEGEND:

E	EXISTING TO REMAIN
ER	EXISTING RELOCATED
NR	NEW TO REPLACE EXISTING IN EXISTING LOCATION
R	EXISTING TO BE REMOVED
RR	REMOVE & RELOCATE EXISTING
	FIRE ALARM HORN / LIGHT
	MULTI-CANDLA STROBE
	MULTI-CANDELA SPEAKER/STROBE
	CEILING MOUNTED MULTI-CANDELA SPEAKER/STROBE
HT	FIRE ALARM SYSTEM CEILING MOUNTED HEAT DETECTOR - "EL" FOR ELEVATOR SHUNT TRIP
SD	FIRE ALARM SYSTEM CEILING MOUNTED SMOKE DETECTOR - "EL" FOR ELEVATOR RECALL
F	WALL MOUNTED FIRE ALARM SYSTEM MANUAL PULL STATION
K	KNOX BOX
J	JUNCTION BOX
	DOOR HOLD-OPEN DEVICE CONNECTION
PS	FIRE ALARM SYSTEM/SPRINKLER SYSTEM PRESSURE SWITCH
FS	FIRE ALARM SYSTEM/SPRINKLER SYSTEM FLOW SWITCH
TS	FIRE ALARM SYSTEM/SPRINKLER SYSTEM TAMPER SWITCH
SD	FIRE ALARM SYSTEM DUCT MOUNTED SMOKE DETECTOR
FACP	FIRE ALARM SYSTEM CONTROL PANEL
FAA	FIRE ALARM ANNUNCIATOR
	GAS SHUT-OFF
EX RT	RADIO TRANSMITTER BOX
MM	MONITOR MODULE
RT	TEST STATION
RM	RELAY MODULE
	ANSUL GAS TANK
AMP	FIRE ALARM AMPLIFIER

REV.	DESCRIPTION	DATE
--	-- --	-- --
--	-- --	-- --
--	-- --	-- --
0	ISSUED FOR BID	06.12.15

ISSUED FOR BID
06.12.15
CURRENT ISSUE STATUS:

STATE OF MAINE STEPHANIE J. LAPLANT No.10272 LICENSED PROFESSIONAL ENGINEER
06.12.15

WBRC
ARCHITECTS• ENGINEERS
WWW.WBRCAE.COM
BANGOR, MAINE 207-947-4511
PORTLAND, MAINE 207-828-4511
SARASOTA, FLORIDA 941-556-0757

PORTLAND HIGH SCHOOL
FIRE ALARM UPGRADES

PROJECT: PORTLAND, ME

FIRST FLOOR - SEG. B FIRE ALARM PLAN

SHEET TITLE:
WBRC CAD FILE: 404100 – FA102B
PROJECT No. 404100
GRAPHIC SCALE: 0" 1"
SCALE: AS NOTED
PROJECT MANAGER: SJL
SHEET No. FA102B
DRAWN BY: KRM
CHECKED BY: SJL

© COPYRIGHT 2015 WBRC

A1	FIRST FLOOR - SEG. B FIRE ALARM PLAN
1/8" = 1'-0"	--

6/16/2015 2:42 PM I:\404\~404100 PORTLAND HIGH SCHOOL FIRE ALARM SYSTEM\2 DESIGN\DWGS\BLDG\PORTLAND SCHOOL EXISTING DRAWINGS\SHEETS\FA102B FIRST FLOOR - SEG. B FIRE ALARM PLAN.DWG KYLE.MAHAR