TECHNICAL NOTES:

1. UTILIZE EXISTING JUNCTION BOX AT T FOR NEW F/A DEVICE.
2. REMOVE EXISTING CONDUCTOR FROI JUNCTION BOX. JUNCTION BOX AND PATHWAY SHALL BE REUSED FOR NEW DEVICE AND CONDUCTORS.
3. LOWER EXISTING MANUAL PULL STATION TO 48" AFF.
4. PROVIDE CONTROL MODULE FOR RELEASE OF MAGNETIC DOOR HOLDER.
5. MAINTAIN EXISTING SPRINKLER FLOW, TAMPER AND/OR PRESSURE SWITCHES WITHIN THIS SPACE. INSTALL MONITOR MODULES AS REQUIRED TO CONNECT TO FIRE ALARM SYSTEM.

Reviewed for Code Compliance
Fire Prevention Division
Approved with Conditions
Date: 07/29/15

KEY PLAN

LEGEND:

E	EXISTING TO REMAIN
ER	EXISTING RELOCATED
NR	NEW TO REPLACE EXISTING IN EXISTING LOCATION
R	EXISTING TO BE REMOVED
RR	REMOVE & RELOCATE EXISTING
	FIRE ALARM HORN / LIGHT
	MULTI-CANDLA STROBE
	MULTI-CANDELA SPEAKER/STROBE
	CEILING MOUNTED MULTI-CANDELA SPEAKER/STROBE
	FIRE ALARM SYSTEM CEILING MOUNTED HEAT DETECTOR - "EL" FOR ELEVATOR SHUNT TRIP
	FIRE ALARM SYSTEM CEILING MOUNTED SMOKE DETECTOR - "EL" FOR ELEVATOR RECALL
	WALL MOUNTED FIRE ALARM SYSTEM MANUAL PULL STATION
	KNOX BOX
	JUNCTION BOX
	DOOR HOLD-OPEN DEVICE CONNECTION
	FIRE ALARM SYSTEM/SPRINKLER SYSTEM PRESSURE SWITCH
	FIRE ALARM SYSTEM/SPRINKLER SYSTEM FLOW SWITCH
	FIRE ALARM SYSTEM/SPRINKLER SYSTEM TAMPER SWITCH
	FIRE ALARM SYSTEM DUCT MOUNTED SMOKE DETECTOR
FACP	FIRE ALARM SYSTEM CONTROL PANEL
FAA	FIRE ALARM ANNUNCIATOR
	GAS SHUT-OFF
EX RT	RADIO TRANSMITTER BOX
MM	MONITOR MODULE
RT	TEST STATION
RM	RELAY MODULE
	ANSUL GAS TANK
AMP	FIRE ALARM AMPLIFIER

REV.	DESCRIPTION	DATE
--	--	--
--	--	--
--	--	--
0	ISSUED FOR BID	06.12.15

ISSUED FOR BID
06.12.15
CURRENT ISSUE STATUS:

STATE OF MAINE
STEPHANIE J. LAPLANT
No.10272
LICENSED PROFESSIONAL ENGINEER
06.12.15

WBRC
ARCHITECTS• ENGINEERS
WWW.WBRCAE.COM
BANGOR, MAINE 207-947-4511
PORTLAND, MAINE 207-828-4511
SARASOTA, FLORIDA 941-556-0757

PROJECT: PORTLAND HIGH SCHOOL FIRE ALARM UPGRADES
PORTLAND, ME

SHEET TITLE: SECOND FLOOR - SEG. A FIRE ALARM PLAN

WBRC CAD FILE:	404100 – FA103A
PROJECT No.	404100
SCALE:	AS NOTED
PROJECT MANAGER:	SJL
DRAWN BY:	KRM
CHECKED BY:	SJL
GRAPHIC SCALE:	0" 1"
SHEET No.	FA103A

© COPYRIGHT 2015 WBRC

A1	SECOND FLOOR - SEG. A FIRE ALARM PLAN
1/8" = 1'-0"	--

6/16/2015 2:42 PM U:\404100-4100\404100 PORTLAND HIGH SCHOOL FIRE ALARM SYSTEM\2 DESIGN\DWGS\BLDG\PORTLAND SCHOOL EXISTING DRAWINGS\SHEETS\FA103A SECOND FLOOR - SEG. A FIRE ALARM PLAN.DWG KYLE.MAHAR