GENERAL NOTES:

1. MAJORITY OF ATTIC IS NOT SPRINKL
ALARM ACTIVATION BY AUTOMATIC
DEVICES (HEAT DETECTORS) IS RE
SPRINKLERS DO NOT EXIST.

Reviewed for Code Compliance
Inspectional Services Division
Approved with Conditions
Date: 07/29/15

TECHNICAL NOTES:

(1) DUCT SMOKE DETECTORS ARE NOTED DIAGRAMMATICALLY IN THIS SPACE. REPLACE EXISTING DUCT SMOKE DETECTOR WITH A NEW DEVICE. CONTRACTOR SHALL FIELD VERIFY THE EXACT LOCATION OF EACH EXISTING DETECTOR. IF 120V POWER IS REQUIRED, CONNECT TO NEARBY RECEPTACLE CIRCUIT.

KEY PLAN

LEGEND:

E	EXISTING TO REMAIN
ER	EXISTING RELOCATED
NR	NEW TO REPLACE EXISTING IN EXISTING LOCATION
R	EXISTING TO BE REMOVED
RR	REMOVE & RELOCATE EXISTING
	FIRE ALARM HORN / LIGHT
	MULTI-CANDLA STROBE
	MULTI-CANDELA SPEAKER/STROBE
	CEILING MOUNTED MULTI-CANDELA SPEAKER/STROBE
	FIRE ALARM SYSTEM CEILING MOUNTED HEAT DETECTOR - "EL" FOR ELEVATOR SHUNT TRIP
	FIRE ALARM SYSTEM CEILING MOUNTED SMOKE DETECTOR - "EL" FOR ELEVATOR RECALL
	WALL MOUNTED FIRE ALARM SYSTEM MANUAL PULL STATION
	KNOX BOX
	JUNCTION BOX
	DOOR HOLD-OPEN DEVICE CONNECTION
	FIRE ALARM SYSTEM/SPRINKLER SYSTEM PRESSURE SWITCH
	FIRE ALARM SYSTEM/SPRINKLER SYSTEM FLOW SWITCH
	FIRE ALARM SYSTEM/SPRINKLER SYSTEM TAMPER SWITCH
	FIRE ALARM SYSTEM DUCT MOUNTED SMOKE DETECTOR
FACP	FIRE ALARM SYSTEM CONTROL PANEL
FAA	FIRE ALARM ANNUNCIATOR
	GAS SHUT-OFF
EX RT	RADIO TRANSMITTER BOX
MM	MONITOR MODULE
RT	TEST STATION
RM	RELAY MODULE
	ANSUL GAS TANK
AMP	FIRE ALARM AMPLIFIER

REV.	DESCRIPTION	DATE
--	--	--
--	--	--
--	--	--
0	ISSUED FOR BID	06.12.15

ISSUED FOR BID

06.12.15

CURRENT ISSUE STATUS:

STATE OF MAINE STEPHANIE J. LAPLANT No.10272 LICENSED PROFESSIONAL ENGINEER

06.12.15

WBRC
ARCHITECTS• ENGINEERS
WWW.WBRCAE.COM
BANGOR, MAINE 207-947-4511
PORTLAND, MAINE 207-828-4511
SARASOTA, FLORIDA 941-556-0757

PORTLAND HIGH SCHOOL
FIRE ALARM UPGRADES

PROJECT: PORTLAND, ME

ATTIC - SEG. B FIRE ALARM PLAN

SHEET TITLE:

WBRC CAD FILE:	404100 – FA105B
PROJECT No.	404100
SCALE:	AS NOTED
PROJECT MANAGER:	SJL
DRAWN BY:	KRM
CHECKED BY:	SJL

GRAPHIC SCALE: 0" 1"

SHEET No. FA105B

© COPYRIGHT 2015 WBRC

A1	ATTIC - SEG. B FIRE ALARM PLAN
1/8" = 1'-0"	--

6/16/2015 2:43 PM I:\4001-4100\404100 PORTLAND HIGH SCHOOL FIRE ALARM SYSTEM\2 DESIGN\DWGS\BLDG\PORTLAND SCHOOL EXISTING DRAWINGS\SHEETS\FA105B ATTIC - SEG. B FIRE ALARM PLAN.DWG KRLE,MAHAR