



Water-Based Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Installation address: 443 CONGRESS ST. CBL: 027 3002

Exact location: (within structure) 5TH FLOOR

Type of occupancy(s) (NFPA & ICC): NFPA 13 - OFFICE SPACE

Building owner: JSR 443 CONGRESS ST - C/O NORTHLAND ENTERPRISES - 1 CITY CENTER 4TH FL.

Managing Supervisor (RMS): 273 License No: 102

Supervisor phone: 998-2551 E-mail: BSTILLAIRE@FAIRPOINT.ME

Installing contractor: HIGH TECH FIRE PROTECTION License No: 102

Contractor phone: 998-2551 E-mail: BSTILLAIRE@FAIRPOINT.ME

The suppression work to be done will be: New: Renovation: Addition to existing system:

This is an amendment to an existing permit: Yes: NO: Permit no: _____

NFPA Standard this system is designed to: NFPA 13 Edition: 2007

*Non-NFPA systems are not approved for use within the City of Portland.

Download a new copy of this document from www.portlandmaine.gov/fire for every submittal. Attach all working documents and complete approved submittals as may be required by the State Fire Marshal's Office on electronic PDF's in addition to full sized plans.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

COST OF WORK: \$ 36,000.00
PERMIT FEE: \$ 380.00
(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)

PLEASE CALL FOR
UM CREDIT CARD #
998-2551

THANKS BRYAN ST. ILLAIRE

5/18 ~~AK~~
Send me call
back w / credit
card #
Gayb
Second message

ions Department.
item, a complete
rtment, and prop
nd the Fire Dep
Hilari

5/23/11
Pd by CC
today
5/23/11 66

ted with
by
Maine
[]

High Tech Fire Protection

Po Box 156 Minot, Maine 04258-0156

Tel: 207-998-2551

Fax: 207-998-4187

To: Portland City hall
389 Congress St Room 315
Portland, ME. 04101

Letter of Transmittal

Date: May 4, 2011	Job No.
Attention:	
Re:	

We are sending you Attached under separate cover Via _____ the following items.

- Shop dwgs Prints Plans Samples Specifications
 Copy of letter Change order _____

Copies	Date	No.	Description
1		FP01	Fire Sprinkler Drawing
1			Hydraulic Calculation print out
1			State Fire Marshals Sprinkler Permit
1			City of Portland fire sprinkler permit application

These are Transmitted as checked below:

- For Approval For your use Return_____ Permit
 As requested For review and comment Return Approved Set

Comments:

If you have any questions please call.

Thank You, Bryan St.Hilaire

Signed: _____

RECEIVED
MAY 10 2011
Dept. of Building Inspections
City of Portland Maine



State of Maine
 Department of Public Safety
Fire Sprinkler System Permit



9487

Clapp Building 5th Floor

Located at: 443 Congress St
 In the Town of: Portland
 Occupancy/Use: Office
 Type of System: NFPA 13

Permission is hereby given to:

High Tech Fire Protection Co., Inc.
 PO Box 156
 Minot, ME 042580156
 Contractor License # 102

to begin installation according to plans submittal approved by the Office of State Fire Marshal. The submittal is filed under log # **2111141**, and no departure from the application submittal shall be made without prior approval in writing. This permit is issued under the provisions of Title 32, Chapter 20, Section 12004-I. Nothing herein shall excuse the holder of this permit from failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions. This permit shall be displayed at the construction site or be made readily available.

This permit was issued on **4/30/2011** for a fee paid of **\$100.00**

*This permit will expire at midnight on **Thursday, October 27, 2011***

The expiration date applies only if the installation has not begun by that date and no permission has been granted to extend the date. Once installation begins, then the permit is valid for however long it takes to complete the installation, assuming that the work is fairly continuous.

John E. Morris
 Commissioner


The type of Fire Department Connection and its location is to be according to the Local Fire Department

Within 30 days of the completion of a new fire sprinkler system or an addition to an existing fire sprinkler system, a fire sprinkler system contractor shall provide to the Office of State Fire Marshal a copy of this permit signed and dated by the certified Responsible Managing Supervisor representing that the fire sprinkler system has been installed according to specifications of the approved plan to the best of the supervisor's knowledge, information, and belief. This requirement is part of the sprinkler law, and neglect of this duty is grounds to not renew the contractor's license to do work in the State of Maine. All renewed sprinkler licenses are good for two years and expire on a June 30th.

Job completed, tested and verified by date of _____

RMS for this job: Labonte Linda C.

RMS Signature: _____



... Fire Protection by Computer Design

HIGH TECH FIRE PROTECTION
84 HACKETT MILLS ROAD
POLAND, ME 04274
998-2551

Job Name	Clapp Building 5th floor
Building	
Location	443 Congress St - Portland, ME
System	NFPA 13
Contract	
Data File	5th floor.wx1

Hydraulic Design Information Sheet

Name - Clapp Building 5th floor Date - 4/26/2011
 Location - 443 Congress St - Portland, ME
 Building - System No. - NFPA 13
 Contractor - Development Services of NE Contract No. -
 Calculated By - High Tech Fire Protection Drawing No. -
 Construction: () Combustible (X) Non-Combustible Ceiling Height - 8 ft
 Occupancy - Office Space

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other
 T Specific Ruling Made By Date

E
 M Area of Sprinkler Operation - 900 SQ FT System Type Sprinkler/Nozzle
 Density - .1 (X) Wet Make Globe
 D Area Per Sprinkler - 196 () Dry Model GL 5601
 E Elevation at Highest Outlet - 50 FT () Deluge Size 1/2"
 S Hose Allowance - Inside - () Preaction K-Factor 5.6
 I Rack Sprinkler Allowance - () Other Temp.Rat.155
 G Hose Allowance - Outside - 100
 N

Note

Calculation Flow Required - 157 gpm Press Required - 50 psi
 Summary C-Factor Used: 120 Overhead 100 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 8/2009 Cap. -
 T Time of Test - Rated Cap.- Elev.-
 E Static Press - 76 @ Press -
 R Residual Press - 74 Elev. - Well
 Flow - 2250 Proof Flow
 S Elevation - 0

U
 P Location - Hydrant #460 - Congress St Portland

P
 L Source of Information - Portland Water Dist
 Y

C Commodity Class Location
 O Storage Ht. Area Aisle W.
 M Storage Method: Solid Piled % Palletized % Rack
 M
 () Single Row () Conven. Pallet () Auto. Storage () Encap.
 S R () Double Row () Slave Pallet () Solid Shelf () Non
 T A () Mult. Row () Open Shelf

O C
 R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse
 G

E Horizontal Barriers Provided:


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
Clapp Building 5th floor

Page 2
Date 4/26/2011

City Water Supply:
C1 - Static Pressure 76
C2 - Residual Pressure: 74
C2 - Residual Flow 2250

Demand:
D1 - Elevation 21.655
D2 - System Flow 157.51
D2 - System Pressure 50.098
Hose (Adj City) _____
Hose (Demand) 100
D3 - System Demand 257.51
Safety Margin 25.866



Fittings Used Summary

HIGH TECH FIRE PROTECTION
Clapp Building 5th floor

Page 3
Date 4/26/2011

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	Generic Swing Check Vlv	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
Clapp Building 5th floor

Page 4
Date 4/26/2011

Node No	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
50	50.0	5.6	12.25	na	19.6	0.1	196	7.0
51	50.0	5.6	12.03	na	19.43	0.1	150	7.0
52	50.0	5.6	12.39	na	19.71	0.1	168	7.0
53	50.0	5.6	12.03	na	19.42	0.1	10	7.0
55	50.0	5.6	12.77	na	20.01	0.1	168	7.0
56	50.0	5.6	12.28	na	19.63	0.1	168	7.0
57	50.0	5.6	12.13	na	19.51	0.1	168	7.0
58	50.0	5.6	13.02	na	20.2	0.1	196	7.0
A	50.0		13.63	na				
B	50.0		13.64	na				
C	50.0		13.78	na				
D	50.0		13.84	na				
E	50.0		13.87	na				
F	50.0		13.88	na				
G	50.0		13.94	na				
H	50.0		14.04	na				
I	50.0		14.24	na				
J	50.0		14.34	na				
500	50.0		18.07	na				
ZONE	10.0		43.93	na				
TOR	0.0		49.12	na				
BOR	0.0		49.47	na	100.0			
HOSE	0.0		49.63	na				
100	0.0		50.09	na				
TEST	0.0		50.1	na				

The maximum velocity is 13.83 and it occurs in the pipe between nodes 500 and ZONE

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
Clapp Building 5th floor

Page 5
Date 4/26/2011

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
50 to A	19.60 19.6	1.049 120 0.1254	1E 1T	2.0 5.0 0.0	4.000 7.000 11.000	12.250 0.0 1.379			K Factor = 5.60 Vel = 7.28	
	0.0 19.60						13.629		K Factor = 5.31	
51 to B	19.43 19.43	1.049 120 0.1233	1E 1T	2.0 5.0 0.0	6.000 7.000 13.000	12.033 0.0 1.603			K Factor = 5.60 Vel = 7.21	
	0.0 19.43						13.636		K Factor = 5.26	
52 to C	19.71 19.71	1.049 120 0.1267	1E 1T	2.0 5.0 0.0	4.000 7.000 11.000	12.390 0.0 1.394			K Factor = 5.60 Vel = 7.32	
	0.0 19.71						13.784		K Factor = 5.31	
53 to F	19.42 19.42	1.049 120 0.1233	1E 1T	2.0 5.0 0.0	8.000 7.000 15.000	12.031 0.0 1.849			K Factor = 5.60 Vel = 7.21	
	0.0 19.42						13.880		K Factor = 5.21	
55 to G	20.01 20.01	1.049 120 0.1302	1E 1T	2.0 5.0 0.0	2.000 7.000 9.000	12.771 0.0 1.172			K Factor = 5.60 Vel = 7.43	
	0.0 20.01						13.943		K Factor = 5.36	
56 to H	19.63 19.63	1.049 120 0.1256	1E 1T	2.0 5.0 0.0	7.000 7.000 14.000	12.283 0.0 1.759			K Factor = 5.60 Vel = 7.29	
	0.0 19.63						14.042		K Factor = 5.24	
57 to I	19.51 19.51	1.049 120 0.1242	1E 1T	2.0 5.0 0.0	10.000 7.000 17.000	12.132 0.0 2.112			K Factor = 5.60 Vel = 7.24	
	0.0 19.51						14.244		K Factor = 5.17	
58 to J	20.20 20.2	1.049 120 0.1326	1E 1T	2.0 5.0 0.0	3.000 7.000 10.000	13.017 0.0 1.326			K Factor = 5.60 Vel = 7.50	
	0.0 20.20						14.343		K Factor = 5.33	
A to B	19.60 19.6	2.157 120 0.0035		0.0 0.0 0.0	2.000 0.0 2.000	13.629 0.0 0.007			Vel = 1.72	
B to C	19.43 19.43	2.157 120 0.0135		0.0 0.0 0.0	11.000 0.0 11.000	13.636 0.0 0.148			Vel = 3.43	
C to D	39.03 19.71 58.74	2.157 120 0.0285		0.0 0.0 0.0	2.000 0.0 2.000	13.784 0.0 0.057			Vel = 5.16	

Final Calculations - Standard

HIGH TECH FIRE PROTECTION
Clapp Building 5th floor

Page 6
Date 4/26/2011

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
D to E	-43.85 14.89	2.157 120	1T	12.307	2.000 12.307	13.841 0.0				
E to F	0.0 14.89	2.157 120		0.0	3.000 0.0	13.873 0.0			Vel = 1.31	
F to G	19.43 34.32	2.157 120		0.0	6.000 6.000	13.880 0.063			Vel = 1.31	
G to H	20.01 54.33	2.157 120		0.0	4.000 0.0	13.943 0.0			Vel = 3.01	
H to 500	19.62 73.95	2.157 120	2E	12.307	80.000 12.307	14.042 0.0			Vel = 4.77	
	0.0 73.95	0.0437		0.0	92.307	4.033			Vel = 6.49	
						18.075			K Factor = 17.39	
D to I	43.84 43.84	2.157 120	1T	12.307	12.000 12.307	13.841 0.0				
I to J	19.51 63.35	2.157 120		0.0	3.000 0.0	14.244 0.0			Vel = 3.85	
J to 500	20.20 83.55	2.157 120	1E	6.153	62.000 6.153	14.343 0.0			Vel = 5.56	
	0.0 83.55	0.0548		0.0	68.153	3.732			Vel = 7.34	
						18.075			K Factor = 19.65	
500 to ZONE	157.51 157.51	2.157 120	2E 1G 1S 1Z	12.307 1.231 13.537 6.153	15.000 33.228 48.228	18.075 17.324 8.533				
ZONE to TOR	0.0 157.51	4.26 120	4E	52.668	80.000 52.668	43.932 4.331			Vel = 13.83	
TOR to BOR	157.51 0.0	0.0064 4.26	1G 1S 1Z	2.633 28.968 13.167	10.000 44.768 54.768	49.117 0.0 0.352			Vel = 3.55	
BOR to HOSE	100.00 257.51	6.14 100	1E 1G	10.608 2.273	30.000 12.881	49.469 0.0			Qa = 100	
HOSE to 100	257.51 0.0	0.0038 6.14	1T	22.732	42.881 100.000	0.162 49.631			Vel = 2.79	
100 to 100	257.51 0.0	0.0038 16.32	1T	87.173	22.732 87.174	0.0 50.094			Vel = 2.79	
100 to TEST	257.51 0.0	0.0		0.0	117.174	0.004			Vel = 0.39	

Final Calculations - Standard

HIGH TECH FIRE PROTECTION
 Clapp Building 5th floor

Page 7
 Date 4/26/2011

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
-----------------------	--------------	----------------------	---------------------------	-------------------------	----------------	----------------	-------	-------	-------

257.51 50.098 K Factor = 36.38