

**. . . Fire Protection by Computer Design**

Residential Fire Protection  
64 Daggett Hill Rd.  
Greene, ME 04236  
946-3473

Job Name : 443 Congress Street Bldg  
Building : STEEL/ CONCRETE STRUCTURE  
Location : 7TH FLOOR  
System : 1  
Contract : C17009  
Data File : 443 Congress St Bldg-7th Flr Hyd Calc.WXF

Hydraulic Design Information Sheet

Name - 443 CONGRESS ST BLDG Date - 5/10/2017  
 Location - 7TH FLOOR  
 Building - STEEL/ CONCRETE STRUCTURE System No. - 1  
 Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - C17009  
 Calculated By - T. PRAY Drawing No. - 1 OF 2  
 Construction: ( ) Combustible (X) Non-Combustible Ceiling Height - 9'-11"  
 Occupancy - RESIDENTIAL APARTMENTS

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other RESIDENTIAL SPRINKLERS

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 4 SPRK'S	System Type	Sprinkler/Nozzle
	Density	- .0508	(X) Wet	Make VIKING
D	Area Per Sprinkler	- 256	( ) Dry	Model VK486
E	Elevation at Highest Outlet	- 77.58	( ) Deluge	Size 7/16"
S	Hose Allowance - Inside	- 50	( ) Preaction	K-Factor 4.0
I	Rack Sprinkler Allowance	-	( ) Other	Temp.Rat.155
G	Hose Allowance - Outside	- 50		

N Note

Calculation Flow Required - 108.91 Press Required - 73.95 AT BOR  
 Summary C-Factor Used: 150 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 7/6/2016		Cap. -
T	Time of Test - N/A	Rated Cap.-	Elev.-
E	Static Press - 84	@ Press -	
R	Residual Press - 78	Elev. -	Well
S	Flow - 1363		Proof Flow
U	Elevation - -17.0'		

P Location - HYDRANTS ARE LOCATED ON CUMBERLAND AVE BEHIND BLDG, SEE PLOT PLAN

L Source of Information - PORTLAND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T	( ) Mult. Row		( ) Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

E Horizontal Barriers Provided:

# Water Supply Curve (C)

Residential Fire Protection  
443 Congress Street Bldg


Page 2  
Date 5/10/2017

### City Water Supply:

C1 - Static Pressure : 84  
C2 - Residual Pressure: 78  
C2 - Residual Flow : 1363

### Demand:

D1 - Elevation : 40.963  
D2 - System Flow : 58.909  
D2 - System Pressure : 77.611  
Hose ( Adj City ) : \_\_\_\_\_  
Hose ( Demand ) : 100  
D3 - System Demand : 158.909  
Safety Margin : 6.276



# Fittings Used Summary

Residential Fire Protection  
443 Congress Street Bldg

Page 3  
Date 5/10/2017

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
F	45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
N	CPVC 90'Ell Harvel-Spears	7	7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
R	CPVC Coupling Tee - Run	1	1	1	1	1	1	2	2	0	0	0	0	0	0	0	0	0	0	0	0
S	Generic Swing Check Valve	4	5	5	7	9	11	14	16	19	22	27	32	45	55	65	76	87	98	109	130
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

# Pressure / Flow Summary - STANDARD

Residential Fire Protection  
443 Congress Street Bldg

Page 4  
Date 5/10/2017

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	77.58	4	10.6	na	13.02	0.0508	256	10.6
2	76.17	4.9	11.39	na	16.54	0.0508	256	7.0
10	76.75		12.42	na				
3	77.58	4	12.91	na	14.37	0.0508	256	10.6
11	76.75		14.82	na				
4	77.58	4	14.02	na	14.98	0.0508	256	10.6
12	76.75		16.91	na				
13	76.75		24.28	na				
14	76.75		28.08	na				
15	76.75		29.31	na				
16	76.75		32.05	na				
HSV	76.75		32.05	na	50.0			
TOR	-2.0		66.89	na				
BOR	-9.0		73.95	na				
CITY	-9.0		73.99	na	50.0			
TEST	-17.0		77.61	na				

The maximum velocity is 15.81 and it occurs in the pipe between nodes 10 and 11

# Final Calculations - Hazen-Williams

Residential Fire Protection  
443 Congress Street Bldg

Page 5  
Date 5/10/2017

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1 to 10	13.02	0.874 150	1N 1O	7.0 3.0	5.370 10.000	10.600 0.359			K Factor = 4.00	
	13.02	0.0947		0.0	15.370	1.456			Vel = 6.96	
	0.0 13.02						12.415		K Factor = 3.70	
2 to 10	16.54	0.874 150	1N 1R	7.0 1.0	0.670 8.000	11.389 -0.251			K Factor = 4.90	
	16.54	0.1473		0.0	8.670	1.277			Vel = 8.85	
10 to 11	13.02	0.874 150	1R	1.0 0.0	4.580 1.000	12.415 0.0				
	29.56	0.4315		0.0	5.580	2.408			Vel = 15.81	
	0.0 29.56						14.823		K Factor = 7.68	
3 to 11	14.37	0.874 150	1N 1O	7.0 3.0	3.670 10.000	12.910 0.359			K Factor = 4.00	
	14.37	0.1137		0.0	13.670	1.554			Vel = 7.68	
11 to 12	29.56	1.101 150	2R	2.0 0.0	5.170 2.000	14.823 0.0				
	43.93	0.2918		0.0	7.170	2.092			Vel = 14.80	
	0.0 43.93						16.915		K Factor = 10.68	
4 to 12	14.98	0.874 150	2N 1O	14.0 3.0	3.670 17.000	14.020 0.359			K Factor = 4.00	
	14.98	0.1227		0.0	20.670	2.536			Vel = 8.01	
12 to 13	43.93	1.598 150	14R 3O	14.0 24.0	52.040 38.000	16.915 0.0				
	58.91	0.0818		0.0	90.040	7.366			Vel = 9.42	
13 to 14	0.0	1.598 150	4R 1O	4.0 8.0	34.500 12.000	24.281 0.0				
	58.91	0.0818		0.0	46.500	3.804			Vel = 9.42	
14 to 15	0.0	1.61 150	2R 1N	2.0 9.0	4.500 11.000	28.085 0.0				
	58.91	0.0788		0.0	15.500	1.222			Vel = 9.28	
15 to 16	0.0	1.61 150	1Z 1S	6.044 13.6	3.000 31.733	29.307 0.0				
	58.91	0.0789	1T	12.089	34.733	2.740			Vel = 9.28	
16 to HSV	0.0	4.26 120		0.0 0.0	4.000 0.0	32.047 0.0				
	58.91	0.0010		0.0	4.000	0.004			Vel = 1.33	
HSV to TOR	50.00	4.26 120	8V 1X	71.629 21.067	100.000 124.297	32.051 34.107			Qa = 50	
	108.91	0.0033	1T 1F	26.334 5.267	224.297	0.729			Vel = 2.45	
TOR to BOR	0.0	4.26 120	1F	5.267 0.0	5.000 5.267	66.887 7.032			* Fixed loss = 4	
	108.91	0.0032		0.0	10.267	0.033			Vel = 2.45	
BOR to CITY	0.0	6.16 140	2L 1G	25.822 4.304	20.000 73.163	73.952 0.0				
	108.91	0.0004	1T	43.037	93.163	0.038			Vel = 1.17	

# Final Calculations - Standard

Residential Fire Protection  
443 Congress Street Bldg

Page 6  
Date 5/10/2017

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
CITY	50.00	8.27	1T	55.354	750.000	73.990		Qa = 50	
to		140		0.0	55.354	3.465			
TEST	158.91	0.0002		0.0	805.354	0.156		Vel = 0.95	
	0.0								
	158.91					77.611		K Factor = 18.04	