

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

WILLIAM J. DEVAN

Located at

21 CHESTNUT ST (Unit 204)

PERMIT ID: 2017-01124

ISSUE DATE: 09/22/2017

CBL: 027 C0102SE

has permission to **Remodel condo by constructing partitions to create bedroom and office.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.	A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
---	---

/s/ Greg Gilbert

Fire Official

/s/ Greg Gilbert

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Residential condominium unit

Building Inspections

Use Group: R-2, M, S **Type:** 1B

Mixed use Multifamily Condo

Condo unit

Non Sprinkled

occupant load existing to remain

ENTIRE

2009 IBC / MUBEC

Fire Department

PERMIT ID: 2017-01124

Located at: 21 CHESTNUT ST (Unit 204)

CBL: 027 C0102SE

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing
Electrical - Commercial
Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-01124	Date Applied For: 07/12/2017	CBL: 027 C0102SE
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same. Residential condo.		Proposed Project Description: Remodel condo by constructing partitions to create bedroom and office.		
Dept: Historic		Status: Approved w/Conditions	Reviewer: Deborah Andrews	Approval Date: 08/08/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Approved subject to the condition that project entails no exterior alterations, including exterior vents or mechanicals.				
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Christina Stacey	Approval Date: 07/31/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) This unit shall remain a residential condominium for single family use. Any change of use shall require a separate permit application for review and approval.				
2) This permit is not approving any lot coverage or setback requirements for the existing structure. It is approving interior work only.				
3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti		Status: Approved w/Conditions	Reviewer: Greg Gilbert	Approval Date: 09/22/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) 713.3 Fire-resistance-rated walls. Penetrations into or through fire walls, fire barriers, smoke barrier walls and fire partitions shall comply with Sections 713.3.1 through 713.3.3. Penetrations in smoke barrier walls shall also comply with Section 713.5.				
2) All construction shall comply with City Code Chapter 10. All smoke detectors and smoke alarms shall be photoelectric. Hardwired Carbon Monoxide alarms with battery backup are required on each floor. A sprinkler system is recommended but not required, unless existing building is sprinkled in which case sprinkler system is required.				
3) Separate permits are required for any electrical: plumbing, sprinkler, fire alarm, HVAC systems, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
4) Review and approval by the Authority having Jurisdiction shall not relieve the applicant of the responsibility of compliance with this Code				
5) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Engineering DPS		Status: Not Applicable	Reviewer: Rachel Smith	Approval Date: 07/24/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) This approval is non-applicable to Engineering DPW as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Works for any other reason than FOG, please contact 207-874-8801.				
Dept: Fire		Status: Approved w/Conditions	Reviewer: Greg Gilbert	Approval Date: 09/22/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				

PERMIT ID: 2017-01124

Located at: 21 CHESTNUT ST (Unit 204)

CBL: 027 C0102SE

1) Smoke Alarms

City of Portland Code Chapter 10 section 10-3 (i) all new single-station and or multiple-station smoke alarms shall be non-ionization (photoelectric) type. Smoke Alarms shall be installed per NFPA 101 2009 section 9.6.2.10. Detectors are required to be installed in the following locations

1. Inside all sleeping rooms.
2. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas
3. On each level of the dwelling unit, including basements but excluding attics and crawl spaces.

Fire extinguishers are required per NFPA 1 (2009 Edition) Table 13.6.2. The quantity, size, type and location shall be in accordance with NFPA 1, 13.6.8.

2) Carbon Monoxide Detectors

City of Portland Code Chapter 10 section 10-3 (L) all residential occupancies, and all new multiple occupancies containing attached parking structures or fuel burning appliances shall be protected in accordance with NFPA 720, Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment, 2009 edition. Detectors shall be provided in the following areas.

1. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas
2. On each level of the dwelling unit, including basements but excluding attics and crawl spaces.

3) General Conditions

All construction shall comply with City Code, Chapter 10.

All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 43

All construction shall comply with 2009 NFPA 1, Fire Code.

This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4).