

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that

BUDDE SCOTT & CHARLOTTE F COLE JTS/Great Falls
Construction

Located at

28 MONUMENT SQ

PERMIT ID: 2013-02473

ISSUE DATE: 11/20/2013

CBL: 027 F002001

has permission to **Converting approximately 280 SF of open space in unit #1 condo to a bedroom and family room**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

basement, 1st & 2nd floors = Public Market
3rd & 4th floors are two residential condos
total

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical Close-in w/Fire & Draftstopping

Above Ceiling Inspection

Final Inspection

Final - Electric

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2013-02473	Date Applied For: 11/04/2013	CBL: 027 F002001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: basement, 1st & 2nd floor = Public Market with two residential condos on upper floors		Proposed Project Description: Converting approximately 280 SF of open space in unit #1 condo to a bedroom and family room		
Dept: Historic Status: Not Applicable Reviewer: Robert Wiener Approval Date: 11/13/2013 Note: It is the understanding of historic preservation staff that no exterior alterations are included with this permit Ok to Issue: <input checked="" type="checkbox"/> application, and none are approved by this office. Conditions:				
<hr/> Dept: Zoning Status: Approved Reviewer: Marge Schmuckal Approval Date: 11/07/2013 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions:				