

Fire Department Requirements

Name: Aidalina Costoso

Address P.O. Box 10081

City, State, zip Portland ME 04104

Phone # (207) 409-0770 cell (207) 228-5444

Proposed use of: Public Market house space, currently used as seating space.
Structure To be used for food prep + sales.

Sq. footage of
proposed Structure: 138 sf

Existing + proposed: Space already occupied and fully sprinkled, alarmed
fire protection of with signs and fire extinguishers
Structure

Separate plans
shall be: a) Suppression system b) detection system (separate permit is required)
submitted for * This will be part of Hood + Vent permit

A separate life Safety Plan must include:
a) Fire resistance ratings of all means of egress
b) Travel distance from most remote point to exit discharge
c) Location of any required fire extinguishers
d) location of emergency lighting
e) location of exit signs
f) NFPA 101 code summary

* All of the above from A to F is already installed per.
occupancy for Seating