

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

28 MSQ LLC

Located at

28 MONUMENT SQ

PERMIT ID: 2014-01893

ISSUE DATE: 09/22/2014

CBL: 027 F002003

has permission to **Kiosk - Dominican food**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.	A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
---	--

/s/ Craig Messinger

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

basement, 1st & 2nd floors = Public
Market with multiple venues such as retail
and food services
3rd & 4th floors are two residential condos
total

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-01893	Date Applied For: 08/22/2014	CBL: 027 F002003
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Kiosk - Dominican food	Proposed Project Description: Kiosk - Dominican food			
<hr/>				
Dept: Historic	Status: Approved w/Conditions	Reviewer: Robert Wiener	Approval Date: 09/16/2014	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) No exterior alterations are approved with this permit. Any planned exterior work, including venting, must be reviewed and approved prior to start of construction.				
<hr/>				
Dept: Zoning	Status: Approved w/Conditions	Reviewer: Marge Schmuckal	Approval Date: 08/25/2014	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Separate permits shall be required for any new signage.				
<hr/>				
Dept: Building	Status: Approved w/Conditions	Reviewer: Laurie Leader	Approval Date: 09/16/2014	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Approval of city license is subject to the health inspectors per the Food Code.				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
<hr/>				
Dept: Engineering DPS	Status: Approved w/Conditions	Reviewer:	Approval Date: 09/19/2014	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) Stall to be placed within Public Market House. DPS will be approaching owner of Public Market House for a single grease control unit for all stalls. If not possible, individual stall may need to install grease control equipment on three bay sink.				
<hr/>				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 09/17/2014	Ok to Issue: <input checked="" type="checkbox"/>
Note:				
Conditions:				
1) The entire sprinkler system shall be maintained in accordance with NFPA 25, Standard for Inspection, Testing and Maintenance of Water-Based Fire Protection Systems, 2008 edition.				
2) All outstanding code violations shall be corrected prior to final inspection.				
3) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.				
4) Shall comply with NFPA 101, Chapter 37 Existing Mercantile Occupancies.				
5) Shall meet the requirements of 2009 NFPA 1 Fire Code				
6) All construction shall comply with City Code Chapter 10.				