

Kitchen Exhaust Checklist Page 2

Grease Gutters provided? yes

Hood Clearance reduction to Combustibles design /specs:
Min 18"

Duct Clearance reduction to Combustibles design /specs:
All interior duct wrap with Firemaster zero clearance

Vibration Isolation System:
—

Air Velocity within the duct system 1800 RPM

Grease accumulation prevention system:
yes

Cleanouts yes

Grease Duct enclosure Fire master

Exhaust Termination Roof — Wall X

Fire Suppression System yes

Exhaust fan mounting and clearance from the roof / wall or Combustibles:
10' min.

Exhaust fan distance from property lines 10'

Exhaust fan distance from other vents or openings —

Exhaust fan distance from adjacent buildings —

Exhaust fan height above adjoining grade —

Hood Specs

Style of Hood Low Profile

Type of Filter Baffle

Height of filter above nearest cooking surface 48" min.

Capacity of hood CFM 1100

Make up Air system description and capacity

using Building HVAC

no make up air for hood