

- TECHNICAL NOTES:**
- LIGHTING CONTROL SYSTEM TOUCHSCREEN - PROVIDE CAT. 5 TO DMX CONTROLLER IN ELEC. 009. REFER TO DETAIL A7/E-502 FOR LIGHTING CONTROL SYSTEM RISER.
 - BAR COUNTER WITH INTEGRATED RGB LED STRIP LIGHT - FIXTURE, ASSOCIATED INTERFACE AND POWER SUPPLY SHALL BE BY DIV. 6. ALL WIRING ASSOCIATED WITH SYSTEM CONNECTION TO LIGHTING CONTROL SYSTEM.
 - EMERGENCY LIGHTING UL924 SWITCHING RELAY - RELAY SHALL BE EQUAL TO LVS, CAT. NO. EPC-A-1/ REFER TO DETAIL A7/E-502 FOR ADDITIONAL WIRING INFORMATION.
 - OCCUPANCY SENSOR CONNECTED TO LIGHTING CONTROL SYSTEM. LOW VOLTAGE WIRING NOT SHOWN FOR CLARITY. REFER TO DETAIL A7/E-502 FOR ADDITIONAL CONNECTION INFORMATION.

REV.	DESCRIPTION	DATE
0	ISSUED FOR BID	06 JUNE 2016

PROJECT NORTH

PROJECT NORTH


WBRC
ARCHITECTS ENGINEERS

WWW.WBRCAE.COM
BANGOR, MAINE 207-947-4511
PORTLAND, MAINE 207-828-4511
SARASOTA, FLORIDA 941-556-0757

PROJECT:
ASYLUM

SHEET TITLE:
BASEMENT LIGHTING PLAN - SEGMENT A

WBRC CAD FILE: C:\Users\laura.mahar\Documents\407110 - ASYLUM DANCE CLUB - ELEC. lyle.mahar.rvt	GRAPHIC SCALE: 0" = 1"
PROJECT No: 4071.10	SHEET No.:
SCALE: 1/4" = 1'-0"	EL101A
PROJECT MANAGER: JRB	CHECKED BY: LW
DRAWN BY: KRM	



A1 BASEMENT LIGHTING PLAN - SEGMENT A
1/4" = 1'-0"

6/3/2016 3:16:20 PM C:\Users\laura.mahar\Documents\407110 - ASYLUM DANCE CLUB - ELEC. lyle.mahar.rvt