



- TECHNICAL NOTES:**
- LOCATE POWER JACKS FOR POS SYSTEM BENEATH WORKTOP, BEHIND BAR TOP.
  - REFER TO TECH NOTE IN THIS LOCATION ON SHEET EY102B FOR WALL BOX INFORMATION.
  - COORDINATE EXACT PLACEMENT OF ELEVATOR CONTROLLER. CONDUITS SHALL BE INSTALLED DOWN FROM THE CEILING TO THE CONTROLLER @ 7'-0" AFF.
  - WINDOW SHADE CONNECTION - REFER TO DETAIL A1/E-302.
  - HVAC CONTROL POWER. LOCATE WITHIN JUNCTION BOX ABOVE CEILING. COORDINATE WITH DIV. 23 CONTRACTOR FOR EXACT LOCATION.
  - CIRCUIT FOR DOOR HARDWARE POWER SUPPLY. LOCATE ABOVE ACCESSIBLE CEILING. COORDINATE EXACT LOCATION IN FIELD WITH SECURITY VENDOR.

0	ISSUED FOR BID	06 JUNE 2016
REV.	DESCRIPTION	DATE

PROJECT NORTH

**WBRC**  
ARCHITECTS ENGINEERS

WWW.WBRCAE.COM  
BANGOR, MAINE 207-947-4511  
PORTLAND, MAINE 207-428-4511  
SARASOTA, FLORIDA 941-556-0757

PROJECT: ASYLUM

SHEET TITLE: FIRST FLOOR POWER PLAN - SEGMENT B

WBRC CAD FILE: C:\Users\jlaplant\Documents\407110 - ASYLUM DANCE CLUB - ELEC - jlaplant.rvt	GRAPHIC SCALE: 0" = 1"
PROJECT No: 4071.10	SCALE: 1/4" = 1'-0"
PROJECT MANAGER: JRB	SHEET No: EP102B
DRAWN BY: KRM	CHECKED BY: SJL

