


TECHNICAL NOTES:

- 1 LOCATE DATA JACKS FOR POS SYSTEM BENEATH WORKTOP
- 2 RECESSED WALL BOX EQUAL TO HUBBELL, CAT. NO. NSAV62M/NSAV62C. LOW VOLTAGE SIDE SHALL RECEIVE (1) TYPE F COAXIAL CONNECTOR, FOR CONNECTION TO CATV SYSTEM, AND (1) DATA JACK FOR CONNECTION TO MEDIA DISTRIBUTION SYSTEM A. REFER TO SHEET EP101A FOR LINE VOLTAGE RECEPTACLE CIRCUIT. FIELD PAINT BOX TRIM AND COVER TO MATCH WALL.
- 3 RECESSED WALL BOX EQUAL TO HUBBELL, CAT. NO. NSAV62M/NSAV62C. LOW VOLTAGE SIDE SHALL RECEIVE (1) TYPE F COAXIAL CONNECTOR, FOR CONNECTION TO CATV SYSTEM, AND (1) DATA JACK FOR CONNECTION TO MEDIA DISTRIBUTION SYSTEM B. REFER TO SHEET EP101A FOR LINE VOLTAGE RECEPTACLE CIRCUIT. FIELD PAINT BOX TRIM AND COVER TO MATCH WALL.
- 4 RECESSED WALL BOX EQUAL TO HUBBELL, CAT. NO. NSAV62M/NSAV62C. LOW VOLTAGE SIDE SHALL RECEIVE (1) DATA JACK FOR CONNECTION TO MENU BOARD DISTRIBUTION SYSTEM. REFER TO SHEET EP101A FOR LINE VOLTAGE RECEPTACLE CIRCUIT. FIELD PAINT BOX TRIM AND COVER TO MATCH WALL.
- 5 EXISTING DEVICES ON EXISTING SURFACES SHALL REMAIN UNLESS SPECIFICALLY NOTED OTHERWISE.
- 6 ALL HDBaseT DATA LINES CONNECTING TO THE MENU BOARD DISTRIBUTION SYSTEM SHALL HOMERUN TO THIS LOCATION. REFER TO DETAIL H7/E-501 FOR SYSTEM RISER DIAGRAM. SIZE JUNCTION BOX AS REQUIRED BY NEC. FACEPLATE SHALL CONSIST OF 2" ROUND PASS THRU OPENING.
- 7 2-GANG JUNCTION BOX TO RECEIVE HDMI, DP AND AUDIO INPUTS, EQUAL TO EXTRON, CAT. NO. DTP T DWP 4K 232 D (WHITE). INPUTS SHALL CONNECT TO MEDIA DISTRIBUTION SYSTEM B AND ASSOCIATED AUDIO SYSTEM.
- 8 4" SQUARE JUNCTION BOX WITH BLANK COVER. PROVIDE 3/4" CONDUIT WITH PULL STRING TO ABOVE ACCESSIBLE CEILING. INTENDED USE IS SECURITY MONITOR. MONITOR AND CABLEING NIC.
- 9 CARD READER / KEY PAD NOTED FOR COORDINATED PURPOSES. CONTRACTOR TO INSTALL 1" CONDUIT WITH PULL STRING FROM DEVICE LOCATION TO ABOVE NEAREST ACCESSIBLE CEILING. PROVIDE 1" CONDUIT WITH PULL STRING FROM CENTER HINGE TO NEAREST ACCESSIBLE CEILING. ALL SECURITY DEVICES AND CABLEING BY OWNER'S SECURITY VENDOR.

REV.	DESCRIPTION	DATE
0	ISSUED FOR BID	06 JUNE 2016



WBRC
ARCHITECTS ENGINEERS
WWW.WBRCAE.COM
BANGOR, MAINE 207-947-4511
PORTLAND, MAINE 207-828-4511
SARASOTA, FLORIDA 941-556-0757

PROJECT:
ASYLUM
BASEMENT SYSTEMS PLAN - SEGMENT A

SHEET TITLE:	
WBRC CAD FILE: C:\Users\jle\msh\Documents\407110 - ASYLUM DANCE CLUB - ELEC. \yfe.msh.rvt	GRAPHIC SCALE: 0" = 1"
PROJECT No: 4071.10	SCALE: 1/4" = 1'-0"
PROJECT MANAGER: JRB	SHEET No:
DRAWN BY: KRM	EY101A
CHECKED BY: SJL	

6/3/2016 3:16:54 PM
 C:\Users\jle\msh\Documents\407110 - ASYLUM DANCE CLUB - ELEC. \yfe.msh.rvt

A1 BASEMENT SYSTEMS PLAN - SEGMENT A
1/4" = 1'-0"