

EXHAUST FAN INFORMATION - Job#2531812

FAN UNIT NO.	TAG	FAN UNIT MODEL #	CFM	ESP.	RPM	H.P.	B.H.P.	Ø	VOLT	FLA	WEIGHT (LBS.)	SDNES
1		NCA16FA	2833	0.850	1010	1.500	0.7870	1	230	10.2	167	11.7
2		NCA16FA	2833	0.850	1010	1.500	0.7870	1	230	10.2	167	11.7

MUA FAN INFORMATION - Job#2531812

FAN UNIT NO.	TAG	FAN UNIT MODEL #	BLOWER	HOUSING	CFM	ESP.	RPM	H.P.	B.H.P.	Ø	VOLT	FLA	WEIGHT (LBS.)	SDNES
3		A2-G15	G15-PB	AE	4532	0.500	646	2.000	1.5110	1	230	9.3	383	11.3

FAN OPTIONS

FAN UNIT NO.	TAG	OPTION (Qty. - Descr.)
1		1 - Grease Box
1		1 - Fan Base Ceramic Seal - For Grease Ducts
2		1 - Grease Box
2		1 - Fan Base Ceramic Seal - For Grease Ducts
3		1 - Gravity Backdraft Damper for Size 2 Housing

FAN ACCESSORIES

FAN UNIT NO.	TAG	EXHAUST		SUPPLY	
		GREASE CUP	WALL MOUNT DAMPER	GRAVITY DAMPER	MOTORIZED WALL MOUNT
1		YES			
2		YES			
3				YES	

CURB ASSEMBLIES

DN FAN NO.	DN FAN TAG	WEIGHT	ITEM	SIZE
1	# 1	34 LBS	Curb	26.500"L x 26.500"H Vented Hinged
2	# 2	34 LBS	Curb	26.500"L x 26.500"H Vented Hinged
3	# 3	50 LBS	Curb	31.000"L x 31.000"H Vented Hinged



JOB Asylum
 LOCATION Monmouth, ME,
 DATE 1/8/2016
 DWG # 5
 JOB # 2531812
 DRAWN BY BFC-21
 SCALE 3/8" = 1'-0"