



... Fire Protection by Computer Design

HIGH TECH FIRE PROTECTION
84 HACKETT MILLS ROAD
P.O. BOX 156
POLAND, ME 04274
207-998-2551

Job Name : Asylum Stage Open area calc #1
Drawing : FP-02
Location : 121 Center Street Portland
Remote Area : #1
Contract : 062716-1
Data File : Stage calc.WXF

HYDRAULIC CALCULATIONS
for

Project name: Asylum Stage Open area calc
Location: 121 Center Street Portland
Drawing no: FP-02
Date: 10/20/16

Design

Remote area number: #1
Remote area location: Addition Stage High Ceiling
Occupancy classification: Ordinary Hazard Group 2
Density: .2 - Gpm/SqFt
Area of application: 1500 - SqFt
Coverage per sprinkler: 113 - SqFt
Type of sprinklers calculated: Quick Response Upright
No. of sprinklers calculated: 18
In-rack demand: N/A - GPM
Hose streams: 250 - GPM
Total water required (including hose streams): 428 - GPM @ 65 - Psi
Type of system: Wet
Volume of dry or preaction system: N/A - Gal

Water supply information

Date: 10/18/16
Location: Hydrant in front of building
Source: Portland Water District

Name of contractor: HIGH TECH FIRE PROTECTION
Address: 84 HACKETT MILLS ROAD / P.O. BOX 156 / POLAND, ME 04274
Phone number: 207-998-2551
Name of designer: Ed Poulin
Authority having jurisdiction: State of Maine / City of Portland
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
Asylum Stage Open area calc #1

Page 2
Date 9/22/16

City Water Supply:
C1 - Static Pressure : 81
C2 - Residual Pressure: 79
C2 - Residual Flow : 1403

Demand:
D1 - Elevation : 18.190
D2 - System Flow : 427.555
D2 - System Pressure : 64.513
Hose (Demand) :
D3 - System Demand : 427.555
Safety Margin : 16.265



Fittings Used Summary

HIGH TECH FIRE PROTECTION
Asylum Stage Open area calc #1

Page 3
Date 9/22/16

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' EII Firelock #001	0	0	0	0	3.5	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	8	8.5	10.8	13	0	16	21	25	33	0	0	0	0	0	0	0
Zib	Wilkins 350A	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
Asylum Stage Open area calc #1

Page 4
Date 9/22/16

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
300	44.0	5.6	18.54	na	24.11	0.2	113	7.0
301	44.0	5.6	18.59	na	24.14	0.2	113	7.0
302	44.0	5.6	18.74	na	24.25	0.2	113	7.0
303	44.0	5.6	19.08	na	24.46	0.2	113	7.0
310	44.0	5.6	16.29	na	22.6	0.2	113	7.0
311	44.0	5.6	16.37	na	22.66	0.2	113	7.0
312	44.0		16.37	na				
313	44.0	5.6	16.52	na	22.76	0.2	113	7.0
314	44.0	5.6	16.86	na	22.99	0.2	113	7.0
315	44.0	5.6	17.6	na	23.49	0.2	113	7.0
316	44.0	5.6	18.29	na	23.95	0.2	113	7.0
320	44.0	5.6	16.74	na	22.91	0.2	113	7.0
321	44.0	5.6	16.83	na	22.97	0.2	113	7.0
322	44.0		16.83	na				
323	44.0	5.6	16.98	na	23.08	0.2	113	7.0
324	44.0	5.6	17.33	na	23.31	0.2	113	7.0
325	44.0	5.6	18.09	na	23.82	0.2	113	7.0
326	44.0	5.6	18.79	na	24.27	0.2	113	7.0
330	44.0	5.6	21.34	na	25.87	0.2	113	7.0
331	44.0	5.6	21.39	na	25.9	0.2	113	7.0
AA	44.0		20.44	na				
AB	44.0		20.56	na				
AC	44.0		21.12	na				
AD	44.0		22.11	na				
AE	44.0		24.23	na				
AF	28.0		32.18	na				
AG	28.0		35.56	na				
AH	28.0		35.89	na				
AI	8.0		45.49	na				
AJ	8.0		46.48	na				
AK	8.0		52.16	na				
TOR	6.0		54.21	na				
BOR	2.0		59.35	na				
BASE	-2.0		65.79	na				
H1	-2.0		66.08	na				
H2	-2.0		66.1	na				
TEST	2.0		64.51	na				

The maximum velocity is 14.44 and it occurs in the pipe between nodes AC and AD

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
Asylum Stage Open area calc #1

Page 5
Date 9/22/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
300 to 301	24.11	2.157 120.0		0.0	9.000	18.537 0.0			K Factor = 5.60	
301 to 302	24.11	0.0054		0.0	9.000	0.049			Vel = 2.12	
301 to 302	24.14	2.157 120.0		0.0	8.000	18.586 0.0			K Factor = 5.60	
302 to 303	48.25	0.0199		0.0	8.000	0.159			Vel = 4.24	
302 to 303	24.25	2.157 120.0		0.0	8.000	18.745 0.0			K Factor = 5.60	
303 to AA	72.5	0.0421		0.0	8.000	0.337			Vel = 6.37	
303 to AA	24.46	2.157 120.0	1T	12.307	6.500	19.082 0.0			K Factor = 5.60	
	96.96	0.0721		0.0	18.807	1.356			Vel = 8.51	
	0.0 96.96					20.438			K Factor = 21.45	
310 to 312	22.60	2.157 120.0	1X	10.461	7.500	16.287 0.0			K Factor = 5.60	
	22.6	0.0049		0.0	17.961	0.088			Vel = 1.98	
	0.0 22.60					16.375			K Factor = 5.58	
311 to 312	22.66	2.157 120.0		0.0	0.500	16.372 0.0			K Factor = 5.60	
312 to 313	22.66	0.0060		0.0	0.500	0.003			Vel = 1.99	
312 to 313	22.60	2.157 120.0		0.0	8.500	16.375 0.0				
313 to 314	45.26	0.0175		0.0	8.500	0.149			Vel = 3.97	
313 to 314	22.76	2.157 120.0		0.0	9.000	16.524 0.0			K Factor = 5.60	
314 to 315	68.02	0.0374		0.0	9.000	0.337			Vel = 5.97	
314 to 315	23.00	2.157 120.0		0.0	11.500	16.861 0.0			K Factor = 5.60	
315 to 316	91.02	0.0642		0.0	11.500	0.738			Vel = 7.99	
315 to 316	23.49	2.157 120.0		0.0	7.000	17.599 0.0			K Factor = 5.60	
316 to AB	114.51	0.0981		0.0	7.000	0.687			Vel = 10.05	
316 to AB	23.95	2.157 120.0	1T	12.307	4.000	18.286 0.0			K Factor = 5.60	
	138.46	0.1394		0.0	16.307	2.273			Vel = 12.16	
	0.0 138.46					20.559			K Factor = 30.54	
320 to 322	22.91	2.157 120.0	1X	10.461	7.500	16.740 0.0			K Factor = 5.60	
	22.91	0.0050		0.0	17.961	0.090			Vel = 2.01	
	0.0 22.91					16.830			K Factor = 5.58	
321 to 322	22.97	2.157 120.0		0.0	0.500	16.827 0.0			K Factor = 5.60	
322 to 323	22.97	0.0060		0.0	0.500	0.003			Vel = 2.02	
322 to 323	22.91	2.157 120.0		0.0	8.500	16.830 0.0				
	45.88	0.0181		0.0	8.500	0.154			Vel = 4.03	

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
Asylum Stage Open area calc #1

Page 6
Date 9/22/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
323 to 324	23.08 68.96	2.157 120.0 0.0383		0.0	9.000	16.984 0.0			K Factor = 5.60	
324 to 325	23.31 92.27	2.157 120.0 0.0658		0.0	11.500	17.329 0.0			Vel = 6.05	
325 to 326	23.82 116.09	2.157 120.0 0.1006		0.0	7.000	18.086 0.0			K Factor = 5.60	
326 to AC	24.27 140.36	2.157 120.0 0.1429	1T	12.307	4.000 12.307 16.307	18.790 0.0 2.331			K Factor = 5.60	
	0.0 140.36								21.121	K Factor = 30.54
330 to 331	25.87 25.87	2.157 120.0 0.0062		0.0	8.000	21.344 0.0			K Factor = 5.60	
331 to AD	25.90 51.77	2.157 120.0 0.0226	2V 1T	8.615 12.307	11.000 20.922 31.922	21.394 0.0 0.721			K Factor = 5.60	
	0.0 51.77								22.115	K Factor = 11.01
AA to AB	96.96 96.96	3.26 120.0 0.0097		0.0	12.500	20.438 0.0				
AB to AC	138.46 235.42	3.26 120.0 0.0497		0.0	11.300	20.559 0.0			Vel = 3.73	
AC to AD	140.36 375.78	3.26 120.0 0.1183		0.0	8.400	21.121 0.0			Vel = 9.05	
AD to AE	51.78 427.56	4.26 120.0 0.0408	3V	26.861	25.000 26.861 51.861	22.115 0.0 2.116			Vel = 14.44	
AE to AF	0.0 427.56	4.26 120.0 0.0408	1V	8.954	16.000 8.954 24.954	24.231 6.930 1.018			Vel = 9.62	
AF to AG	0.0 427.56	4.26 120.0 0.0408	3V	26.861	56.000 26.861 82.861	32.179 0.0 3.382			Vel = 9.62	
AG to AH	0.0 427.56	4.26 120.0 0.0408		0.0	8.000	35.561 0.0			Vel = 9.62	
AH to AI	0.0 427.56	4.26 120.0 0.0408	1V	8.954	14.000 8.954 22.954	35.887 8.662 0.937			Vel = 9.62	
AI to AJ	0.0 427.56	4.26 120.0 0.0408	1X	21.067	3.300 21.067 24.367	45.486 0.0 0.994			Vel = 9.62	

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
Asylum Stage Open area calc #1

Page 7
Date 9/22/16

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
AJ to AK	0.0 427.56	4.26 120.0 0.0408	4V 1T	35.814 26.334 0.0	77.000 62.148 139.148	46.480 0.0 5.679		Vel = 9.62	
AK to TOR	0.0 427.56	4.026 120.0 0.0537	1T	20.0 0.0 0.0	2.000 20.000 22.000	52.159 0.866 1.182		Vel = 10.78	
TOR to BOR	0.0 427.56	4.26 120.0 0.0409	1Fsp 1V	0.0 8.954 0.0	1.000 8.954 9.954	54.207 4.732 0.407		* Fixed loss = 3 Vel = 9.62	
BOR to BASE	0.0 427.56	4.26 120.0 0.0408	1Zib 1E	0.0 13.167 0.0	1.000 13.167 14.167	59.346 5.862 0.578		* Fixed loss = 4.13 Vel = 9.62	
BASE to H1	0.0 427.56	6.16 140.0 0.0051	1G 1T	4.304 43.037 0.0	10.000 47.341 57.341	65.786 0.0 0.292		Vel = 4.60	
H1 to H2	0.0 427.56	12.24 100.0 0.0003	1T	48.362 0.0 0.0	5.000 48.362 53.362	66.078 0.0 0.018		Vel = 1.17	
H2 to TEST	0.0 427.56	6.16 140.0 0.0051	1G 1E	4.304 20.084 0.0	5.000 24.388 29.388	66.096 -1.732 0.149		Vel = 4.60	
	0.0 427.56					64.513		K Factor = 53.23	