


Front View
30 City Center

High temp Clean Out



16 gauge steel grease duct solid welded
Then wrap in 3m grease duct wrap
Above Loft.

Top off hood 2" min wool
Insulation non combustible
with 2" Air space

Loft

make up air duct work
24ga galv steel.

Tile wall on 5/8 sheetrock

84"

Floor

Borgeson + Sons LLC
Dan Borgeson
749-1878