Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 03/25/16

BOUNDARY FOR GROSS AREA FOR OCCUPANT LOAD CALCULATION

AREA FOR OCCUPANT LOAD: 3409 SF
OCCUPANT LOAD FOR BUSINESS =
1/100 SF = 34 OCCUPANTS

EGRESS WIDTHS
36" WIDTH MINIMUM
PROVIDED AT
DOORS
STAIRS
AISLES
EXIT ACCESS

1ST FLOOR 12'-0"
1/8" = 1'-0"

RM Davis, 24 City Center, Portland, Maine
Tenant Improvement
1st floor code and life safety

LICENSED ARCHITECT
Josef Chalat
AR2354
STATE OF MAINE