DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

CITY OF PORTLAND

Located at

456 CONGRESS ST

PERMIT ID: 2014-02055

ISSUE DATE: 09/11/2014

CBL: 027 G001001

has permission to
Tent and staging permit application for Sept. 13 Portland Greenfest

tents and 1 stage

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ David Petruccelli

/s/ Jeanie Bourke

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning
Public Space - Monument Square

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 09/08/2014 2014-02055 027 G001001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: Proposed Project Description: Monument Sq Tent event for Portland Greenfest Tent and staging permit application for Sept. 13 Portland Greenfest tents and 1 stage **Dept:** Zoning Status: Approved Reviewer: Marge Schmuckal **Approval Date:** 09/09/2014 Ok to Issue: Note: **Conditions:**

Dept: Building **Status:** Approved w/Conditions **Reviewer:** Jeanie Bourke **Approval Date:** 09/11/2014

Note: Ok to Issue: ✓

Conditions:

- 1) 108.2 Conformance. Temporary structures and uses shall conform to the structural strength, fire safety, means of egress, accessibility, light, ventilation and sanitary requirements of this code as necessary to ensure public health, safety and general welfare.
- 2) A separate permit is required for any temporary electrical work.
- 3) This permit DOES NOT authorize any construction activities. The tent/stage must be removed at the end of the event.

Dept: Fire **Status:** Approved w/Conditions **Reviewer:** David Petruccelli **Approval Date:** 09/11/2014 **Note:** Ok to Issue: ✓

Conditions:

- 1) 12.4.5.2 Platform Construction.
 - 12.4.5.2.1 Temporary platforms shall be permitted to be constructed of any materials.
 - 12.4.5.2.2 The space between the floor and the temporary platform above shall not be used for any purpose other than the electrical wiring to platform equipment.
- 2) All tents shall meet the flame propagation performance criteria contained in NFPA 701. A certificate or other evidence of acceptance by an organization acceptable to the AHJ shall serve as evidence that the tent fabric materials have the required flame propagation performance.
- 3) If the sides of the tents are to be enclosed at least two remotely located and marked exits shall be provided.
- 4) Tents shall have an approved fire resistant rating and maintain 10' between stake lines. No smoking or open flame allowed within 10'. Provide at least one 2A:10 BC fire extinguisher.
- 5) Tents shall have an approved fire resistant rating and maintain 10' between stake lines. No smoking or open flame allowed within 10'. Provide at least one 2A:10 BC fire extinguisher.
- 6) Fuel-fired heating equipment and propane tanks shall be installed outside of the tents and not with 5 feet of the tents or an exit discharge.
- 7) Cooking within the tents has not been reviewed and approved.
- 8) Tents shall have an approved fire resistant rating and maintain 10' between stake lines. No smoking or open flame allowed within 10'. Provide at least one 2A:10 BC fire extinguisher.
- 9) 12.4.5 Stages and Platforms. See 3.3.262 and 3.3.209.
 - 12.4.5.1 Materials and Design.
 - 12.4.5.1.1 Materials used in the construction of platforms and stages shall conform to the applicable requirements of the local building code.
- 10 If the sides of the tents are to be enclosed at least two remotely located and marked exits shall be provided.
- 11 Installation shall comply with City Code Chapter 10.