DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

CITY OF PORTLAND

Located at

456 CONGRESS ST

PERMIT ID: 2014-02111

ISSUE DATE: 10/03/2014

CBL: 027 G001001

has permission to Tent event for 2014 Iris Network. 1 tent. October 18th - White Cane Awareness Walk

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Laurie Leader

Fire Official

PERMIT ID: 2014-02111

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning
Public Space - Monument Square

Building Inspections

Fire Department

Located at: 456 CONGRESS ST CBL: 027 G001001

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of	Portland, N	Maine - Building or Use Permit	Permit No:	Date Applied For:	CBL:		
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 87 Proposed Use:				2014-02111	09/12/2014	027 G001001	
				Proposed Project Description:			
Same: Public Space - Monument Sq				Tent event for 2014 Iris Network. 1 tent. October 18th - White Cane Awareness Walk			
Dept:	Historic	Status: Approved	Reviewer:	Robert Wiener	Approval Da	nte: 10/02/2014	
Note:						Ok to Issue: 🔽	
Condit	tions:						
Dept:	Zoning	Status: Approved	Reviewer:	Marge Schmucka	al Approval Da	nte: 09/18/2014	
Note:						Ok to Issue: 🔽	
Condit	tions:						
Dept:	Building	Status: Approved w/Conditions	Reviewer:	Laurie Leader	Approval Da	nte: 10/01/2014	
Note:						Ok to Issue: 🗹	
Condit	tions:						

- 1) 108.2 Conformance. Temporary structures and uses shall conform to the structural strength, fire safety, means of egress, accessibility, light, ventilation and sanitary requirements of this code as necessary to ensure public health, safety and general welfare.
- 2) A separate permit is required for any temporary electrical work.
- 3) This permit DOES NOT authorize any construction activities. The tent/stage must be removed at the end of the event.
- 4) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.

 Dept:
 Fire
 Status:
 Approved w/Conditions
 Reviewer:
 Craig Messinger
 Approval Date:
 09/18/2014

 Note:
 Ok to Issue:
 ✓

Conditions:

- 1) Fire extinguishers will be required per NFPA 10.
- 2) Fuel-fired heating equipment and propane tanks shall be installed outside of the tents and not with 5 feet of the tents or an exit discharge.
- 3) If the sides of the tents are to be enclosed at least two remotely located and marked exits shall be provided.
- 4) Tents shall have an approved fire resistant rating and maintain 10' between stake lines. No smoking or open flame allowed within 10'. Provide at least one 2A:10 BC fire extinguisher.
- 5) Tents shall have an approved fire resistant rating and maintain 10' between stake lines. No smoking or open flame allowed within 10'. Provide at least one 2A:10 BC fire extinguisher.