DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





This is to certify that

CITY OF PORTLAND

Located at

456 CONGRESS ST

PERMIT ID: 2016-02230 **ISSUE DATE:** 09/02/2016

CBL: 027 G001001

has permission to Erect 10x10 size Canopy and 20x40 and 20x50 tents setup and breakdown 9/10/16 provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Michael White /s/ Jonathan Rioux

Fire Official Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases 6 months.
- If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop W Order" and subsequent release to continue.

REQUIRED INSPECTIONS:

Site VISIT

Final Inspection

The project cannot move to the next phase prior to the required inspection and approva to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 08/22/2016 2016-02230 027 G001001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: Proposed Project Description: Erect 10x10 size Canopy and 20x40 and 20x50 tents setup and Monument Sq breakdown 9/10/16 **Dept:** Zoning Status: Approved **Reviewer:** Christina Stacey **Approval Date:** 09/02/2016 Ok to Issue: Note: **Conditions:** 09/02/2016 Building Inspecti **Status:** Approved w/Conditions Reviewer: Jonathan Rioux **Approval Date:** Dept: Note: Ok to Issue:

Conditions:

1) 108.2 Conformance. Temporary structures and uses shall conform to the structural strength, fire safety, means of egress, accessibility, light, ventilation and sanitary requirements of this code as necessary to ensure public health, safety and general welfare. Field modification may be required.

108.3 Temporary power. The building official is authorized to give permission to temporarily supply and use power in part of an electric installation before such installation has been fully completed and the final certificate of completion has been issued. The part covered by the temporary certificate shall comply with the requirements specified for temporary lighting, heat or power in NFPA 70

This permit DOES NOT authorize any construction activities. The tent(s)/ stage must be removed at the end of the event.

A separate permit is required for any temporary electrical work.

Application approval based upon information provided by applicant. Any deviation from approved plans requires separate review and approval prior to work.

Dept: Fire **Status:** Approved w/Conditions **Reviewer:** Michael White **Approval Date:** 08/30/2016 **Note:** Ok to Issue: ✓

Conditions:

- 1) Cooking within the tents has not been reviewed and approved.
- 2) Fuel-fired heating equipment and propane tanks shall be installed outside of the tents and not with 5 feet of the tents or an exit discharge.
- 3) Tents shall have an approved fire resistant rating and maintain 10' between stake lines. No smoking or open flame allowed within 10'. Provide at least one 2A:10 BC fire extinguisher.
- 4) If the sides of the tents are to be enclosed at least two remotely located and marked exits shall be provided.
- 5) All tents shall meet the flame propagation performance criteria contained in NFPA 701. A certificate or other evidence of acceptance by an organization acceptable to the AHJ shall serve as evidence that the tent fabric materials have the required flame propagation performance.
- 6) All means of egress to remain accessible at all times.
- 7) All construction shall comply with 2009 NFPA 101, Chapter 11 Special Structures and High Rise Buildings.
- 8) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4).
- 9) All construction shall comply with City Code, Chapter 10.