

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

CLARK BOX LLC

Located at

312 CONGRESS ST

PERMIT ID: 2015-03033

ISSUE DATE: 01/25/2016

CBL: 028 C004001

has permission to **Renovations to 1 bedroom apt; #34, to include removing wall, adding insulation, new studs and sheetrock, replacement windows and door, new cabinets and bathroom fixtures.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

Multi-family - 20 units

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing

Electrical - Commercial

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-03033	Date Applied For: 12/17/2015	CBL: 028 C004001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Multi family	Proposed Project Description: Renovations to 1 bedroom apt; #34, to include removing wall, adding insulation, new studs and sheetrock, replacement windows and door, new cabinets and bathroom fixtures.			
Dept: Historic	Status: Approved w/Conditions	Reviewer: Robert Wiener	Approval Date: 01/05/2016	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) All components of exterior decks and stairs are to be painted or stained with a solid, opaque color when weather and wood moisture content permits - to be completed by 6/15/16.				
2) All future window replacement proposals for this property must be reviewed and approved separately, and shall be evaluated based on location in the building, and on the window types in neighboring openings.				
3) Windows to be replaced (5 in number) are to have white wood exterior trim to match new window color and previously replaced windows.				
Dept: Zoning	Status: Approved	Reviewer: Christina Stacey	Approval Date: 12/29/2015	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
Dept: Building Inspecti	Status: Approved w/Conditions	Reviewer: Tammy Munson	Approval Date: 01/15/2016	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) All floors and walls that separate dwelling units or dwelling units and common areas are required to meet a 1 hour fire rated assembly and sound transmission rating of 45 STC.				
3) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 01/25/2016	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Shall comply with NFPA 101, Chapter 31, Existing Apartment Buildings.				
2) Shall meet the requirements of 2009 NFPA 1 Fire Code.				
3) All construction shall comply with City Code Chapter 10.				